

INFORMATION SHEET FOR PROCUREMENT OF CABLES

Reference No.: FNK-I/IUL/2021/230

Issued on 18th May 2021

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





Section I: Instruction to Bidders

A. General	A. General					
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for				
		cables in accordance with Section III, Technical				
		Specifications				
	1.2	It is in Fenaka Corporation Limited's discretion to cancel				
		the bid invitation mentioned in 1.1 at any time.				
2. Eligible Participants	2.1	Local companies registered in Maldives are eligible to participate in the tender Foreign companies are eligible to participate in the				
	2.2					
		tender only if the total bid value is above 2,500,000				
		Maldivian Rufiyaa.				
B. Preparation of the Bid						
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly indicated in the quotation				
	3.2	All items shall be quoted in the bid (please refer to				
		Section III, Technical Specifications for the details of				
		required items)				
	3.3	Quotation shall separately indicate the additional				
		charges such as freight charges, insurance, etc.				
	3.4	The bidder shall submit quotation on CIF basis to Male'				
		port				
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa				
5. Alternative Bids	5.1	Bidders can submit a maximum of two (2) options				
6. Validity of Bids	6.1	Quotation shall remain valid for minimum sixty (60)				
		days from the date of bid opening				

Page 2 of 7














7. Bid Security	7.1	All bids should be accompanied with a bid security of			
		USD 5,000 (Five Thousand US Dollars) or its equivalent			
		in Maldivian Rufiyaa			
	7.2	The bid security should be:			
		- Original bank guarantee letter (or)			
		- Bank guaranteed and stamped check (or)			
		- An insurance policy from an insurance company			
		registered at Maldives Monetary Authority.			
	7.3	Any bid not accompanied by a Bid Security shall be			
		rejected during bid opening			
	7.4	The bid security must be valid for a minimum of twenty			
		(20) additional days beyond the validity of quotation			
8. Technical	8.1	All relevant information including the brand shall be			
Compliance		given to enable technical evaluation of quoted items			
	8.2	The quoted brand of cables must be approved by Utility			
		Regulatory Authority (URA)			
	8.3	Fenaka Corporation Limited will only accept items that			
		meet OEM standards			
	8.4	If the goods do not comply with the requirements			
		mentioned in Section III, Technical Specifications, the			
		bid will be rejected during evaluation			
	8.5	In case supplied items do not meet the required items,			
		they will be rejected and returned			
9. Documents	9.1	Quotation (inclusive of the delivery period and payment			
Comprising the Bid		terms)			
	9.2	Specifications of the offered product			
	9.3	Details of the company			
		- Company profile/background			
		- Company registration certificate			
•	•	<u>'</u>			

Page 3 of 7















		- GST registration certificate (for local bidders only)			
		- TAX clearance report (6 months validity)			
		- Contact details (name, designation, mobile number			
		and e-mail address)			
	9.4	Experience letters, if available			
		- Letters within past five (5) years			
		- Relevant experience letters			
		- Letters with project name and value			
	9.5	Utility Regulatory Authority (URA) approval certificate			
	9.6	One (1) compact disc with original bid document			
		scanned and written			
10. Format of Bid	10.1	The Bidder shall submit two (2) sets of the bid docum			
		(1 original and 1 copy), enclosed separately in two			
		envelopes and sealed with company stamp			
	10.2	All pages of the bid document shall be stamped and			
		bound properly (excluding the bid security)			
C. Bid Submission					
11. Sealing and	11.1	The bid document shall be sealed properly in an			
Marking Bid		envelope clearly marked 'ORIGINAL' or 'COPY', with			
Document		the name of the company and the tender reference			
		number (FNK-I/IUL/2021/230)			
12. Bid Opening	12.1	The bids will be opened on 31st May 2021, 1200hrs in			
		the presence of bidders			
	12.2	Bids will be opened at:			
		Fenaka Corporation Limited			
		Hilaalee Magu, K. Male', Republic of Maldives			
	12.3	Bids received electronically will not be accepted			
13. Bid Rejection	13.1	Bidders that arrive after bid submission deadline shall			
		not be able to participate in the bid			
1	1				

Page 4 of 7

















13.2	Bidders that do not register for the tender are unable to			
	participate in the bid opening			
13.3	Bids lacking the documents mentioned in 9. Documents			
	Comprising the Bid (except 9.4 Experience letters and			
	9.5 MEA approval certificate) and that do not comp			
	with 10. Format of Bid are subjected to be rejected			
D. Awarding of Contract				
14.1	The awarded vendor shall provide the approval letter			
	from Utility Regulatory Authority (URA) prior to			
	signing the agreement			
14.2	The cables must be packed in accordance with the list			
	given in Section III: Technical Specifications to avoid			
	rejection			
15.1	An advance payment will not be released for this project			
	13.3 ract 14.1			

Page 5 of 7













Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

(Lowest price / proposed price) x 70

Delivery: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 20
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

(Proposed credit period / longest credit period) x 10











Page 6 of 7





Section III: Technical Specifications

#	DESCRIPTION	QTY	PACKAGING (meter per drum)
1	CABLE 4C x 95SQMM CU/XLPE/PVC/SWA/PVC/600/1000V	2000	500*4
2	CABLE 4C x 70SQMM CU/XLPE/PVC/SWA/PVC/600/1000V	2200	500*4 200*2
3	CABLE 4C x 50SQMM CU/XLPE/PVC/SWA/PVC/600/1000V	2000	500*4
4	CABLE 4C x 35SQMM CU/XLPE/PVC/SWA/PVC/600/1000V	600	500*1 100*1



(Outer cover of cable drum must be properly packed and covered as per the picture above)

Page 7 of 7







