

INFORMATION SHEET FOR PROCUREMENT OF 500KVA and 1500KVA TRANSFORMERS

Reference No: FNK-I/IUL/2021/253

Issued on: 09th June 2021

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





Section I: Instruction to Bidders

A. General			
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for transformers	
		in accordance with Section III, Technical Specifications	
	1.2	It is in Fenaka Corporation Limited's discretion to cancel this bid	
		invitation at any time.	
2. Eligible	2.1	Local companies registered in Maldives are eligible to participate	
Participants		in the tender	
	2.2	Foreign companies are eligible to participate in the tender only if	
		the total bid value is above 2,500,000 Maldivian Rufiyaa.	
B. Preparation of the Bid			
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly	
		indicated in the quotation	
	3.2	All items shall be quoted in the bid (please refer to Section III,	
		Technical Specifications for the details of required items)	
	3.3	Quotation shall separately indicate the additional charges such as	
		freight charges, insurance, etc.	
	3.4	The bidder shall submit quotation on CIF basis to Male' port	
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa	
5. Alternative Bids	5.1	Bidders can submit a maximum of two (2) options	
6. Validity of Bids	6.1	Quotation shall remain valid for minimum sixty (60) days from	
		the date of bid opening	
7. Bid Security	7.1	All bids should be accompanied with a bid security of USD	
		10,000 (Ten Thousand US Dollars) or its equivalent in Maldivian	
		Rufiyaa	
	7.2	The bid security should be:	
		- Original bank guarantee letter (or)	
		- Bank guaranteed and stamped check (or)	

Page 2 of 8













		- An insurance policy from Maldives Monetary Authority	
		(MMA) registered insurance company	
	7.3	Any bid not accompanied by a Bid Security shall be rejected	
		during bid opening	
	7.4	The bid security must be valid for a minimum of twenty (20)	
		additional days beyond the validity of quotation	
8. Technical	8.1	All relevant information including the brand shall be given to	
Compliance		enable technical evaluation of quoted items	
	8.2	If the manufacturer or assembler is not the same as the bidder, a	
		document indicating that manufacturer or assembler is willing to	
		sell the generator set to the bidder is required	
	8.3	Technical compliance letter will be required to enable technical	
		evaluation	
	8.4	If the goods do not comply with the requirements mentioned in	
		Section III, Technical Specifications, the bid will be rejected	
		during evaluation.	
9. Documents	9.1	Quotation (inclusive of the delivery period and payment terms)	
Comprising the	9.2	Specifications of the offered product	
Bid	9.3	Single-line diagram of engine panel system	
	9.4	Details of the company	
		- Company profile/background	
		- Company registration certificate	
		- GST registration certificate (for local bidders only)	
		- TAX clearance report (6 months validity)	
		- Contact details (name, designation, mobile number and e-mail	
		address)	
	9.5	Experience letters, if available	
		- Letters within past five (5) years	
		- Relevant experience letters	
		- Letters with project name and value	

Page 3 of 8














	9.6	One (1) compact disc with original bid document scanned and		
		written		
	9.7	Bids lacking the documents above are subjected to be rejected		
		during the bid opening		
10. Format of Bid	10.1	The Bidder shall submit two (2) sets of the bid document (1		
		original and 1 copy), enclosed separately in two envelopes and		
		sealed with company stamp		
	10.2	All pages of the bid document shall be stamped and bound		
		properly (excluding the bid security)		
C. Bid Submission				
11. Sealing and	11.1	The bid document shall be sealed properly in an envelope clearly		
Marking Bid		marked 'ORIGINAL' or 'COPY', with the name of the company		
Document	Document and the tender reference number (FNK-I/IUL/2021/253)			
12. Bid Opening	12.1	The bids will be opened on 21st June 2021, 1100hrs in the presence		
		of bidders		
	12.2	Bids will be opened at:		
		Fenaka Corporation Limited		
		Hilaalee Magu, K. Male', Republic of Maldives		
	12.3	Bids received electronically will not be accepted		
13. Bid Rejection	13.1	Fenaka Corporation Limited shall not consider any bidders that		
		arrive after the deadline for submission		
	13.2	Bidders that do not register for the tender are unable to participate		
		in the bid opening		
	13.3	Bids lacking the documents mentioned in 9. Documents		
		Comprising the Bid (except 9.5 Experience letters) and that do not		
		comply with 10. Format of Bid are subjected to be rejected		
D. Awarding of Contract				
14. Payment	14.1	An advance payment will not be released for this project		
Terms				

Page 4 of 8















15. Factory	15.1	Supplied items shall be fully tested at the manufacturer workshop	
Acceptance		in the presence of Client's appointees via video conferencing	
Testing	15.2	The testing shall be conducted at internationally accepted testing	
		standards	
	15.3	The items shall undergo protection testing and operation testing	
	15.4	The items shall be checked for dimension and the supplier shall	
		provide the dimensions of the panel during the virtual factory	
		acceptance testing.	
	15.5	Video recorded while operating the units will not be accepted as	
		virtual factory acceptance testing.	

Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

- (Lowest price / proposed price) x 70


Delivery: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 20
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

- (Proposed credit period / longest credit period) x 10

Page 5 of 8















Section III: Technical Specifications

(Specification provided is for one unit)

Description	Quantity
500 KVA Step-Up Transformer	02
1500 KVA Step-Up Transformer	02

500 kVA Step-Down Transformer with Separate LV panel & 3 Way RMU (Quantity: 02 Nos)

Climatic Conditions

Materials supplied shall be suitable for operating under the following climatic conditions

Climate: Typical tropical coast line.

Atmosphere: Saliferous, corrosive and dusty. Altitude: 2 meter above mean sea water level.

Temperature: 32°C (mean maximum) 25°C (mean minimum).

Barometric air pressure: 1010 millibars.

Relative humidity: 90%.

Average rainfall : 145 days/year. Average sunshine : 24 days/month. Mean wind speed : 10.8 knots. Maximum wind speed : 15.1 knots.


A) Step-Down Transformer 11kV/415V, 500kVA

3 phase 50Hz 500kVA Dyn11, core type double wound with copper conductor, mineral oil immersed ONAN cooled distribution transformer with corrugated tank or conservator arrangement having a no-load voltage ratio of 11/0.433 KV. Tappings +5% to -5% in steps of 2.5% shall be provided at line end of HV winding. Changing of taps shall be carried out by means of OFF Load Tap Changer.

Temperature rise shall be $50/60\,^{\circ}\text{C}$ in oil/winding respectively over a maximum ambient of $40\,^{\circ}\text{C}$. The transformer shall be manufactured as per latest IEC.

HV Insulation Level 12kV
Power frequency 28kV. r.m.s.
Basic Impulse Level 75kV. Peak.
HV/LV Connection Delta/ Star N. pt
Dial type thermometer with contacts and control box for relays.
level indicator and pressure relief valve and oil drain valve.
Hermetically sealed without gas cushion.
Relevant testing standards: IEC / BS standards.

Page 6 of 8















B) Separate LV Panel for Transformer

Free standing LV Panel with 1200A, PVC sleeved Cu busbar, complete with measuring, indication and protection (ELR).


Incoming

1 Nos x 800A ACB motorized - main circuit breaker

Outgoing

- 4 Nos x Outgoing feeder with 300A MCCB
- 6 Nos x Outgoing feeder with 250A MCCB
- Bottom entry Cable Termination arrangement.
- · Complete with nuts and bolts to connect LV cables.
- C) 1Nos x 3 Way Non Extensible Unit with 2 Nos. Isolators as Incomers and 1 No. Circuit Breaker as Outgoing to 500kVA Transformer ((TYPE Ringmaster : Merlin Gerin RM6 NE-IDI or equivalent)

3 Way, 11kV, indoor extensible free standing metal clad SF6 insulated ring main unit compromising of three numbers 630A fault making/ load breaking switches and one number 200A tee-off circuit breakers complete with all necessary measurement and protection devices.















Specification for Step-Up Transformer 1500 kVA Power Transformer (Quantity: 02 Nos)

3 Phase 50 Hz 1500 kVA Ynd1, core type double wound with copper conductor mineral oil immersed ONAN cooled power transformer with the corrugated tank and conservator arrangement having a no load voltage ratio of 0.415/11 KV. Tappings +5% to -5% in steps of 2.5% shall be provided at line end of HV winding. Changing of taps shall be carried out by means of OFF load Tap Changer. Temperature rise shall be 50/60 °C in oil / winding respectively over a maximum ambient of 40 °C.

Transformer shall have metal cover for termination area with lifting eye.

The transformer shall be manufactured as per latest IEC, conforming to following parameters:

- HV Insulation level 12 Kv.
- Power Frequency 28 Kv r.m.s
- Basic impulse level 75 Kv Peak.
- Hermetically sealed, without gas cushion.

Dial Type thermometer with contacts and control box for relays.

Oil level indicator and pressure relief valve and oil drain valve.

Paint class: for extreme weather conditions, salty, hot and humid environment.

Relevant testing standards: IEC / BS Standards.







