

INFORMATION SHEET FOR PROCUREMENT OF 1.2MW GENERATOR SET

Reference No.: FNK-I/IUL/2021/520

Issued on 24th November 2021

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





Section I: Instruction to Bidders

A. General		
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for 1.2MW generator
		set in accordance with Section III, Technical Specifications
	1.2	It is in Fenaka Corporation Limited's discretion to cancel the bid
		invitation mentioned in 1.1 at any time.
2. Eligible	2.1	Local companies registered in Maldives are eligible to participate in
Participants		the tender
	2.2	Foreign companies are eligible to participate in the tender only if the
		total bid value is above 2,500,000 Maldivian Rufiyaa.
B. Preparation	of the	Bid
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly indicated
		in the quotation
	3.2	All items shall be quoted in the bid (please refer to Section III,
		Technical Specifications for the details of required items)
	3.3	Quotation shall separately indicate the additional charges such as
		freight charges, insurance, etc.
	3.4	The bidder shall submit quotation on CIF basis to Male' port
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa
5. Alternative Bids	5.1	Bidders can submit a maximum of two (2) options
6. Validity of Bids	6.1	Quotation shall remain valid for minimum sixty (60) days from the date
		of bid opening
7. Bid Security	7.1	All bids should be accompanied with a bid security of USD 5,000 (Five
		Thousand US Dollars) or its equivalent in Maldivian Rufiyaa
	7.2	The bid security should be:
		- Original bank guarantee letter (or)
		- Bank guaranteed and stamped check (or)
		- An insurance policy from Maldives Monetary Authority (MMA)

Page 2 of 9













	7.3	Any bid not accompanied by a Bid Security shall be rejected during bid
		opening
	7.4	The bid security must be valid for a minimum of twenty (20) additional
		days beyond the validity of quotation
8. Technical	8.1	All relevant information including the brand shall be given to enable
Compliance		technical evaluation of quoted items
	8.2	The documents required for technical evaluation are:
		- Technical data sheets of engine and the alternator
		- Datasheets specifying cooling system rated at ambient temperature
		50°C
		- Certificate of Authenticity specifying manufacturer/assembler is an
		OEM or a genuine reputed international engine brand
	8.3	If the manufacturer or assembler is not the same as the bidder, a
		document indicating that manufacturer or assembler is willing to sell
		the generator set to the bidder is required
	8.4	Technical compliance letter will be required to enable technical
		evaluation
	8.5	If the goods do not comply with the requirements mentioned in Section
		III, Technical Specifications, the bid will be rejected during evaluation.
	8.6	Generator set should comply with our requirements, if not the bid will
		be rejected
9. Documents	9.1	Quotation (inclusive of the delivery period and payment terms)
Comprising the	9.2	Specifications of the offered product
Bid	9.3	Certificate of Authenticity specifying that manufacturer / assembler is
		an OEM of a genuine reputed international engine brand
	9.4	Details of the company
		- Company profile/background
		- Company registration certificate
		- GST registration certificate (for local bidders only)
		- TAX clearance report (6 months validity)
I		·

Page 3 of 9











		- Contact details (name, designation, mobile number and e-mail
		address)
	9.5	Experience letters, if available
		- Letters within past five (5) years
		- Relevant experience letters
		- Letters with project name and value
	9.6	One (1) compact disc with original bid document scanned and written
	9.7	Bids lacking the documents above are subjected to be rejected during
		the bid opening
10. Format of Bid	10.1	The Bidder shall submit two (2) sets of the bid document (1 original
		and 1 copy), enclosed separately in two envelopes, and sealed with
		company stamp
	10.2	All pages of the bid document shall be stamped and bound properly
		(excluding the bid security)
C. Bid Submissi	on	
11. Sealing and	11.1	The bid document shall be sealed properly in an envelope clearly
Marking Bid		marked 'ORIGINAL' or 'COPY', with the name of the company and
Document		the tender reference number (FNK-I/IUL/2021/520)
12. Bid Opening	12.1	The bids will be opened on 05 th December 2021, 10:30am in the
		presence of bidders
	12.2	Bids will be opened at:
		Fenaka Corporation Limited
		Hilaalee Magu, K. Male', Republic of Maldives
	12.3	Bids received electronically will not be accepted
13. Bid Rejection	13.1	Bidders that arrive after bid submission deadline shall not be able to
		participate in the bid
	13.2	Bidders that do not register for the tender are unable to participate in
		the bid opening
	13.3	Bids lacking the documents mentioned in 9. Documents Comprising the
		Bid (except 9.5 Experience letters) and that do not comply with 10.
		Format of Bid are subjected to be rejected

Page 4 of 9















D. Awarding of	Contr	act
14. Payment	14.1	An advance will not be released for this project
Terms		
15. Factory	15.1	The generator(s) shall be fully tested at the manufacturer workshop in
Acceptance		the presence of Client's appointees via video conferencing.
Testing	15.2	The testing shall be conducted at internationally accepted testing
		standards
	15.3	The generator(s) shall be checked for dimension, the supplier shall
		provide dimension of the generator(s) during the virtual factory
		acceptance testing.
	15.4	Generator(s) should be tested to run at 25%, 50%, 75%, 100%, and
		110% of rated load and power factor until the engine temperature
		stabilized for 30 minutes, and should check the protections below:
		- Lub oil low level (alarm testing)
		- Lub oil low pressure (alarm testing)
		- Earth fault (alarm testing)
		- Over current (alarm testing)
		- High temperature (alarm testing)
		- Cooling system (alarm testing)
		- High voltage pressure (alarm testing)
		- All the functioning tests and routine tests should be done
	15.3	All the protections should work properly, it should be examined for oil
		and coolant leaks, and it should be visually tested and secured
	15.4	The remote radiator should operate continuously 100% in a 50-degree
		ambient temperature
		- It should be designed with vertical air discharge remote radiator with
		motor and fan
		- It should include all the generator connection pipes, accessories, joints
		and diagrams
	Port	t Complex Building, 7th Floor, Hilaalee Magu, Male, 20207, Maldives





















- The radiator should be developed remotely from the engine providing an added flexibility cooling system, and to be installed at the desired location
- It should be designed with lower power consumption, and high efficiency aero foil designed fans are used
- It must be designed with lower noise levels
- The radiator core should be formed using high efficiency fin profile
- The thickness of connection pipes must be in a range of 2mm to 4mm
- Two (2) engineers from Fenaka Corporation Limited shall carry out necessary inspection and testing of equipment prior to shipment in supplier's warehouse to validate the items
- The bidder shall arrange airfare, transportation, stipend (as per the Client's policy), accommodation and lodging for two of Client's engineers for the testing (minimum two days for testing)













Section II: Evaluation Criteria

Proposal Cost: 70 points for the lowest price

(Lowest price / proposed price) x 70

Delivery: 20 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 20
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

(Proposed credit period / longest credit period) x 10

Note: Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.











Section III: Technical Specifications

#	DESCRIPTION	QTY
1	1.2MW Generator Set	01

S/N:	Description	Unit	Qty
1	1200 kW prime rated diesel generator set with parameters 0.8 P.F, 11kV, 3 Phase, 4 wires, 50 Hz at 1500 r.p.m. Powered by Internationally reputed brand engine coupled with internationally reputed brand Alternator. The Generator set shall be powered by a Branded engine origin (UK, USA) or assembled/manufactured by an Original Company's Licenced OEM manufactured/assembler. The engine must produce a mechanical power output (kW _m) which should meet the required electric power (kW _e) of 1200kW and must be coupled with a 1200kW Alternator with pre-installed Droop CT and a control connection box.(termination	1	No
¥	Engine to be complete with following auxilliary items: • Heavy electrical flywheel • SAE flywheel housing • Air filters, Lubricating Oil Filters, Fuel Filters and all other such filter required for operation of the engine • Low lubricating oil pressure switch • High engine temperature switch • lub oil sender • Water Temperature Sender • All necessary items to run and to protect the engine		
	Starting equipment fitted to engine, consisting of: 24 Volt charging altenator (Brushless) 24 Volt starting motor Fuel Shut-off solenoid Heavy duty lead acid batteries, supplied in a dry charged condition Governing System The engine to be fitted with a close tolerance Cummins Electronic Governing system, which should include efc, actuators, magnetic pickups, etc, including wiring Cooling Equipment		
	Cooling equipment compromising a heavy-duty tropical remote radiator, with fans driven by Electric Motors (ABB or equivalent). The radiator core should be electroplated with silver solder tin plated to prevent early failure due to corrosion. Coupon plated radiators are acceptable.		
	Radiator must be designed to adequately cool the generator at an ambient temperature of 50°C • Exhaust system 450 mm of stainless steel below type flexible exhaust, together with suitable flanges and fittings shall be supplied for each silencer. • Alternator		

Page 8 of 9













1.6	Warranty		
1.5.7	Split type rockwool insulation lagging suitable for 75 to 125mm dia. Exhaust pipes. The lagging shall be covered with High Quality Aluminium foil.	1	Lot
	washers,1spring washer 2 Nuts)	1	Lot
1.5.6	Bolts, Nuts and Washers for the Flanges. (Each set shall include 1 bolt, 2		
1.5.5	Flanges having dia (to match the engine exhaust)	8	No
1.5.4	Elbows having dia (to match the engine exhaust)	6	No
1.5.3	3m Exhaust pipe dia (to match engine exhaust)	4	No
1.5.2	Secondary silencer barrel (to match engine exhaust)	2	No
1.5.1	Primary silencer barrel (to match engine exhaust)	2	No
	above mentioned generator sets,		
1.5	Accessories The Components shall meet the British Standard and ISO standards, items are for the		-
4.0	1 No x Engine shop manual		
	1 No x Governor control unit manual		
	1 No x Generator AVR manual		
	1 No x Generator operation and maintenace manual		
	1 No x Generator parts catalogue		
	1 No x Engine parts catalogue		
	1 No x Engine operation and maintenance manual		
	1 Nos x Electrical wiring diagram		
	1 No x Manual on How to handle the generation equipment		
1.4	Literature and drawings consisting of :	1	Lot
	no 10 of this document.		
	bidder shall provide an extended warranty of one extra year than mentioned in Iteme		
	prior to dispatch in case the bidder is unable to provide factory test as required the		
	of client/apointees to check the ratings,overload,functional tests on a dummy load		
1.3	The generator should be fully tested at the manufacturer workshop in the presence	1	No
1.3	Enstant sandan		
	All necessary fittings to be supplied in conformity with fuel flow diagram.		
	connection is to be mounted. These mounts are are to be sumplied as loose item.		
	filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet		
	A fuel day tank of 12 hours capacity complete with level indicator, drain plug,		
112	1 1	1	INC
1.2	applied to the complete set. Fuel system	1	No
	After assembling the genset zinc coated self-etching primer should be		
	• Finishing		
	plate. The vibration mounts are to be supplied as loose item.		
	base plate and vibration mounts to be mounted underside of the base		
	foundation bolts. The engine and the alternator are to be mounted on a		
	and electrically welded, drilled on the underside to allow the fitting of		
	The simplex type base plate is of heavy duty rolled steel constructed, bolted		
	alternator should be 11000V. Generator arrangement and drive		-
	Condensation Coil to be fitted in the Alternator. The output voltage of		
	assuming a speed variation not exceeding 4% on the engine. Anti-		
	of +/- 1.5% from no load to full load under the steady state conditions		
	BS 5000, tropically impregnated with voltage regulation being in the order		
	insulation on both the stator and field windings. It shall be built and rated to		
	The alternator shall be brushless revolving type altenator, having class H		









