

ADDENDUM NO.1 TO THE BIDDING DOCUMENTS

Reference No: AIA-11/IL/2021/043

Project: Procurement of SS Pipe and Accessories

Addendum Date: 20th December 2021

- a) This Addendum provides clarification and answer to Contractor question received by email.
- b) This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Addendum shall govern and take precedence.
- c) Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Addendum. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.
- d) The following modifications, additions, or deletions are hereby incorporated into the contract documents

The bid documents are modified and clarified, as follows:

1. CLARIFICATIONS

<u>Reference</u>	<u>Changes/Clarification</u>																								
<u>Information Sheet</u> 2. Scope of Work	<p>The width of Flange changed. The Length of Pipe added SS Grade added as follows:</p> <p>Addu International Airport Pvt Ltd requires quotations from interested and eligible bidders for the procurement of the following goods.</p> <table border="1"> <thead> <tr> <th>Descriptopn</th> <th>Size</th> <th>Quantity</th> <th>Length</th> </tr> </thead> <tbody> <tr> <td>SS Pipe (3mm width) HP</td> <td>4"</td> <td>12 NOS</td> <td>6 meters</td> </tr> <tr> <td>SS Elbow (3mm width) HP</td> <td>4"</td> <td>12 NOS</td> <td></td> </tr> <tr> <td>SS Flange(12mm width) HP</td> <td>4"</td> <td>10 NOS</td> <td></td> </tr> <tr> <td>SS "Y" Fitting (3mm width) HP</td> <td>4"</td> <td>05 NOS</td> <td></td> </tr> <tr> <td>SS Ball Valve (3mm width) HP</td> <td>4"</td> <td>01 NOS</td> <td></td> </tr> </tbody> </table> <p>The required SS grade is SS 316.</p>	Descriptopn	Size	Quantity	Length	SS Pipe (3mm width) HP	4"	12 NOS	6 meters	SS Elbow (3mm width) HP	4"	12 NOS		SS Flange(12mm width) HP	4"	10 NOS		SS "Y" Fitting (3mm width) HP	4"	05 NOS		SS Ball Valve (3mm width) HP	4"	01 NOS	
Descriptopn	Size	Quantity	Length																						
SS Pipe (3mm width) HP	4"	12 NOS	6 meters																						
SS Elbow (3mm width) HP	4"	12 NOS																							
SS Flange(12mm width) HP	4"	10 NOS																							
SS "Y" Fitting (3mm width) HP	4"	05 NOS																							
SS Ball Valve (3mm width) HP	4"	01 NOS																							

The above changes have been incorporated in to the document.



-End of Document-

