



بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Kanbihaa Magu | 19020 | Addu City | Maldives
info@aeH.gov.mv | +960 6885555
www.aeh.gov.mv



ANNEX 1

3kVA Tower UPS Technical Specifications

Quantity Required:	04
Output power capacity	2.1kWatts / 3.0kVA
Output Connections	(8) IEC 320 C13 (Battery Backup) (3) IEC Jumpers (Battery Backup)
Nominal Input Voltage	230V
Waveform Type	Sine wave
Battery Type	Lead-acid Battery
Warranty	Minimum 2 years repair or replace (excluding battery) Minimum 2 years for battery
Other	Should include USB Cable

1.5kVA Tower UPS Technical Specifications

Quantity Required:	03
Output power capacity	1.0kWatts / 1.5kVA
Output Connections	(2) IEC Jumpers (Battery Backup) (8) IEC 320 C13 (Battery Backup)
Nominal Input Voltage	230V
Waveform Type	Sine wave
Battery Type	Lead-acid Battery
Warranty	Minimum 2 years repair or replace (excluding battery) Minimum 2 years for battery
Other	Should include USB Cable



3kVA RACK MOUNT UPS Technical Specifications

Quantity Required:	02
Output power capacity	2.1kWatts / 3.0kVA
Output Connections	(8) IEC 320 C13 (Battery Backup) (1) IEC 320 C19 (Battery Backup) (3) IEC Jumpers (Battery Backup)
Nominal Input Voltage	230V
Waveform Type	Sine wave
Rack Mountable	Yes
Rack Height	2U
Warranty	Minimum 2 years repair or replace (excluding battery) Minimum 2 years for battery
Other	Brackets, cage nuts and screw for rack mount should be included

