



بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Kanbihaa Magu | 19020 | Addu City | Maldives
info@ae.h.gov.mv | +960 6885555
www.aeh.gov.mv



ANNEX 1

3kVA Tower UPS Technical Specifications

Quantity Required:	04
Output power capacity	2.1kWatts / 3.0kVA
Output Connections	(8) IEC 320 C13 (Battery Backup) (3) IEC Jumpers (Battery Backup)
Nominal Input Voltage	230V
Waveform Type	Sine wave
Battery Type	Lead-acid Battery
Warranty	Minimum 2 years repair or replace (excluding battery) Minimum 2 years for battery
Other	Should include USB Cable

1.5kVA Tower UPS Technical Specifications

Quantity Required:	03
Output power capacity	1.0kWatts / 1.5kVA
Output Connections	(2) IEC Jumpers (Battery Backup) (8) IEC 320 C13 (Battery Backup)
Nominal Input Voltage	230V
Waveform Type	Sine wave
Battery Type	Lead-acid Battery
Warranty	Minimum 2 years repair or replace (excluding battery) Minimum 2 years for battery
Other	Should include USB Cable

