

# INFORMATION SHEET FOR PROCUREMENT OF 350KW GENERATOR SET

Reference No.: FNK-I/IUL/2022/419

Issued on 08th June 2022

Issued by:

Fenaka Corporation Limited

Male', Republic of Maldives





### **Section I: Instruction to Bidders**

A. General		
1. Scope of Bid	1.1	Fenaka Corporation Limited requests quotations for 350kW generator set in
		accordance with Section III, Technical Specifications
	1.2	It is in Fenaka Corporation Limited's discretion to cancel the bid invitation
		mentioned in 1.1 at any time.
2. Eligible	2.1	Local companies registered in Maldives are eligible to participate in the tender
Participants	2.2	Foreign companies are eligible to participate in the tender only if the total bid
		value is above 2,500,000 Maldivian Rufiyaa.
B. Preparation	of the	Bid
3. Bid Prices	3.1	The unit price of each item and the total price shall be clearly indicated in the
		quotation
	3.2	All items shall be quoted in the bid (please refer to Section III, Technical
		Specifications for the details of required items)
	3.3	Quotation shall separately indicate the additional charges such as freight
		charges and Insurance.
	3.4	The bidder shall submit quotation on CIF basis to Male' port
4. Currency	4.1	The bidder shall quote entirely in Maldivian Rufiyaa
5. Alternative Bids	5.1	Bidders can submit a maximum of two (2) options
6. Validity of Bids	6.1	Quotation shall remain valid for minimum sixty (60) days from the date of bid
		opening
7. Bid Security	7.1	All bids should be accompanied with a bid security of USD 2,000 (Two
		Thousand US Dollars) or its equivalent in Maldivian Rufiyaa
	7.2	The bid security should be:
		- Original bank guarantee letter (or)
		- Bank guaranteed and stamped check (or)
		- An insurance policy from Maldives Monetary Authority (MMA) registered
		insurance company
	7.3	Any bid not accompanied by a Bid Security shall be rejected during bid opening

Page 2 of 9
















	7.4	The bid security must be valid for a minimum of twenty (20) additional days
		beyond the validity of quotation
8. Technical	8.1	All relevant information including the brand shall be given to enable technical
Compliance		evaluation of quoted items
	8.2	The documents required for technical evaluation are:
		- Technical data sheets of engine and the alternator
		- Datasheets specifying cooling system rated at ambient temperature 50°C
		- Certificate of Authenticity specifying manufacturer/assembler is an OEM or
		a genuine reputed international engine brand
	8.3	If the manufacturer or assembler is not the same as the bidder, a document
		indicating that manufacturer or assembler is willing to sell the generator set to
		the bidder is required
	8.4	Technical compliance letter will be required to enable technical evaluation
	8.5	If the goods do not comply with the requirements mentioned in Section III,
		Technical Specifications, the bid will be rejected during evaluation.
	8.6	Generator set should comply with our requirements, if not the bid will be
		rejected
9. Documents	9.1	Quotation (inclusive of the delivery period and payment terms)
Comprising the	9.2	Specifications of the offered product
Bid	9.3	Certificate of Authenticity specifying that manufacturer / assembler is an OEM
		of a genuine reputed international engine brand
	9.4	Details of the company
		- Company profile/background
		- Company registration certificate
		- GST registration certificate (for local bidders only)
		- TAX clearance report (6 months validity)
		- Contact details (name, designation, mobile number and e-mail address)
	9.5	Experience letters, if available
		- Letters within past five (5) years
		- Relevant experience letters
		- Letters with project name and value

Page 3 of 9


















9.7 Bids lack opening	ng the documents above are subjected to be rejected during the bid	
opening		
<b>10. Format of Bid</b> 10.1 The Bidd	er shall submit two (2) sets of the bid document (1 original and 1	
copy), en	closed separately in two envelopes and sealed with company stamp	
10.2 All pages	of the bid document shall be stamped and bound properly (excluding	
the bid se	curity)	
C. Bid Submission		
11. Sealing and 11.1 The bid	locument shall be sealed properly in an envelope clearly marked	
Marking Bid 'ORIGIN	AL' or 'COPY', with the name of the company and the tender	
<b>Document</b> reference	number (FNK-I/IUL/2022/419)	
<b>12. Bid Opening</b> 12.1 The bids	1 The bids will be opened 21 <sup>st</sup> June 2022, 11:00am in the presence of bidders	
12.2 Bids will	be opened at:	
Fenaka C	orporation Limited	
Hilaalee I	Magu, K. Male', Republic of Maldives	
12.3 Bids rece	ved electronically will not be accepted	
<b>13. Bid Rejection</b> 13.1 Bidders the	at arrive after bid submission deadline shall not be able to participate	
in the bid		
13.2 Bidders the	nat do not register for the tender are unable to participate in the bid	
opening		
13.3 Bids lack	ing the documents mentioned in 9. Documents Comprising the Bid	
(except 9.	5 Experience letters) and that do not comply with 10. Format of Bid	
are subject	ted to be rejected	
D. Awarding of Contract		
<b>14. Payment</b> 14.1 An advan	ce will not be released for this project	
Terms 14.2 Proposed	payment terms should not be tied with submission of Bill of Lading.	
<b>15. Factory</b> 15.1 The gene	rator(s) shall be fully tested at the manufacturer workshop in the	
<b>Acceptance</b> presence	of Client's appointees via video conferencing.	
<b>Testing</b> 15.2 The testing	g shall be conducted at internationally accepted testing standards	
15.3 The gene	rator(s) shall be checked for dimension, the supplier shall provide	
dimension	of the generator(s) during the virtual factory acceptance testing.	

Page 4 of 9

















- 15.4 Generator(s) should be tested to run at 25%, 50%, 75%, 100%, and 110% of rated load and power factor until the engine temperature stabilized for 30 minutes, and should check the protections below:
  - Lub oil low level (alarm testing)
  - Lub oil low pressure (alarm testing)
  - Earth fault (alarm testing)
  - Over current (alarm testing)
  - High temperature (alarm testing)
  - Cooling system (alarm testing)
  - High voltage pressure (alarm testing)
  - All the functioning tests and routine tests should be done
- 15.5 All the protections should work properly, it should be examined for oil and coolant leaks, and it should be visually tested and secured
- 15.6 Recorded video clips while operating the units will not be accepted as virtual factory acceptance testing.















#### **Section II: Evaluation Criteria**

Proposal Cost: 60 points for the lowest price

(Lowest price / proposed price) x 60

**Delivery**: 30 points for the lowest delivery period

- (Lowest delivery period / proposed delivery period) x 30
- If the delivery period indicates 'ex-stock', it shall be taken same as the party offering the longest delivery period.

Credit Period: 10 points for the maximum credit period

(Proposed credit period / longest credit period) x 10

Note: Any discrepancy in technical details specified in quotation with technical specification document, the specification shall prevail.















### **Section III: Technical Specifications**

\*Please note that the below specifications are for one unit only.

S/N:	Description	Unit	Qty
	350 kW prime rated diesel generator set with parameters 0.8 P.F, 415kV, 3 Phase, 4	1	No
1	wires, 50 Hz at 1500 r.p.m. Powered by Internationally reputed brand engine coupled		
	wires, 50 Hz at 1500 r.p.m. Powered by Internationally reported brains and the send Albertator		
	with internationally reputed brand Alternator.		
	The Generator set shall be powered by a Branded engine origin or		
	assembled/manufactured by an Original Company's Licenced OEM		
	manufactured/assembler.		
	The engine must produce a mechanical power output (kW <sub>m</sub> ) which should meet the		
	required electric power ( kW <sub>e</sub> ) of 350kW and must be coupled with a 350kW		
	Alternator with pre-installed Droop CT and a control connection box.(termination		
b	box to connect control cables and power cables)		
	to a with following auxilliary items:		
	Engine to be complete with following auxilliary items:		
	Heavy electrical flywheel     GAS flowback bouries		
	<ul> <li>SAE flywheel housing</li> <li>Air filters, Lubricating Oll Filters, Fuel Filters and all other such filter required</li> </ul>		
	for operation of the engine  Low lubricating oil pressure switch		
	High engine temperature switch		
	Iub oil sender		
	Water Temperature Sender		
	All necessary items to run and to protect the engine		
	Starting equipment fitted to engine, consisting of :		
	24 Volt charging altenator (Brushless)		
	• 24 Volt starting motor		
	Fuel Shut-off solenoid		
	Heavy duty lead acid batteries, supplied in a dry charged condition		
	Governing System		
	The engine to be fitted with a close tolerance Electronic Governing system,		
	which should include efc, actuators, magnetic pickups, etc, including wiring		
	Cooling Equipment		
	Cooling equipment compromising a heavy-duty tropical radiator, together		
	with pusher type cooling fan and guards to be fitted. The radiator core		
	should be electroplated with silver solder tin plated to prevent early failure	1	
	due to corrosion. Coupon plated radiators are acceptable. Radiator has to		
	be mounted on vibration mounts with enough strength to withstand the		
	radiator and vibrations.		
	Radiator must be designed to adequately cool the generator at an ambient		
	temperature of 50°C		
	<ul> <li>Exhaust system</li> <li>450 mm of stainless steel bellow type flexible exhaust, together with</li> </ul>		
	suitable flanges and fittings shall be supplied for each silencer.		
	Alternator	1	

Page 7 of 9















washers,1spring washer 2 Nuts)  Split type rockwool insulation lagging suitable for 75 to 125mm dia. Exhaust pipes. The lagging shall be covered with High Quality Aluminium foil.  Warranty	1	Lot
		-
	1	Lot
Bolts, Nuts and Washers for the Flanges. (Each set shall include 1 bolt, 2		
	4	No
		No
		No
CONTROL OF THE PROPERTY OF THE		No
above mentioned generator sets.		No
- Control Cont		
1 No x Engine shop manual		
1 No x Governor control unit manual		
1 No x Generator AVR manual		
	1	Lot
no 1.6 of this document.		
The state of the s	1	No
Factory tecting	-	
All necessary fittings to be supplied in conformity with fuel flow diagram.		1
		INC
applied to the complete set.  Fuel system	1	No
After assembling the genset zinc coated self-etching primer should be		
• Finishing		
plate. The vibration mounts are to be supplied as loose item.		
Generator arrangement and drive		
assuming a speed variation not exceeding 4% on the engine. Anti- Condensation Coil to be fitted in the Alternator.		
of +/- 1.5% from no load to full load under the steady state conditions		
BS 5000, tropically impregnated with voltage regulation being in the order		
	of +/- 1.5% from no load to full load under the steady state conditions assuming a speed variation not exceeding 4% on the engine. Anti-Condensation Coil to be fitted in the Alternator.  • Generator arrangement and drive  The simplex type base plate is of heavy duty rolled steel constructed, bolted and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a base plate and vibration mounts to be mounted underside of the base plate. The vibration mounts are to be supplied as loose item.  • Finishing  After assembling the genset zinc coated self-etching primer should be applied to the complete set.  Fuel system  A fuel day tank of 12 hours capacity complete with level indicator, drain plug, filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet connection is to be mounted. These mounts are are to be suuplied as loose item. All necessary fittings to be supplied in conformity with fuel flow diagram.  Factory testing The generator should be fully tested at the manufacturer workshop in the presence of client/apointees to check the ratings, overload, functional tests on a durmy load prior to dispatch in case the bidder is unable to provide factory test as required the bidder shall provide an extended warranty of one extra year than mentioned in iteme no 1.6 of this document.  Literature and drawings consisting of:  1 No x Manual on How to handle the generation equipment  1 No x Engine operation and maintenance manual  1 No x Generator parts catalogue  1 No x Generator parts catalogue  1 No x Generator parts catalogue  1 No x Generator sets caused the generation equipment of the provide of the pro	insulation on both the stator and field windings. It shall be built and rated to BS 5000, tropically impregnated with voltage regulation being in the order of +/- 1.5% from no load to full load under the steady state conditions assuming a speed variation not exceeding 4% on the engine. Anti-Condensation Coil to be fitted in the Alternator.  • Generator arrangement and drive  The simplex type base plate is of heavy duty rolled steel constructed, boited and electrically welded, drilled on the underside to allow the fitting of foundation bolts. The engine and the alternator are to be mounted on a base plate and vibration mounts to be mounted underside of the base plate. The vibration mounts are to be supplied as loose item.  • Finishing  After assembling the genset zinc coated self-etching primer should be applied to the complete set.  Fuel system  A fuel day tank of 12 hours capacity complete with level indicator, drain plug, filler, fuel return with fuel outlet connections and a fuel filter fitted with outlet connection is to be mounted. These mounts are are to be suuplied as loose item.  All necessary fittings to be supplied in conformity with fuel flow diagram.  1 factory testing  The generator should be fully tested at the manufacturer workshop in the presence of client/apointees to check the ratings, overload, functional tests on a dummy load prior to dispatch in case the bidder is unable to provide factory test as required the bidder shall provide an extended warranty of one extra year than mentioned in iteme no 1.6 of this document.  Literature and drawings consisting of:  1 No x Manual on How to handle the generation equipment  1 No x Engine operation and maintenance manual  1 No x Generator AVR manual  1 No x Generator AVR manual  1 No x Generator AVR manual  1 No x Generator day manual  2 Secondary silencer barrel (to match engine exhaust)  3 michaust pipe dia (to match engine exhaust)  4 Elbows having dia (to match the engine exhaust)  5 Flanges having dia (to match the engine exhaust)

















Generator set should carry a warranty of one year from the date of commissioning

Lot

#### Documents Required for technical evaluation

- · technical data sheets of engine
- · technical data sheets of Alternator
- datasheets specifying cooling system rated at ambient temperature 50°C
- Certificate of Authenticity specifying manufacturer /Assembler is an OEM of a genuine reputed international Engine Brand

Note: Proposal that do not conform to the given technical specification shall be rejected.

Prepared and checked by:

Technical Services & Green Energy Department

Page 9 of 9









