


# 100 Football pitch Project



**Football Ground: HA. Utheemu**  
Site visit report – supporting information

Date of visit	17 <sup>th</sup> June 2022	
Site address	HA. Utheemu	
Weather Condition during site visit		
Officials providing information	Council Vice President: Mohamed Adam	
Local Contact details	Island:	HA. Utheemu
	Contact name:	Mohamed Adam
	Designation	Council Vice president
	address:	
	Tel:	7939896
	e-mail	
	Fax:	

Scope of the Project	Design and construction of full-size football Artificial turf pitch (Subbase)				
	Category of pitch requirement	FIFA Recommended			
	Level of competition and activities & requirement	National Level			
Proposed usage	Level of play	National Level			
	Intensity of paly per week / year	+/- 36 hrs. /week			
Field orientation	North / South				
Proposed filed dimensions					
		Length		Width	
	Field size	105m		68m	
	Run – off area	North	South	West	East
		3m	3m	2.5m	2.5m
	Total Green area (synthetic)	111m x 73m			
Spectator Area	No Specific Spectator area				
Fencing	Build boundary wall with goal fence,				

Ground Conditions: Proposed site is in the Northeast side of the island; some trail holes were made, and soil layers shows evidence of silt sand. Proposed site is the existing football ground, Noticed the ground level is higher than other islands we inspected, ground mostly flat and covered with grass, heavily grown on the corner areas and sides. Plot is in sports courts area footprint must be laid in accordance with council for space utilization.

Groundwater evidence	According to the representatives on site water is likely more than 4-5 feet deep,
Topography	Existing football ground, surface with mostly covered with grass and heavily grown grass patches on the corners generally a football pitch size area is flat.
Drain Outlet	Drainage is designed with enough soak pits
Existing Service & sports lighting	No existing structure, with Boundary wall and goal fence
Disposal of Spoil	All removed spoil sand disposal must be finalized with a consent from local council.

Site photos



Trial Holes.



Construction Detail: Footprint must be laid in a way to best utilize space. Existing football pitch area is previously filed for the purpose of growing grass, looks higher than the surrounding roads		
Site access	Distance from the harbor to the site may cause some problem for mobilization	
Site Compound	It's located due Northeast of the island, Existing football ground area, on the east side is the main mosque of the island.	
Best time of the year to construct	No significant time of the year	
Working restriction	Allocated plot is on the awest side of the main mosque of the island, working during the prayer time will be restricted.	
Drainage	Base design,	
Provision for new functional extension	Footprint must be laid in a way space is best utilized for further development and other sports courts	
Maintenance equipment requirement	TBC	
Sports equipment	TBC	

#### Other Consideration

- Good enough area for football ground
- Footprint and Orientation of the construction must be laid to best utilize the space for further development of the facility
- Easy access to the facility for vehicles (Ambulance)
- Potential outlet for field drainage connecting to local sewerage system
- Power supply to the football field should be a direct cable from the powerhouse avoiding interference to public households during an event.
- Gutter line to be lowered unless council provide sand (advice to assure sand availability before lowering or raising the sub base)

#### **PPROPOSED INDICATIVE LAYOUT**

Spectator area to be development by Council, footprint of the pitch according to the concept by council



Drawing of the pitch area

