

# **Design and Life Cycle Cost of a Vertical Ground Source Heat Exchange System for the Smith College Field House**

**by**

**Xinyi L. Li**

An honor thesis submitted in partial fulfillment  
of the requirements for the degree of  
Bachelor of Science with Honors  
(Picker Engineering Program)  
in Smith College  
2019

Thesis Committee:

Professor Denise A. McKahn, Advisor

Professor Aaron J. Rubin, Second Reader

## Abstract

### Design and Life Cycle Cost of a Vertical Ground Source Heat Exchange System for the Smith College Field House

by

Xinyi L. Li

Committee: Denise A. McKahn  
Aaron J. Rubin

Committed to becoming a carbon neutral campus by 2030, Smith College is transitioning towards geothermal energy for campus heating and cooling. Energy Consultants have been hired to conduct an economic and phasing analysis to prepare a district energy master plan. In conjunction with this planning effort, this thesis designed and evaluated the life cycle cost of a vertical ground source heat pump system for the Field House as a pilot demonstration project.

A building energy model of the Field House was constructed in Trace 700. A sensitivity analysis identified eight sensitive unknown design parameters, including wall construction, ventilation and infiltration rate, window, wall and floor u-factor and wall height. The model was validated with existing oil usage data. The calibrated model estimates a total annual energy consumption within 4% difference from the oil data.

With this model of building heating load, a ground-source heat pump (GSHP) was designed. The design included the calculation of five key parameters, namely the total and individual borehole flow rate, borehole thermal resistance, total borehole length, number of boreholes and the power of the water and heat pumps. Two methods of borehole length calculation were compared, and a final design was proposed that detailed three boreholes at 600 ft, with a flow rate of 2.4 gpm per well coupled with three heat pumps of 0.6 tons.

A life cycle cost analysis was conducted over a period of thirty years for four design options, including (1) the existing oil-based system, (2) a GSHP system, (3) a GSHP system with medium level building retrofit and (4) a GSHP system with deep level building retrofit. While remaining on oil requires the least cost over the next 30 years, that solution does not meet our carbon neutrality goals and offsets are not being considered as a viable path. As a result, the GSHP only option ranked the least among the three remaining options in terms of the total converted present worth at year 30, \$285,000, closely followed by GSHP + Deep, which also reduced the annual heating demand by 28.9%. Economically, it is not worthwhile to retrofit a load bearing masonry building unless a deep retrofit is conducted.

Future work is recommended to improve system efficiency and reduce total life cycle cost. Specifically, work is identified in areas of thermal modeling to provide more accurate temperature profile of the system. A PV system is also recommended to provide electricity for the geothermal system heat pumps. This framework provides a useful way to compare potential carbon tax policy frameworks.

© Xinyi L. Li

---

All Rights Reserved  
2019

For Connie,  
And all the happiness that quietly crept in with her.

# Acknowledgments

First and foremost, I would like to thank Professor Denise McKahn, my thesis and research advisor, whose unconditional support and belief in me have been instrumental in the completion of this thesis as well as my undergraduate education. Her dedication and passion for teaching and research have been a constant inspiration for me throughout my years at Smith, without which I would not have become who I am today.

I would also like to thank Professor Aaron Rubin, on his help with geothermal borehole sizing and ground thermal property estimations, and his generous feedback on the thesis draft as a second reader. I am particularly grateful to Dano Weisbord and the Center for the Environment, Ecological Design, and Sustainability (CEEDS), for their heartfelt support and genuine interest in this work. This thesis cannot be completed without the technical help from the facility staff, including Gary Hartwell for the oil consumption data, Karl Kowitz for information on electricity and oil rates, Karla Youngblood and Roger Mosier for their constant support. Additional thanks to Professor John Brady and Professor Amy Rhodes of the Geology Department, for their instrumental help with ground composition and temperature estimation.

This thesis cannot be completed without the generous financial support from Mike Howard and the partial funding for the drilling of test boreholes from Constellation, an Exelon Company.

In the end, special thanks to my friends who offered substantial technical and emotional support during the most difficult and stressful times. I would like to thank Melanie Nguyen for offering her expertise in economics; Phuong Bui for providing homey culinary comfort; and Connie Zhang for bearing with my babbling and offering advice throughout the time this thesis was written up. I especially thank these three for being amazing audience of my mock (and actual) defense.

# Acronyms

<i>A</i> ...	Annual worth
<i>ACH</i> ...	Air Changes per Hour
<i>ASHRAE</i> ...	The American Society of Heating, Refrigerating and Air-Conditioning Engineers
<i>BHE</i> ...	Borehole Heat Exchanger
<i>C</i> ...	Capital cost
<i>CAD</i> ...	Computer-aided Design
<i>COP</i> ...	Coefficient of Performance
<i>DN</i> ...	Diametre Nominal
<i>E</i> ...	Sum of all anticipated equipment repair and replacement cost
<i>F</i> ...	Future worth
<i>GCHP</i> ...	Ground-Coupled Heat Pump
<i>GSHP</i> ...	Ground Source Heat Pump
<i>HDPE</i> ...	High-density Polyethylene
<i>HVAC</i> ...	Heating, Ventilation and Air Conditioning
<i>HW</i> ...	Heavyweight
<i>LCC</i> ...	Life Cycle Cost
<i>M</i> ...	Sum of annul maintenance cost
<i>MT eCO<sub>2</sub></i> ...	Metric Tons of Carbon Dioxide Equivalent
<i>OA</i> ...	Outdoor Air
<i>P</i> ...	Present Worth
<i>PV</i> ...	Photovoltaic
<i>S</i> ...	The salvage value of the system at the end of the life cycle
<i>SCAMP</i> ...	Sustainability and Climate Action Management Plan
<i>SDR</i> ...	Standard Dimension Ratio
<i>TOE</i> ...	Tons of Oil Equivalent
<i>VAV</i> ...	Variable Air Volume

# Symbols

To differentiate theoretical and modeled values,  $x$ , from measured data or variables calculated using measurements,  $\bar{x}$ , an overbar is used. Derivatives are denoted as  $d()/d()$ .

A list of variable and parameter symbols, definitions and units is provided below, any deviations from these units will be explicitly stated in the text:

$A$ ...	contact area ( $m^2$ )
$c_p$ ...	specific heat at constant pressure ( $J/kgK$ )
$d, D$ ...	diameter (m)
$f$ ...	Moody friction factor (unitless)
$h$ ...	convective heat transfer coefficient ( $W/m^2K$ )
$i$ ...	interest, discount rate (%)
$k$ ...	thermal conductivity ( $W/mK$ )
$L$ ...	length (m)
$\dot{m}$ ...	mass flow rate ( $kg/s$ )
$n$ ...	period of time (years)
$P$ ...	sensitivity analysis output (unitless)
$P$ ...	pressure (Pa)
$q, Q$ ...	energy in the form of heat (J)
$\dot{q}, \dot{Q}$ ...	heat flow rate ( $J/s$ )
$r$ ...	radius (m)
$R$ ...	thermal resistance ( $Km/W$ )
$Re$ ...	Reynolds Number (unitless)
$S$ ...	sensitivity coefficient (unitless)
$T$ ...	temperature ( $^{\circ}C$ )
$\dot{v}$ ...	velocity of the fluid ( $m/s$ )
$\dot{V}$ ...	volumetric flow rate ( $m^3/s$ )
$\dot{W}$ ...	energy rate in the form of electricity ( $J/s$ )
$x$ ...	x, or horizontal direction (unitless)
$X$ ...	sensitivity analysis input (unitless)
$\alpha$ ...	thermal diffusivity ( $m^2/day$ )
$\rho$ ...	density ( $kg/m^3$ )
$\mu$ ...	viscosity ( $Ns/m^2$ )

A list of the subscript and superscript symbols and definitions is provided below:

<i>avg</i> ...	average
<i>b</i> ...	borehole
<i>cond</i> ...	related to conductive heat transfer
<i>conv</i> ...	related to convective heat transfer
<i>f</i> ...	circulating fluid
<i>fitting</i> ...	pipe fitting
<i>friction</i> ...	friction
<i>g</i> ...	ground
<i>gr</i> ...	grout
<i>h</i> ...	hourly
<i>i</i> ...	index
<i>in</i> ...	input
<i>m</i> ...	monthly
<i>out</i> ...	output
<i>p</i> ...	pipe
<i>pi</i> ...	pipe inner rim
<i>po</i> ...	pipe outer rim
<i>s</i> ...	contact surface
<i>total</i> ...	total
<i>u</i> ...	center-to-center distance between pipes
<i>w, water</i> ...	water
<i>y</i> ...	yearly, annual
<i>1m</i> ...	one month
<i>10y</i> ...	ten years
<i>6h</i> ...	six hours
$\infty$ ...	at infinity



# Table of Contents

<b>Dedication</b> . . . . .	ii
<b>Acknowledgments</b> . . . . .	iii
<b>Acronyms</b> . . . . .	iv
<b>Symbols</b> . . . . .	v
<b>List of Tables</b> . . . . .	ix
<b>List of Figures</b> . . . . .	x
<b>List of Appendices</b> . . . . .	xii
<b>Chapter 1 Background and Introduction</b> . . . . .	1
1.1 Global and Institutional Contexts for Geothermal Energy . . . . .	1
1.1.1 Sustainability Planning Efforts at Smith College . . . . .	3
1.2 Geothermal Energy Conversion Strategies . . . . .	4
1.2.1 Geothermal Power Plants . . . . .	5
1.2.2 Direct Uses of Geothermal Energy . . . . .	6
1.2.3 Geothermal Heat Pumps . . . . .	9
1.3 Contributions . . . . .	10
<b>Chapter 2 Building Energy Modeling of the Field House</b> . . . . .	12
2.1 Building Energy Modeling in Trace 700 . . . . .	12
2.2 Model Development and Calibration . . . . .	13
2.2.1 Acquiring Building Information . . . . .	14
2.2.2 Sensitivity Analysis . . . . .	17
2.2.3 Parameter Calibration and Assumptions . . . . .	18
2.2.4 Model Validation . . . . .	21
<b>Chapter 3 Ground Source Heat Exchange System Design for the Field House</b> . . . . .	23
3.1 System Overview . . . . .	23
3.2 System Design . . . . .	24
3.2.1 Design Variables and Process . . . . .	25
3.2.2 Total Borehole Volumetric Flow Rate . . . . .	27
3.2.3 Borehole Thermal Resistances . . . . .	28
3.2.4 Borehole Sizing . . . . .	30

3.2.5	Heat Pump Sizing . . . . .	32
3.3	Design Results . . . . .	34
<b>Chapter 4</b>	<b>Life Cycle Cost Analysis . . . . .</b>	<b>35</b>
4.1	Overview . . . . .	35
4.1.1	Life Cycle Cost Calculation . . . . .	35
4.1.2	Background on Building Retrofits . . . . .	37
4.2	Cost Benefit Analysis for Design and Retrofit Options . . . . .	38
4.2.1	Acquiring Cost Information and Assumptions . . . . .	38
4.2.2	Results and Comparisons . . . . .	41
<b>Chapter 5</b>	<b>Conclusion and Future Work . . . . .</b>	<b>45</b>
5.1	Conclusion . . . . .	45
5.2	Future Work . . . . .	46
<b>Appendices</b>	<b>. . . . .</b>	<b>47</b>
A.1	Weather Information . . . . .	48
A.2	Rooms . . . . .	48
A.2.1	Kitchen . . . . .	48
A.2.2	Lounge . . . . .	53
A.2.3	Middle . . . . .	58
A.2.4	Office Area . . . . .	62
A.2.5	Stairs . . . . .	66
A.2.6	Attic . . . . .	70
A.2.7	Basement-Large . . . . .	74
A.2.8	Basement-Left . . . . .	81
A.2.9	Basement-Right . . . . .	86
A.3	Systems . . . . .	91
A.4	Assign Rooms to Systems . . . . .	95
A.5	Plants . . . . .	96
A.6	Assign Systems to Plants . . . . .	98
B.1	Room Definition . . . . .	100
B.2	Partition Definition . . . . .	101
C.1	Morris House . . . . .	103
C.2	Lawrence House . . . . .	104
E.1	Geothermal Only . . . . .	109
E.2	Geothermal + Medium . . . . .	112
E.3	Geothermal + Deep . . . . .	115
H.1	Field House Field Investigation Notes . . . . .	124
H.2	Building Insulation Cost Estimation . . . . .	125
<b>Bibliography</b>	<b>. . . . .</b>	<b>140</b>

# List of Tables

<b>Table</b>		
2.1	Sensitivity Analysis Results* . . . . .	18
3.1	Design Parameters for a Vertical BHE. . . . .	28
4.1	Building Dimensions and Pump Power of the Field House . . . . .	38

# List of Figures

<b>Figure</b>		
1.1	Types of Renewable Energy Sources[5]. . . . .	2
1.2	The Potential of Renewable Energy Sources. Geothermal energy resources, if all converted to useful work, could meet the needs of current global energy needs by five times. The circles here indicate relative magnitude of available resources [5]. . . . .	2
1.3	Geothermal Resources of the United States [29] . . . . .	3
1.4	Utilization of Geothermal Energy based on Ground Temperature [3] . . . . .	5
1.5	Schematic of a Binary Power Plant [3] . . . . .	6
1.6	Schematic of a Flash Power Plant [3] . . . . .	7
1.7	Percentage of Total Geothermal Energy Use by Types Worldwide [14] . . . . .	7
1.8	Schematic of Ground Source Heat Pumps: (a) groundwater well, (b) standing column well, (c) vertical closed-loop borehole, (d) horizontal Slinky, and (e) surface water closed loop [3] . . . . .	9
1.9	The two common BHE Pipe Configurations: U-tube (left) and Coaxial pipe (right) [3]	10
1.10	An Schematic of a Vertical BHE System Coupled with Heat Pumps for Heating [16]	11
2.1	An Overview of Trace 700 Main Project Page. . . . .	13
2.2	The Building Exterior of the Field House. . . . .	14
2.3	A CAD Drawing of the First Floor of the Field House. . . . .	15
2.4	Boilers for Heating and Domestic Hot Water at the Basement of Field House. . . . .	16
2.5	Sensitivity Coefficient for Six Most Sensitive Unknown Building Parameters . . . . .	19
2.6	Ventilation Ducts in the Attic-1 . . . . .	20
2.7	Ventilation Ducts in the Attic-2 . . . . .	20
2.8	One of the Two Irregular Spaces in the Basement . . . . .	21
3.1	Configuration of a Vertical Ground Source Heat Pump System [13] . . . . .	24
3.2	Schematic of a Air-to-Water Heat Pump (Left) and a Water-to-Water Heat Pump (Right) [12] . . . . .	25
3.3	Schematic Diagram of a geothermal borehole heat exchanger (BHE) comprised of a single U-tube grouted in a vertical borehole. [3] . . . . .	26
3.4	Flowchart of the Calculation Procedure for Total Flow Rate, Borehole Resistance, Borehole Length and Heat Pump Sizing. . . . .	27
3.5	Ground Composition of the Field House (marked within the red square) up to around 320m. (John Brady) . . . . .	30
3.6	Ground Temperature vs Depth (0-100 m) below the Earth's Surface. [3] . . . . .	31
3.7	Ground water contour map of the New England area. [12] . . . . .	31
3.8	Schematic of a Heat Pump in Heating Mode [3] . . . . .	33
4.1	A Screenshot of an Interest Rate Table at $i = 1\%$ [18] . . . . .	36

4.2	One of the Two Windows at the Field House that were Removed . . . . .	40
4.3	One of the Two Half-Size Windows (left) at the Field House . . . . .	40
4.4	Life Cycle Cost Calculation for Four Design + Retrofit Options . . . . .	42
4.5	Total Life Cycle Present Worth Comparisons For Four Design and Retrofit Options at Year 30 . . . . .	43
4.6	Total Life Cycle Present Worth per Square Foot For Four Design and Retrofit Options	43

# List of Appendices

## Appendix

A	Trace 700 Model Inputs . . . . .	48
B	Trace Manual . . . . .	99
C	Blower Door Test Reports for Lawrence and Morris House from 2010 . . . . .	102
D	Heat Pump Sizing Spreadsheet . . . . .	105
E	Field House Energy Consumption Reports . . . . .	108
F	Geothermal System Review Spreadsheet . . . . .	118
G	Life Cycle Cost Spreadsheet . . . . .	121
H	Scanned Notes . . . . .	123
I	PV System Design Report . . . . .	126

# Chapter 1

## Background and Introduction

This thesis presents a design and life cycle cost analysis of a vertical ground source heat pump system for the Smith College Field House. In this chapter, global and institutional context of the utilization of geothermal energy are discussed and an introduction to the technology of harnessing geothermal energy is included.

### 1.1 Global and Institutional Contexts for Geothermal Energy

The issues surrounding climate change continue to be a major global concern. In 2015, the United Nations has called the world to “ensure access to affordable, reliable, sustainable and modern energy for all” after adopting the 2030 Agenda for Sustainable Development and its Sustainable Development Goals (SDGs)[17]. In countries around the world, sustainable energy conversion technologies have been fast developing, policies have been established to provide incentives for the use of renewable energy and goals have been set by institutions as well as corporations to reduce carbon emissions. While progress has been made, climate change continue to be an imminent threat. As identified by a report from the Intergovernmental Panel on Climate Change (IPCC) in 2018, a reduction of average earth temperature of 2 °C before 2030 was adjusted to a new goal of 1.5 °C, which can only be achieved given “unprecedented and urgent action”[24].

In this context, research institutions and organizations have been invested in developing carbon neutral conversion technologies and improving system efficiency for thermal and electricity generation. Efforts have also been made to make renewable energy systems more financially accessible. Figure 1.1 shows the main sources of renewable energy, including solar, wind, marine, hydro, bioenergy and geothermal energy. In terms of energy potential, if fully developed and converted, these sources possess an equivalent of 3078 times the current global energy needs, as shown by Figure 1.2.

Throughout the world, the use and application of geothermal energy has been increasing over the past years. According to reports from the World Geothermal Congress 2010 in Bali, Indonesia ([31]), by the end of 2009, a total of 48,493 MWt was generated for worldwide direct utilization of geothermal energy, an increase of almost 72% from 2005 and growing at an annual compound rate of 11.4% [14]. Geothermal energy has served as a capable replacement of fossil fuels, leading to




Figure 1.1: Types of Renewable Energy Sources[5].




Figure 1.2: The Potential of Renewable Energy Sources. Geothermal energy resources, if all converted to useful work, could meet the needs of current global energy needs by five times. The circles here indicate relative magnitude of available resources [5].

a reduction of 55 TOE (tons of oil equivalent) of fuel oil for both electricity generation and direct use, and a total of 50 TOE of carbon emission [14]. Geothermal energy installations have been increasingly adopted in the United States as well, which ranks number one in the total electricity produced and number two in direct use of geothermal energy in 2009 and 2010, respectively [7].

Some limitations and advantages exist for the utilization of geothermal energy. One of the major limitations for geothermal power generation is location. System efficiency is highly dependent on several variables, one of which is the thermal condition of the ground at the chosen location. High



subsurface temperature is needed for electricity and power generation, which limits the location of geothermal based power plants to places with naturally higher temperatures. Figure 1.3 shows the geothermal resources in the United States that are ranked based on temperature profile from 3 to 10 km below the soil surface, a depth that is needed for power generation. The level of favorability decreases as location shifts from west to east, making States like Oregon and California ideal locations. Despite the requirement on deep ground temperature profiles for power generation, the direct use of geothermal energy to meet heating and cooling needs is more accessible to all, as it only requires heat from the “shallow” surface of the ground, commonly from 200 to 500 ft [12]. In addition, geothermal energy also has advantages in terms of having the largest capacity factor (the number of hours a power plant can produce per 24-hour period), not dependent on weather conditions, and having an inherent storage capacity and a relatively low operating cost [7].




Figure 1.3: Geothermal Resources of the United States [29]

### 1.1.1 Sustainability Planning Efforts at Smith College

Smith College has been actively involved in sustainable planning efforts for the past few years. After signing the Carbon Commitment (Formerly known as the American College and University

Presidents' Climate Commitment) in 2007, Smith College published a Sustainability and Climate Action Management Plan (SCAMP) in 2010 to achieve carbon neutrality by 2030 [4]. The SCAMP, a detailed plan analyzing our current sources of carbon emissions, shows that the burning of fossil fuels for campus heating and cooling accounts for 23800 MT eCO<sub>2</sub> (metric tons of carbon dioxide equivalent), or 85% of all college carbon emissions. Carbon reduction strategies were then implemented which enabled the construction of a large laboratory and research building, Ford Hall, to come online with no added carbon footprint. In 2016, the Smith College Study Group on Climate Change evaluated carbon mitigation strategies and the feasible options for transitioning to a non-carbon based energy infrastructure in consultation with Integral Group [8, 23]. They identified the utilization of ground source heat exchange as one instrumental step toward carbon neutrality and evaluated the degree to which the existing distribution system remains centralized [8].

At the start of the Fall 2018 semester, the College selected energy consultants, MEP and Associates, to develop a District Energy Master Plan that evaluates phasing opportunities and life cycle costs as the College transition toward a geothermal heating and cooling system. A pilot project that involves drilling of a test borehole near the athletic fields has been developed to evaluate the soil and hydraulic characteristics as well as provide an understanding of the ground conditions essential for the design of the geothermal system. A grant was received by Constellation, an Exelon Corporation, to fund geologic and thermal modeling research on the pilot system.

## 1.2 Geothermal Energy Conversion Strategies

Geothermal energy is energy available in rocks and ground water beneath the soil surface. The temperature of the earth remains stable, on average 15°C for the first 100 m, in comparison to the ground surface temperature, which greatly varies throughout the year. This thermal stability makes the ground a perfect heat reservoir, capable of heat extraction and rejection. Starting at around 10 meters, or 32 feet, the temperature of the earth follows a relatively linear increase with respect to depth. This linear relationship, characterized by the geothermal gradient, is about 30°C every 1 km, in general. Heat can be extracted from or rejected to the ground via a heat exchange system, where a circulating fluid, called the geothermal working fluid, circulates through the ground and returns back to the surface. Heat is transferred between the geothermal fluid and the ground such that the fluid increases in temperature when heating is needed and decreases in temperature when cooling is needed. The contact length (often expressed as depth) for which the geothermal fluid needs to be in contact with the ground directly affects the heat extraction/rejection rate, which is controlled by the demand of heating/cooling or electricity generation.

Common ways of utilizing geothermal energy are: 1. direct use for heating and cooling and 2. electricity and power generation. Combined electricity and heat generation, a method that uses waste heat from power generation for district heating, is another common option. Figure 1.4 shows ways of utilizing geothermal energy based on ground temperature. Generally speaking, direct usage of geothermal energy is not confined to low or medium temperature, but rather fits the category as

long as geothermal energy is used directly owing to its temperature [3]. However, direct use, primarily in the form of geothermal heat pumps (68.3% of all installed geothermal capacity globally), is less demanding of the ground temperature (between 10°C to 25°C) and depth, and is widely used for residential building space heating and cooling [14]. Geothermal based power plants, on the other hand, rely on heat engines, which can employ a Rankin Cycle to convert high temperature (at least 100°C) ground heat into electricity. In the following sections, system setup for the direct-use and power generation will be discussed in detail.




Figure 1.4: Utilization of Geothermal Energy based on Ground Temperature [3]

### 1.2.1 Geothermal Power Plants

Currently, geothermal based power generation relies on the use of hydrothermal resources, which have three components required for electricity generation: fluid, heat and permeability [19]. There are three main types of geothermal power plants: binary, flash steam and dry steam. A binary power plant is the most common type, feasible for temperatures up to 175°C. In a binary power plant, the

geothermal fluid remains in liquid phase. After circulating through the supply wells, as shown in Figure 1.5, the liquid-phase fluid exchanges heat with a lower-boiling-point working fluid which then gets expanded in the turbine and condensed back to liquid phase, in a closed loop. A path for the working fluid would be  $4 \rightarrow 4' \rightarrow 1 \rightarrow 2 \rightarrow 3 \rightarrow 4$ . On the other hand, a flash steam power plant, shown in figure 1.6, uses two-phase fluid separated from single-phase geothermal fluid in the separator. The steam fraction then goes through a typical expansion in the turbine and a condensation in the condenser. This system operates in an open loop, where the condensed water returns back to the geothermal reservoir through an injection well. The water fraction from the separator, also called waste water, condenses and can be utilized for potential direct heat uses. A dry steam power plant, only exists in a few locations worldwide, is similar to a flash steam power plant but uses geothermal fluid that is in superheated vapor phase when extracted from the wells. This configuration has the highest requirement for both well depth and ground temperature.




Figure 1.5: Schematic of a Binary Power Plant [3]

## 1.2.2 Direct Uses of Geothermal Energy

When geothermal energy is used directly for thermal purposes, as opposed for conversion into another form of energy such as electricity, the process is called a direct use. There remains debate about whether geothermal heat pumps belong to the direct use category. For instance, Chiasson argues that since a heat pump is needed for temperature amplification, which indicates that the resource temperature is not high enough to be used directly, it should be its own category [3]. However, for the sole purpose of separation from power generation, geothermal heat pumps are included as applications of direct uses of geothermal energy in this work.

Other than geothermal heat pumps, the most popular way to leverage direct use geothermal resources includes swimming pools and spas, space heating and greenhouse heating, as illustrated by




Figure 1.6: Schematic of a Flash Power Plant [3]

Figure 1.7, together making up about 45% of total geothermal energy use [14].




Figure 1.7: Percentage of Total Geothermal Energy Use by Types Worldwide [14]

Geothermal heat pumps, often known as ground source heat pump (GSHP) systems, is the most popular and accessible way of directly using geothermal energy, and involves coupling of heat

pumps with low temperature thermal energy from the earth. This type of heat exchange is achieved by pumping geothermal fluid to the ground through a channel, most often pipes, and having heat to travel from or to the fluid due to temperature difference between the fluid and the ground. Heat is then pumped and distributed from the heat pump above the ground to various locations. As technology develops, nowadays, ground source is not only restricted to the earth, but also includes groundwater, surface water and other forms of reservoir.

### Ground Heat Exchange Configurations

There are five main ground heat exchange configurations for ground source heat pump systems, as shown in Figure 1.8. A **groundwater well** (Figure 1.8a) is an open loop system where underground water is pumped to a heat pump or directly to usage from the bottom of a borehole, and is discharged to a suitable receptor, such as an aquifer, to an unsaturated zone. A **standing column well system** (Figure 1.8b) is a semi-open-loop system where ground water is pumped to a heat pump from the bottom of a deep borehole, but is returned to the same borehole after use. These boreholes are usually up to 15 cm in diameter, and allow water infiltration throughout the length of the borehole.

The **horizontal Slinky** (Figure 1.8d) and **the surface water closed loop** (Figure 1.8e) are similar in borehole orientation and the mechanism of heat extraction/rejection. A circulating fluid travels in horizontally laid pipes to exchange heat with either the ground or an open channel, such as a pond, lake or other water reservoir. A slinky shape is popular for maximizing contact area for heat exchange.

For close-loop systems, a **vertical borehole heat exchange system** (Figure 1.8c), also known as a vertical borehole heat exchanger (BHE), is the most commonly used configuration. A vertical BHE features a closed-loop HDPE pipe installed in a vertical borehole ranging from 60 to 90m (200 to 300 ft), though drilling conditions may have it go over 150m (400 ft). A standard HDPE pipe has a diameter between 25 to 40mm (3/4 to 1 1/4 in). Two configurations of the pipe are common, one of which is a single U-tube, in which the medium, usually water, circulates the ground through a u-shaped tube; the other is a coaxial tube, featuring one single pipe in the center of the borehole and water flowing into the ground from the annulus/central to the central/annulus. Both configurations and flow direction are illustrated in Figure 1.9.

For larger heating or cooling loads, multiple boreholes are connected in parallel to form a geothermal BHE field. These boreholes are designed to extract or reject thermal energy to/from the ground at a temperature called  $T_g$ , using the medium fluid, with an average temperature  $T_f$  of inlet  $T_{in}$  and outlet  $T_{out}$ . The space in between the borehole and the pipe is usually filled with grout, materials with low thermal conductivity such as bentonite, to prevent heat intervention between pipes.




Figure 1.8: Schematic of Ground Source Heat Pumps: (a) groundwater well, (b) standing column well, (c) vertical closed-loop borehole, (d) horizontal Slinky, and (e) surface water closed loop [3]

### 1.2.3 Geothermal Heat Pumps

For geothermal BHE based space heating and cooling projects, after exchanging heat with the ground, the circulating fluid is amplified via heat pumps and directed to residential houses or buildings, to complete its heating or cooling cycle through another heat exchange with that environment. For instance, in heating modes, when room temperature is lower than ground temperature, the circulating fluid travels from the room/building, to the heat pumps before entering the BHE wells. With relatively low  $T_{in}$ , it extracts heat from the ground in the pipe, returns to the ground, being pumped into the building and heat the room. A graphic illustration of this example is shown in Figure 1.10.

A geothermal heating/cooling system can be centralized or decentralized, depending on current heating system configuration, as well as land availability. A centralized geothermal field features one complete field that generates and distributes heat through pipes that reach the entire campus




Figure 1.9: The two common BHE Pipe Configurations: U-tube (left) and Coaxial pipe (right) [3]

while a decentralized field comprises several fields, each responsible for heating of a local region. An example of a decentralized field at Smith College would be a field at Athletic Field heating the main campus and a field at the Quadrangle residential area for its own heating.

### 1.3 Contributions

This project details the design of a vertical ground source heat pump system with u-tube configurations and provides a design to be implemented in the summer of 2019 as a pilot project for demonstration and research purposes. This work also guides the phasing and economic analysis for the District Energy Master Plan. This modeling and analysis framework could be incorporated into retrofit analysis with carbon tax policy implications to evaluate alternative energy systems [26].

In Chapter 2, a building modeling process of the Field House is explained, including model development, sensitivity analysis, model calibration and validation and a annual heating load is calculated. Chapter 3 presents the design process of a vertical ground source heat pump system and illustrates detailed assumptions and calculations that are used to generate design parameters, such as borehole length and heat pump power. Chapter 4 presents a life cycle cost analysis of the GSHP system design and closely quantifies the cost-benefit balance of four design options. Chapter 5






Figure 1.10: An Schematic of a Vertical BHE System Coupled with Heat Pumps for Heating [16]

concludes the work and identifies future directions.

## Chapter 2

# Building Energy Modeling of the Field House

In this chapter, an energy modeling process for the Field House will be presented. Trace 700, a commercial software for building energy modeling, is used to simulate the annual energy consumption of the Field House. Sensitivity analysis of building parameters is conducted for model calibration with existing oil consumption data of the boilers and to account for uncertainties from unknown building variables.

### 2.1 Building Energy Modeling in Trace 700

Trace 700 is a Windows based energy software developed by TRANE<sup>®</sup>, for building performance modeling and existing load calculations for building envelope, air conditioning, electricity consumption. It can also be used to generate suggestions for system design parameter values, as well as economics calculation and life cycle cost.

Users input weather data when creating a project, by selecting the location of the building. Weather is then incorporated from an internal library. Users can also override library data by manually changing variables such as dry/wet bulb temperature. Three major components in the Trace 700 main project navigator, shown in Figure 2.1 are the Create Rooms, Create Systems and Create Plants tabs. In Create Rooms, users construct a virtual building by creating rooms and inputting values and setup options for various building components in each room, including basic dimensions, walls and envelopes, internal loads, airflows and indoor partitions and other structures. A overall building energy consumption profile is then calculated.

In Create Systems, users define the HVAC (Heating, ventilation, and air conditioning) air distribution system by choosing the type of heating and cooling systems that serve in the buildings. Users can choose from a list of systems including unit heaters, fan coil, radiation, single zone, VAV, water source heat pump and so on. Once a system is selected for heating and cooling, users can further specify details of these systems in terms of the dedicated outdoor air (OA) system, temperature and humidity, and fans and coils. Trace 700 will then calculate corresponding power and electricity loads on the air distribution system based on previous total energy consumption calculated in Rooms. Users also need to assign rooms to air distribution systems so that potential zones can be created to reflect the reality of the building.

In Create Plants, users choose and setup configurations for building cooling and heating equipments, including air-cooled chillers, boilers, gas-fired heat exchangers and others. Users can further setup details, such as boiler efficiency, about these utilities in the Heating/Cooling Equipment tabs or setup base utility such as domestic hot water load in the Base Utility tab. Users can also assign air distribution systems to plants to designate heating/cooling loads on these plants.











Project Navigator		
		Alternative 1
	Enter Project Information	Field House
	Select Weather Information	Chicopee, Massachusetts
	Create Templates	7 Templates
	Create Rooms	9 Rooms
	Create Systems	1 Systems
	Assign Rooms to Systems	9 Assigned Rooms
	Create Plants	2 Plants
	Assign Systems to Plants	System Assignments
	Define Economics	No utility rates defined 0(\$)
	Calculate and View Results	04/02/2019 - 05:03 PM

Figure 2.1: An Overview of Trace 700 Main Project Page.

## 2.2 Model Development and Calibration

In this section, a building model of the Field House is developed and calibrated in Trace 700. The process and result of obtaining known building parameters are discussed and unknown parameters are identified to calibrate the model. A sensitivity analysis is conducted for all unknown building parameters and configuration options in the Create Rooms section. Sensitive building parameters are identified and assumptions are made to approximate them with greatest precision possible. Additional adjustments and assumptions for unknown air-side system configurations, domestic hot water usage and modeling the geometry of the basement are also be discussed. The building model is tuned to match the total energy converted from oil usage by the boilers within a reasonable percentage difference.

### 2.2.1 Acquiring Building Information

A building model for the field house is constructed in Trace 700 based on information about building parameters acquired from a variety of sources, including field investigation, personal conversations with the facilities staff, existing documents about building structures and envelopes, CAD drawings, as well as reasonable assumptions based on similar building types (complete model input see Appendix A). Since the Field House has already been built, challenges remain for fully obtaining information on the building, especially for undocumented building dimensions, as well as wall and attic composite materials. In the following paragraphs, the initial modeling process based on known parameters is discussed. Unknown parameters are listed and a sensitivity analysis is conducted. Sensitive unknown parameters are then calibrated based on reasonable assumptions and a final building energy model is developed and compared to existing annual oil consumption of the Field House.



Figure 2.2: The Building Exterior of the Field House.

The Field House is a load bearing masonry [9], three-story (basement, first floor and attic) house located on the athletic field, as shown in Figure 2.2. It is primarily used by student athletes for equipment storage, gathering and occasional showering. Figure 2.3 shows the layout of the first floor, with a floor area of  $3116 \text{ ft}^2$ . Trace 700 defines a room as the smallest space for which a user

can calculate loads and recommends that a user create one room for every single space surrounded by walls (detailed definition see Trace 700 manual in Appendix B.1). Therefore, five rooms in total are created for the first floor. “Office Area”, “Kitchen”, and “Lounge” are existing rooms labeled on the drawing. A room called “Middle” is designated to the area to the left of the lounge, with a dimension of 37’3” × 20’7 1/2”. Similarly, a “Stairs” room is created for the closed area on the left right corner, with a dimension of 34’10 1/2” × 22’1/2”. The dimension of the attic and the basement is not available from any existing CAD drawings or any other documented sources. The total area of the attic is assumed to be equal to the total area of the first floor. Assumptions about further geometry and energy modeling regarding the basement will be discussed in Model Calibration.




Figure 2.3: A CAD Drawing of the First Floor of the Field House.

Observations suggest that the thermostat setpoint on the first floor are the same and the overall temperature change is insignificant between rooms. Therefore, no partitions have been created for rooms, which corresponds to the suggestion by Trace 700, saying that “It is not necessary to model a partition if there is not a significant thermal difference between the spaces adjacent to it.” (detailed definition see Trace 700 manual in Appendix B.2). All rooms on the first floor are grouped into one zone, for the same reason. From observation, there are no thermostats in the attic or the basement,

or any other type of conditioning system. Therefore, the attic and the basement are grouped into unconditioned zones. Information about building interiors, including the material of roof, doors, interior partitions, lighting, flooring and ceiling is acquired from the Building Attribute Spreadsheet documented from past building energy efforts in [9] and [10].

Information about the building air-side distribution system, such as the heating source, the heating distribution system and the heating end devices is acquired from [9]. Existing boiler specifics are obtained from personal field investigation at the Field House (scanned notes in Appendix H.1). Information about domestic hot water usage inside the Field House, such as sports team shower schedule is obtained from conversations with sports team members and coaches.



Figure 2.4: Boilers for Heating and Domestic Hot Water at the Basement of Field House.

The Field House is not connected to the college central steam system, but entirely relies on oil fired steam boilers in the basement shown in Figure 2.4 [9]. There is also no cooling system for the Field House. However, due to restrictions of Trace 700, energy consumption reports can only be generated if heating and cooling plants are available. Therefore, boilers are added to heating plants to simulate the boilers in the basement, and default equipments are added to the cooling plant, with pump capacity reduced to zero. Additionally, fans are also configured as to cycle with heating load only. This precaution has been verified by Current Annual Energy Consumption Re-

port (Appendix E.1) which suggests that energy consumed by cooling load is only 0.3% of total energy consumption.

All known information is input to the building model following the categorization of Rooms, Systems and Plants. Unknown parameters remain as default to allow sensitivity analysis to be done before they are categorized as sensitive or non-sensitive and tuned.

### 2.2.2 Sensitivity Analysis

Sensitivity Analysis is used to identify unknown building details that significantly influence heating load. For the Rooms setting, there are parameters that are not specified in documents but can be reasonably assumed based on existing information or buildings of similar settings, such as the u-factor of walls and floors, the infiltration rate, and the unknown dimensions of the attic and the basement. There are other parameters that are harder to assume, such as the acoustic ceiling resistance, heat gain of the lighting system, and the time lag of the room due to thermal mass. In addition, there are several other characteristics of the Field House that are not available in Trace 700, such as the unique geometry of the basement, or a geothermal ground-sourced heating system.

Therefore, a sensitivity analysis is conducted to determine and calibrate unknown variables that have a significant impact on model behavior. A sensitivity analysis measures the variance of an output given a variance of the input of a parameter. An initial input,  $X_i$ , which generates an output  $\bar{P}_i$ , is changed by a certain fraction,  $\delta X$ , to an input with error,  $\tilde{X}_i$ , which generates an output with error,  $\tilde{P}_i$ . The sensitivity coefficient,  $S_i$ , is defined as the ratio of the fraction of change in input to the fraction of change in output, illustrated by Equation 2.1 [2]. Therefore, a high sensitivity coefficient indicates a sensitive parameter, where a percentage change of its output is much greater than that of its input.

$$S_i = \frac{\frac{\delta P}{\bar{P}_i}}{\frac{\delta X}{X_i}} = \frac{X_i}{\tilde{X}_i - X_i} \frac{\tilde{P}_i - \bar{P}_i}{\bar{P}_i} \quad (2.1)$$

A sensitivity error analysis is conducted to all variables in the Create Rooms section. Initially, this analysis is done to all variables from room to room. An example procedure would be to change the wall u-factor in Kitchen by 5%, keeping the wall u-factor in other rooms constant, and calculate a corresponding sensitivity coefficient, before repeating this process for every variable and for every room. After this is done to every room, variables with  $S_i > 0.005$  (which is the third quartile of the total sensitivity coefficients) are selected to proceed to an overall sensitivity analysis.

An overall sensitivity analysis entails the same process done with an uniform variable change in all rooms at the same time. An example procedure would be to change the wall u-factor by 5% in every room simultaneously before calculating the sensitivity coefficient. A justification of this process is that since seven out of the eight variables selected from before are the same for all rooms, when one variable changes, this influence carries out to all rooms. It is therefore more representative of reality to quantify and compare the influence of each variable on all rooms. The only variable that varies from room to room, namely the glass/window percentage, is excluded from this round of

analysis since there would be no real-life implication of doing so.

Table 2.1 shows the result from the overall sensitivity analysis of seven of the eight selected variables. All textual options, such as types of window and floor has been converted to numerical values in the form of u-factor, and therefore refer to the level of insulation they provides. For Window Type,  $0.6 \text{ Btu/hr}\cdot\text{ft}^2\cdot\text{°F}$  is the u-factor of a double clear 1/8" and  $0.28 \text{ Btu/hr}\cdot\text{ft}^2\cdot\text{°F}$  is the u-factor of a triple 1/4". For Floor Type,  $0.2666 \cdot\text{ft}^2\cdot\text{°F}$  is the u-factor of a 2" wood floor and  $0.09599 \cdot\text{ft}^2\cdot\text{°F}$  is that of a 2" wood floor with 2" insulation. For the purpose of consistency with the nomenclature of Trace 700, original labels, such as Window Type and Floor Type are kept in the table and the graph, but refer to u-factor and levels of insulation rather than the type, as explained before.

Table 2.1: Sensitivity Analysis Results\*

Building Parameter	$X_i$	$\tilde{X}_i$	$\bar{P}_i$ (kBTU)	$\tilde{P}_i$ (kBTU)	$S_i$
Window Type (Btu/hr·ft <sup>2</sup> ·°F)	0.6	0.28	227210	177404	0.4110
Wall Height (ft)	8	10	227210	245629	0.3243
Wall Construct (Btu/hr·ft <sup>2</sup> ·°F)	0.12207	0.04511	227210	209388	0.1244
Floor Type (Btu/hr·ft <sup>2</sup> ·°F)	0.2666	0.09599	226957	137751	0.6142
Ventilation (cfm/person)	20	21	266461	268415	0.1467
Infiltration (ACH)	0.7	0.3	226957	210917	0.1237

\* Glass/Window Percentage not included.

Figure 2.5 compares the sensitivity coefficients from six of the seven most sensitive building parameters, with Glass/Window Percentage data omitted due to its uncomparable nature. Based on the graph, window type, wall height and floor type are the top three most sensitive parameters, and all seven of them, including Glass/Window Percentage, will be carefully calibrated in the next section.

### 2.2.3 Parameter Calibration and Assumptions

For Glass/Window Percentage, a site evaluation of the dimensions of the windows was made to compare the ratio of glass to wall area. Different rooms have slightly different percentages because they have a different window surface area. For instance, as shown in neon blue color in Figure 2.3, the lounge generally has at least 4 units of windows per wall, while the stairs area only has one unit of window on one side and three on the other. The average of window percentage is set to 30% with fluctuations based on the specific number of windows per wall.

Window Type, or the u-factor of windows, is determined by observations of windows on site, which indicates a double pane model. Thickness is assumed to be 1/8", as opposed to 1/4", which is the other option in Trace, based on a best estimation by eye of the windows.

Similarly, based on personal conversations and existing facility building attributes sheets [9], wall height is set to 8 ft, wall composite is set to 4" HW Concrete with 2" of insulation and floor






Figure 2.5: Sensitivity Coefficient for Six Most Sensitive Unknown Building Parameters

type is set to 2” wood floor, without any insulation.

The ventilation system in the Field House is a somewhat complicated matter. There is a set of exhaust heat recovery ventilation ducts in the attic, as shown in Figure 2.6 and 2.7, but the specifics of which is not documented in any existing facility sources available. The condition of these ducts are unknown and there are no testing reports indicating its performance. Due to lack of information, no exhaust heat recovery system is setup in the model and the ventilation rate is estimated based on a most basic ventilation system, which includes a ventilation method of “equal to the sum of outdoor air”. In Etta’s thesis, ventilation rate for load bearing masonry is assumed to be  $0.08 \text{ cfm}/\text{ft}^2$  [9]. This estimation is also supported by the ventilation rate of a warehouse, which is setup in Trace with a similar ventilation schedule, one that is relatively constant throughout the day and non-dependent on its occupants, and has a ventilation rate around  $0.05 \text{ cfm}/\text{ft}^2$ . Therefore, the ventilation rate of all rooms, except the basement, is set to be  $0.08 \text{ cfm}/\text{ft}^2$ , while the basement is set to be zero, based on field observation.

Infiltration rate is determined based on existing blower door tests for Morris and Lawrence House in 2010. Two blower door tests were done for each building, one before and one after a retrofit. An estimated annual infiltration rate before any sealing is 0.63 ACH for Morris and 0.53 ACH for Lawrence. These two buildings are identical to each other in design and construction. Both number are slightly smaller than the estimated infiltration rate for design for these houses, which



Figure 2.6: Ventilation Ducts in the Attic-1



Figure 2.7: Ventilation Ducts in the Attic-2

has an average of 0.65 ACH (full blower door reports see Appendix C). Based on field observations and personal conversations, a conservative estimation of 0.7 ACH is used for all rooms.

During the field investigation, it is also observed that the boilers also provide heat for domestic hot water usage, a portion of energy that is not yet determined. Domestic hot water is mostly used by water taps in the kitchen, and showers in the bathroom. Personal conversations with sports team managers suggest that these showers are rarely used by student athletes, only once to twice every month and occasionally when teams from other regions come visit and play. Originally, based on an estimated usage (100 gallon/hr) that is more frequent than what the manager suggests, only an increase of 42 kBTU (out of 280,000 kBTU) in annual energy usage is noted. Therefore, domestic hot water usage is assumed to be negligible in this model.

The geometry of the basement is another challenge for the model, in that there is no existing geometry setup in Trace that is capable of fully describing its space layout. In addition to a regular space estimated to be about 21 ft  $\times$  15 ft, there are two hollow spaces that are about 6.5 ft above the ground, extending from the west and east side of the interior wall into the ground. Figure 2.8 shows one of these spaces.

Several modeling approaches are used, and the best method is selected based on how close the energy consumption value is compared to the oil data. In the selected method, the basement is divided into three sub-rooms: a large room with the dimensions of 21 ft  $\times$  15 ft, and two identical small rooms with the dimensions of 10 ft  $\times$  10 ft. Partitions are created for the large room for all five directions (north, south, west, east and top ceiling). The ceiling is set to be adjacent to the Middle room on the first floor while the west and east partitions further divide into four: two that are adjacent to the ground, and two that are adjacent to the small rooms. The ceiling shared by the basement and the Middle room is assumed to have a smaller than average u-factor. Floors and



Figure 2.8: One of the Two Irregular Spaces in the Basement

partitions for the small rooms are also created, where the top ceilings are set to be adjacent to the Kitchen room and the Lounge room, according to the orientation. A drawback of this method is the mistreating of the open entrance of the two small spaces as an additional partition. To amend for this problem, a maximum u-factor of the partitions is chosen to simulate heat convection through the openings.

After model calibration, a final annual energy consumption of the Field House is calculated by Trace 700 to be 286,498 kBTU/yr.

#### **2.2.4 Model Validation**

The building model is validated by the total energy generated from the boilers in the basement. Existing data shows the consumption of number 2 fuel oil for the academic year 2014-2015 and 2015-2016 to be 2031 gallons and 1928 gallons, respectively (obtained from personal conversation with Gary Hartwell). An average heating value of 139400 BTU/gal for a number 2 fuel oil is used [32]. An average annual energy usage of the Field House is then calculated to be 275,942,300 BTU/yr, or 275,942 kBTU/yr. The Trace 700 building model, which generates an annual heating

load of 286,498 kBTU/yr, is within 4% of difference from the oil data, and is therefore validated.  
(Full report in Appendix E.1).

# Chapter 3

## Ground Source Heat Exchange System Design for the Field House

This chapter documents the system design process of a vertical ground source heat exchange system for the Smith College Field House. Given the heating load estimated in Chapter 2, here the ground-source heat pump (GSHP) system design variables are identified, in order to calculate the required bore length, number of boreholes, required fluid volumetric flow rate, and heat pump size.

### 3.1 System Overview

This section introduces the system configuration and main components of a ground source heat exchange system. Generally speaking, a complete heating and cooling system using geothermal energy consists of three major components: vertical ground-coupled heat exchangers, or simply called the ground loops, heat pumps, and the distribution system. A basic system configuration illustrating these three components is shown in Figure 3.1.

As discussed in Chapter 1, a GSHP system consists of one or multiple borehole heat exchanger(s) (BHE) that are connected in parallel or series. Ground-coupled heat pump (GCHP) is a subcategory of GSHPs, and refers to closed-loop ground-source heat pumps. The most popular is the vertical GCHP, or more commonly called the vertical BHE. The design of these heat exchangers depends on a variety of system variables, such as site conditions, including ground thermal properties, heating/cooling loads, geothermal fluid properties, borehole dimensions and configurations, such as borehole length, number of boreholes needed and average temperature of the geothermal fluid, and the size of heat pumps, including their power input and electricity consumption. Additionally, though not included in this design, borehole plumbing diagrams and system wiring schematics are also part of a final design package.

For geothermal based heating and cooling system for a residential building where borehole wells are located near the building, heat pump unit(s), connecting to the output of the vertical BHEs, amplify and pump the heat to an optional heat storage unit or directly to the building.

The most popular option is the water-to-air heat pump, where heat is exchanged between the geothermal fluid from the ground loops and the liquid refrigerant in the water coils in the pumps,




Figure 3.1: Configuration of a Vertical Ground Source Heat Pump System [13]

and is ultimately distributed from an air-based fan to the distribution system inside the building, usually a forced-air system. Similarly, a water-to-water heat pump uses water on both the ground loop coil and the building loop coil, and is often used for hydronic heating and cooling, dedicated domestic water heating, and outdoor air preconditioning [12]. The schematic for both heat pumps is illustrated in Figure 3.2. A third type of heat pump is a direct-expansion GCHP, which uses a buried copper piping network as one of the heat pump coils, through which refrigerant is circulated and heat is exchanged. Heat is then distributed inside a building in a variety of ways. Currently, Smith uses steam pipes to carry heat from the central heating plant, which is then distributed inside buildings through baseboards. Other distribution systems such as radiant heating systems are also commonly used.

This design focuses on the vertical BHEs and the heat pump sizing, and only discusses potential sizing of the distribution system based on existing information. A hydronic loop is currently located below the first floor subfloor, between the joists, in the Field House. This layout is a sub-optimal radiant system that would be removed and require installation of a new distribution system.

### 3.2 System Design

The design of a vertical ground source heat pump system have several inter-related variables that have an influence on the overall system thermal performance. However, it is also economically unjustifiable or technically impossible to obtain information on every variable. In some situations, exact value of some variables, such as the thermal conductivity of the ground at 400 ft, is often unavailable until a costly drilling and thermal response test is conducted. In other situations, as-




Figure 3.2: Schematic of a Air-to-Water Heat Pump (Left) and a Water-to-Water Heat Pump (Right) [12]

assumptions about other variables must be made based on reliable evidence and common practice, in order to efficiently proceed with necessary calculations. Therefore, the following sections strive to present a comprehensive, yet efficient design process that has taken both the economic and technical constraints into consideration.

### 3.2.1 Design Variables and Process

The performance of any geothermal-based heat exchanger relies on the heat exchange process between the ground and a circulating fluid. Therefore, understanding the thermal performance of a BHE and variables that significantly contribute to its performance, is crucial for designing a system that meets the heating load adequately and efficiently.

A typical vertical BHE with a single U-tube, as shown in Figure 3.3, comprises of a cylindrical borehole that has a U-shaped tube inside, with grout filled between the pipes and the borehole wall.

There are two types of heat transfer involved in the thermal performance of a BHE: heat conduction and heat convection. Heat conduction occurs when a thermal gradient is present, across or within solid material, where as convection occurs, in this application, between the surface of a solid and the surrounding fluid. Convection occurs from the working fluid in the pipe to the surface of the pipe wall while conduction occurs through the pipe and grout. Both conduction and convection occur from the grout to the rock and/or ground water.

For this design, conduction is assumed in the horizontal  $x$  direction, as described by the following equation.

$$\dot{Q}_{cond} = k \frac{dT}{dx} \quad (3.1)$$




Figure 3.3: Schematic Diagram of a geothermal borehole heat exchanger (BHE) comprised of a single U-tube grouted in a vertical borehole. [3]

Heat convection occurs between the circulating fluid and the pipe walls, and is summarized by Equation 3.2, where  $T_s$  is the temperature at the contact surface of the fluid and the solid, and  $T_\infty$  is the temperature infinitely far away from the contact surface (at the middle of the pipe).

$$\dot{Q}_{conv} = h\Delta(T_s - T_\infty) \quad (3.2)$$

Based on these heat transfer mechanisms, parametric studies have been done to identify variables that most significantly influence BHE thermal performance. Eskilson [6] and Hellström [11] identified five most important design parameters for the thermal performance of a borehole heat exchanger as follow:

1. the ground thermal conductivity,
2. the borehole thermal resistance,
3. the undisturbed ground temperature,
4. the heat extraction/rejection rate, and
5. the mass flow of the circulating fluid.

Since many design variables have an inter-dependent relationship, such as mass flow of the fluid and the borehole thermal resistance, some variables need to be assigned pre-determined values so that others can be calculated. Figure 3.4 represents the relationship between variables and sequence



of calculations.




Figure 3.4: Flowchart of the Calculation Procedure for Total Flow Rate, Borehole Resistance, Borehole Length and Heat Pump Sizing.

Table 3.1 summarizes the values used for pre-determined design variables, which are categorized into ground heating loads, ground properties, fluid properties and borehole dimensions. The following sections will discuss specific assumptions in obtaining these values and explain the process to calculate borehole flow rate, borehole thermal resistance, total borehole length, number of boreholes and the power of the heat pumps.

### 3.2.2 Total Borehole Volumetric Flow Rate

As Equation 3.3 stated, the total mass flow rate,  $\dot{m}$ , is dependent on the total energy leaving the fluid  $\dot{Q}_{out}$ , the specific heat capacity of water  $c_p$ , and the change of temperature of the fluid  $T_{out} - T_{in}$ . For this design, 80% of the hourly peak load  $\dot{q}_h$  (values in Table 3.1) is used for  $\dot{Q}_{out}$ . This assumption is made in correspondence with MEP Associates. Mass flow can then be converted to volumetric flow using Equation 3.4.

$$\dot{Q}_{out} = c_p \dot{m} (T_{out} - T_{in}) \quad (3.3)$$

$$\dot{m} = \dot{V}_{total} \cdot \rho \quad (3.4)$$

To determine values for inlet and outlet temperature,  $T_{in}$  and  $T_{out}$ , some assumptions are made. For this design, it is assumed that the fluid only engages in heat transfer for the downward trip, which is a distance of roughly the length of a BHE, 600 ft, and remains at the temperature it reaches

Table 3.1: Design Parameters for a Vertical BHE.

Design Parameters	Values
Ground Heating Loads (80%)	
Annual Load $q_y$ (W)	11661
Monthly Peak Load $q_m$ (W)	17283
Hourly Peak Load $q_h$ (W)	19200
Ground Properties	
Average Soil Thermal Conductivity $k_g$ ( $W \cdot m^{-1}K^{-1}$ )	4
Thermal Diffusivity $\alpha$ ( $m^2 \cdot day^{-1}$ )	0.086
Undisturbed Ground Average Temperature $T_g$ ( $^{\circ}C$ )	15
Fluid Properties	
Specific Heat Capacity of Water $C_p$ ( $J \cdot K^{-1}kg^{-1}$ )	4180
Density of Water $\rho$ ( $kg \cdot m^{-3}$ )	1000
Viscosity of Water $\mu$ ( $N \cdot s \cdot m^{-2}$ )	0.001307
Convective Heat Transfer Coefficient for Water $h$ ( $W \cdot m^{-2}K^{-1}$ )	1000
Temperature at BHE Inlet $T_{in}$ ( $^{\circ}C$ )	4
Temperature at BHE Outlet $T_{out}$ ( $^{\circ}C$ )	14
Average Temperature of Circulating Fluid $T_{avg}$ ( $^{\circ}C$ )	9
Borehole Dimensions	
Borehole Radius $r_b$ (m)	0.0762
Pipe Inner Radius $r_{pi}$ (m)	0.013
Pipe Outer Radius $r_{po}$ (m)	0.016
Pipe Thermal Conductivity $k_p$ ( $W \cdot m^{-1}K^{-1}$ )	0.46
Grout Thermal Conductivity $k_{gr}$ ( $W \cdot m^{-1}K^{-1}$ )	1.6
Center-to-Center Distance Between Pipes $L_u$ (m)	0.051

at the bottom of the pipe for the rest of the upward trip. Another important assumption is that the average fluid temperature,  $T_{avg}$ , is the arithmetic mean of the inlet ( $T_{in}$ ) and outlet ( $T_{out}$ ) fluid temperature, and is calculated as  $\frac{T_{in}+T_{out}}{2}$ . Again, this is an oversimplification. Numerical and analytic methods, not included in this design, have been studied in the past for more accurate temperature profile modeling that provides methods for average temperature calculations. Temperature of the working fluid at the inlet of the BHE,  $T_{in}$ , is determined based on case studies of GCHP designs by Philippe [28] in a similar heating setting. The system was designed for a temperature difference between inlet and outlet of 10  $^{\circ}C$ . Outlet temperature,  $T_{out}$ , and arithmetic average fluid temperature,  $T_{avg}$ , are calculated accordingly, as shown in Table 3.1.

### 3.2.3 Borehole Thermal Resistances

The borehole thermal resistance,  $R_b$ , is analogous to that for a circuit and is significant in optimizing the thermal performance of a BHE, in that the smaller the total borehole resistance, the shorter the total borehole length needs to be. The way a single borehole is configured can be seen as equivalent to a circuit, where the ground, the grout and the pipe form a series circuit and the total resistance can

be calculated by adding all the resistances together as if in a series circuit. Hellström [11] developed a model for calculating borehole resistance, which states that the total borehole resistance,  $R_b$ , for a single borehole is equal to the sum of the resistance of the grout,  $R_{gr}$ , and the total resistance of the pipe,  $R_{p,total}$  [28].

$$R_b = R_{gr} + R_{p,total} \quad (3.5)$$

where the total resistance of the pipe as half the sum of the convection thermal resistance and the conductive thermal resistance of the pipe.

$$R_{p,total} = \frac{R_{conv} + R_p}{2} \quad (3.6)$$

Equations for calculating the convective resistance,  $R_{conv}$ , thermal resistance of the pipe,  $R_p$  and the grout,  $R_{gr}$  are:

$$R_{conv} = \frac{1}{2\pi r_{pi} h} \quad (3.7)$$

$$R_p = \frac{\ln\left(\frac{r_{po}}{r_{pi}}\right)}{2\pi k_p} \quad (3.8)$$

$$R_{gr} = \frac{1}{4\pi k_{gr}} \left[ \ln\left(\frac{r_b}{r_{po}}\right) + \ln\left(\frac{r_b}{L_u}\right) + \frac{k_{gr} - k_g}{k_{gr} + k_g} \ln\left(\frac{(r_b)^4}{(r_b)^4 - \left(\frac{L_u}{2}\right)^4}\right) \right] \quad (3.9)$$

Some assumptions need to be made regarding the estimation for the thermal conductivity of the ground, the grout and the pipe, as well as for borehole dimensions.

Without a thermal response test, the exact thermal conductivity of the ground cannot be determined. Therefore, an average soil thermal conductivity is determined based on existing information about ground composition at the Field House provided by Professor John Brady from the Geoscience Department at Smith. Figure 3.5 shows that red sandstone has dominated more than half of the existing 40 m of the ground, as schist takes over after that. Average thermal conductivity of sandstone and schist is given by [12] as 3.5 and 4.5  $W \cdot m^{-1}K^{-1}$ , respectively. Therefore, an average of 4  $W \cdot m^{-1}K^{-1}$  is used for this design.

Undisturbed ground temperature,  $T_g$ , is another variable that cannot be fully determined without a thermal response test. Chiasson [3] provides an average ground temperature vs depth graph, as shown in Figure 3.6, which indicates that average temperature for winter experiences rapid increases starting from 5 °C to 15 °C at around 10 ft, but increases at a steady rate of 3 °C per 100 m after that. According to this figure, at 600 ft, which is the borehole length for this thesis work, temperature is expected to reach 21 °C. In addition, [12] also suggests using ground water temperature as a reference. Figure 3.7 shows an average ground temperature in the west Massachusetts area of around 50 °F, or 10 °C. An average between 10 °C and 21 °C, 15 °C, is used for this project, which is slightly lower than the average shown in 3.6 because Massachusetts is in the north and




Figure 3.5: Ground Composition of the Field House (marked within the red square) up to around 320m. (John Brady)

potentially has lower surface temperature.

Borehole dimensions are determined based on a variety of sources. Personal conversations with Professor Aaron Rubin provided information on borehole diameter (6 in) and pipe nominal diameter (1 1/4 in). A DN32, SDR 11 HDPE pipe is selected based on known criteria, and inner pipe radius is calculated given minimum pipe thickness of a SDR 11 HDPE pipe, provided by P.E.S, Industrial and Productive Company [27]. The thermal conductivity of a HDPE pipe is determined by taking an average of three thermal conductivities of HDPE pipes, provided by INEOS Olefins & Polymers USA [33]. Similarly, a variety of thermal conductivity of bentonite grout are provided by the [12] and an average of  $1.6 \text{ W} \cdot \text{m}^{-1} \text{K}^{-1}$  is used.

For the thermal diffusivity of the ground and center-to-center distance between pipes, default values are used based on case studies provided in [28].

ASHRAE has developed a borehole thermal resistance calculator that is used in this project to estimate these thermal resistances [12].

### 3.2.4 Borehole Sizing

Borehole sizing refers to the calculation of the total borehole length,  $L$ , required to meet a certain heating load. Method One states that  $L$  is a function of volumetric flow rate,  $\dot{V}_{total}$ , building heating




Figure 3.6: Ground Temperature vs Depth (0-100 m) below the Earth's Surface. [3]




Figure 3.7: Ground water contour map of the New England area. [12]

loads,  $q_h$  ( $q_m$  and  $q_{yr}$  are optional depending on the method), borehole thermal resistance,  $R_b$  (other borehole thermal resistances over a different time period are optional), average temperature of the fluid,  $T_{avg}$ , undisturbed temperature of the ground,  $T_g$ , and an optional temperature penalty,  $T_p$ , as

characterized in

$$L = \frac{q_h R_b}{T_{avg} - T_g} \quad (3.10)$$

Philippe[28] adjusts Equation 3.10 and introduces a slightly more extensive Method Two for borehole length calculation that incorporates annual,  $q_{yr}$ , and monthly loads,  $q_m$ , as well as effective thermal resistances for various durations of time periods, in

$$L = \frac{q_h R_b + q_y R_{10y} + q_m R_{1m} + q_h R_{6h}}{T_{avg} - (T_g + T_p)} \quad (3.11)$$

where  $T_p$  is the temperature penalty, are effective ground thermal resistances for 10 years, 1 month and 6 hours of heat load. Temperature penalty,  $T_p$  is used to account for the effect of thermal interferences, and recommended for the calculation of more than 4 boreholes. Equations for  $R_{10y}$ ,  $R_{1m}$ ,  $R_{6h}$  and  $T_p$  can be found in [28], which also provides access to a spreadsheet tool developed by ASHRAE that is used in this project to calculate borehole length L from Equation 3.11. Results calculated using Method One and Two are compared in Section 3.3, where a final borehole length L is selected.

For heating loads, as discussed before, 80% of the hourly peak load,  $q_h$ , is used for Equation 3.10. Original heating loads values are obtained from reports generated by Trace 700 (Appendix E.1) in different units. Annual load,  $q_{yr}$ , is converted from kBTU to W, over a duration of the total heating season, which is assumed to be 8 months, instead of 12 months. Monthly peak load,  $q_m$ , is manually chosen to be February, based on monthly oil consumption displayed in the Monthly Energy Consumption Report in Appendix E.1. This value is then converted from therms to W over a duration of a month. Hourly peak load is also manually selected to be the fifth hour on weekdays in February, based on Hourly Energy Consumption Report in Appendix E.1. This value is converted from BTU/h to W, over a duration of an hour. Converted  $q_{yr}$  and  $q_m$  are then used for Equation 3.11. All heating values that are used to size the borehole (namely 80% of their original value) are summarized in Table 3.1. Assumptions for  $T_{avg}$  is discussed in Section 3.2.2 where as assumptions for  $T_g$  is discussed in Section 3.2.3.

The number of boreholes is calculated by dividing the total borehole length L by the length per borehole, which is 600 ft. Volumetric flow rate per borehole can then be calculated by equally dividing the total  $\dot{V}_{total}$  with the number of boreholes needed.

### 3.2.5 Heat Pump Sizing

Figure 3.8 shows a basic heat pump unit in heating mode. The Coefficient of Performance (COP) describes the relationship between the electricity input,  $\dot{W}_{in}$ , and the energy output,  $\dot{q}_{out}$  which is 80% of the hourly heating load, and indicates the level of efficiency at which a heat pump operates. The larger the COP, the less amount of electricity is needed to pump or amplify a fixed amount of heat. For all heat pumps in this project, COP is assumed to be 3, which is likely to be an underestimation, since MEP Associates suggest a possible COP of GSHP to be around 6. Equation 3.12 is

used to calculate the power of each heat pump for the three BHEs needed. It is also assumed that each BHE is coupled with one heat pump.

$$COP = \frac{\dot{q}_h}{\dot{W}_{in}} \quad (3.12)$$




Figure 3.8: Schematic of a Heat Pump in Heating Mode [3]

For a closed-loop system, the power needed for the water pumps to circulate the fluid in the boreholes is equal to the pressure loss due to irreversible friction losses in the pipes and ducts. This is because for a closed-loop, the velocity and elevation of the inlet and outlet are the same. Therefore, the total power of a water pump is described in Equation 3.13, where the total loss due to friction can be further expanded into pressure loss due to friction with the pipes, and from the fittings [3]. Since  $\Delta P_{fitting}$  is really small, it is neglected in this design process. It is also assumed that each borehole has its own water pump.

$$\dot{W} = \dot{V} \Delta P_{friction} = \dot{V} (\Delta P_{pipe} + \Delta P_{fitting}) = \dot{V} \Delta P_{pipe} \quad (3.13)$$

where  $\dot{V}$  is the volumetric flow rate of the fluid.  $\Delta P_{pipe}$  can then be calculated using Equation 3.14.

$$\Delta P_{pipe} = \frac{f L \rho \dot{v}^2}{2D} \quad (3.14)$$

In this equation,  $f$  is the dimensionless Moody friction factor (one way of calculating which is shown in Equation 3.15),  $\dot{v}$  is the fluid velocity (m/s),  $L$  is the length of the pipe, and  $D$  is the pipe inside diameter.

$$f = (0.79 \cdot \ln(Re) - 0.64)^{-2} \quad (3.15)$$

The expression for  $Re$ , the Reynolds number, is shown in Equation 3.16.

$$Re = \frac{\rho v D_{fluid}}{\mu} \quad (3.16)$$

where  $v$  is the velocity of the fluid,  $D_{fluid}$  is the diameter of the fluid, and  $\mu$  is the viscosity of the fluid.

### 3.3 Design Results

The total mass flow,  $m_{total}$ , is calculated to be 0.46 kg/s, which is equal to 7.3 gpm of total volumetric flow rate,  $V_{total}$ .

Borehole thermal resistances are calculated using the ASHRAE tool spreadsheet [28] as follow:  $R_{conv} = 0.012$  mK/W,  $R_p = 0.069$  mK/W,  $R_{gr} = 0.097$  mK/W and  $R_b = 0.138$  mK/W.

Method One gives a total borehole length  $L$  of 442 m, or 1449 ft. This results in a total of three borehole wells. Based on this result, initially, temperature penalty was not used for Equation 3.11. Using Method Two, ASHRAE calculator [28] generates a total borehole length of 1114 m, or 3655 ft, which results in 6 borehole wells. This result is a bit of a surprise, since the number of wells has doubled from results calculated with method One. In addition, since the number of wells is larger than four, temperature penalty should be taken into consideration. Therefore, additional parameters required for calculating the temperature penalty are added, namely distance between boreholes as 6.1m, and the borefield aspect ratio as 4 (meaning wells are lined up in  $1 \times 4$  configuration). After taking into account the temperature penalty, the number of wells is reduced to 4, with 603 ft per well for a total of 735 m or 2413 ft.

Overall, Method Two (including the temperature penalty) produced a much larger total borehole length than Method One. This is mostly because Method Two has incorporated multiple heating loads across a variety of time frames, which greatly increases the numerator in Equation 3.10.

For this design project, calculated results from Method One is used, which generates a volumetric flow rate of 2.4 gpm per well (full spreadsheet Appendix D). Although, it is important to acknowledge that for systems that are intended to last for years, and especially for geothermal systems that have a significant imbalance between heating and cooling load, understanding and taking into account the thermal performance over a long period, in addition to short-term performance, is crucial in properly sizing the BHEs.

Assuming each BHE has its own heat pump gives a total of three heat pumps of 2133 W/well, or 0.61 ton/well (full calculation see Appendix D). Also assuming that each BHE has its own water pump generates a total of three water pumps of 1.1 W/well to ensure the circulation of water within the BHEs (full calculation see Appendix D). Energetic needs for the distribution system within the house are not discussed in this design process.



# Chapter 4

## Life Cycle Cost Analysis

System designs are often justified and implemented by evaluating the economic impact. In this chapter, a life cycle cost calculation is conducted for the vertical GSHP design from Chapter 3 to provide an economic scope of work. Life cycle costs for additional retrofit options are also conducted and compared with that for the current system design to shed some light on the decision making process for a most cost-beneficial option for future design projects. The key driver for this analysis is determining the life cycle cost based on the degree of the building retrofit in order to guide capital planning.

### 4.1 Overview

In this section, a basic procedure of a life cycle cost calculation is presented, and its significance explained. Common practice of a building retrofit is also described to provide some background information about the process, such as the components it usually entails, and specifically, about the impact of retrofits on capital cost.

#### 4.1.1 Life Cycle Cost Calculation

Life cycle cost (LCC) analysis provides a framework of assessing the total cost of a project during a set period of time. Generally, any cost, including capital cost and costs generated in the future, is included in the calculation to provide as thorough an analysis as possible. A LCC calculation is useful in many ways. First, it provides an economic perspective in evaluating the effectiveness and the benefits of a project. For any design project to be implemented in real life, the cost of it is an important factor, which lead to its second benefit. A LCC is especially useful in design selection of several options that are similar in the technical aspects but differs in their benefits and costs.

Overall, a basic LCC calculation is captured in Equation 4.1,

$$LCC = C + M + E + R - S \quad (4.1)$$

where C is the capital cost, or the initial cost of a system, M is the sum of annual maintenance cost, E is the sum of annual energy cost, R is the sum of all anticipated equipment repair and replacement

cost,  $S$  is the salvage value of the system at the end of the LCC period [15]. For this system, LCC is comprised of three main categories - capital cost, annual cost and salvage, which then correspond to three types of value: present worth ( $P$ ), annual cost or revenues ( $A$ ) and future worth ( $F$ ).

Present worth is what the cost is, in today's dollar value. All capital costs that one pays once at the beginning of a project, including installation, drilling, construction and so on, are present worth. Annual costs include the cost for annual maintenance and energy consumption, and other forms of cost that occur every year. Salvage refers to a recuperated value, if it were salvaged at the end of the LCC period. For instance, if the salvage rate is 20% of the capital cost at present worth, then that would be the amount one would receive in the last year,  $n$ . Not every project has materials that are worth salvaging as salvaging itself also means an extra output of labor. At end of life, there is no significant difference between salvage value of these systems. Therefore salvage value is neglected. It is important that all future costs are converted to their present worth. Equation 4.2 and 4.3 are the two most common calculations that converts between present worth, future worth and annual cost. Equation 4.4 is used to estimate annual cost that are predicted to escalate at a rate that is different from the inflation rate [15].

$$P = \frac{F}{(1+i)^n} \quad (4.2)$$

$$P = A \cdot \frac{1 - (1+i)^{-n}}{i} \quad (4.3)$$

$$P = A \cdot \left( \frac{1+E}{I-E} \cdot \left( 1 - \left( \frac{1+E}{I-E} \right)^N \right) \right) \quad (4.4)$$

where  $P$  is present worth,  $F$  is future worth,  $A$  is annual worth,  $n$  is the period of time over which a certain cost happens and  $i$  is the interest, or discount rate.

There are also pre-calculated tables that provide conversion factors at certain discount rates that allow the process of converting all costs to one type of value to be more efficient. Figure 4.1 is an example of this type of tables provided by the FE Reference Handbook 9-5 [18]. The letter on the right indicates the original type of a value while the letter on the left indicates the target.

**Factor Table -  $i = 1.00\%$**

$n$	$P/F$	$P/A$	$P/G$	$F/P$	$F/A$	$A/P$	$A/F$	$A/G$
1	0.9901	0.9901	0.0000	1.0100	1.0000	1.0100	1.0000	0.0000
2	0.9803	1.9704	0.9803	1.0201	2.0100	0.5075	0.4975	0.4975
3	0.9706	2.9410	2.9215	1.0303	3.0301	0.3400	0.3300	0.9934
4	0.9610	3.9020	5.8044	1.0406	4.0604	0.2563	0.2463	1.4876
<b>5</b>	<b>0.9515</b>	<b>4.8534</b>	<b>9.6103</b>	<b>1.0510</b>	<b>5.1010</b>	<b>0.2060</b>	<b>0.1960</b>	<b>1.9801</b>
6	0.9420	5.7955	14.3205	1.0615	6.1520	0.1725	0.1625	2.4710
7	0.9327	6.7282	19.9168	1.0721	7.2135	0.1486	0.1386	2.9602
8	0.9235	7.6517	26.3812	1.0829	8.2857	0.1307	0.1207	3.4478
9	0.9143	8.5650	33.6959	1.0937	9.3685	0.1167	0.1067	3.9337
<b>10</b>	<b>0.9053</b>	<b>9.4713</b>	<b>41.8435</b>	<b>1.1046</b>	<b>10.4622</b>	<b>0.1056</b>	<b>0.0956</b>	<b>4.4179</b>

Figure 4.1: A Screenshot of an Interest Rate Table at  $i = 1\%$  [18]

### 4.1.2 Background on Building Retrofits

In the United States, buildings consume more than 40% of the total energy produced, out of which 32% is for space heating and cooling [25]. While it is very difficult to eliminate heat loss from buildings, a building retrofit can improve the condition of the building and significantly reduce heating and cooling energy consumption. As building envelope material degrades overtime, the exterior surfaces of the building, called the building envelope, degrades, resulting in greater heat loss. In battling with heat leakage, residents have to increase the total amount of energy required to heat the building. Retrofitting existing buildings, therefore, provides an opportunity to improve building performance. At Smith College, with well over 100 buildings on campus, approximately 2 buildings a year undergo a significant retrofit. Retrofits, then provide the college an opportunity to reduce campus heating load, but at a significant cost. As a result, buildings are retrofit not just to reduce heat load, but also to address deferred maintenance and improve accessibility. Often, retrofitting an existing building is more cost-beneficial than building a new building, since retrofits often improve building heating and cooling efficiency and reduce energy demands.

With a model of heat load for a design alternative as shown in Chapter 2, the LCC of scenarios can be calculated to evaluate retrofit options. By inputting typical methods of retrofit to an existing building model, and comparing results in terms of both energy reduction and efficiency, total LCC calculations can be compared.

There are several degrees of retrofits that target different heat transport mechanisms. One of the most common and least labor intensive is sealing. Sealing a building targets convective heat transfer and minimizes unwanted air movement across the building envelopes through gaps in materials. In fact, sealing can often reduce up to 30% of total heating and cooling cost [20]. A blower door test is often conducted before sealing is done, to quantify the amount of air leakage a building has. Weather stripping and caulking holes can be conducted simultaneously with blower door tests to determine whether sealing has achieved its target infiltration rate [9].

A significantly more invasive retrofit is to add wall insulation. The ability to conduct heat in building envelope materials is measured by the so-called “R-value”. R-value is used to quantify the thermal resistance of building insulation and indicates the resistance to conductive heat transfer [21]. The larger an R-value is for a material, the more resistive it is to heat conduction. Building envelope insulation has a major effect in reducing building energy consumption, but is also very costly, as the next section will illustrate. Additional changes to the attic insulation, namely increasing the R-value of the attic, is also practiced to specifically reduce the unwanted heat gain through the roofs in the summer. For building with wall cavities, like wood-framed buildings, insulation can be added by accessing wall cavities from the exterior. The degree to which wall and attic insulation can be added is very dependent on the building construction and occupied space finishes.

Window replacement is another way of reducing conductive and convective heat transfer through the building envelope. Typical window configurations include single, double and triple pane glass windows, representing an increasing resistance to heat conduction. Pressurized gas or vacuum is often used as a filling between the panes, to further increase thermal conductivity. Convective

heat transport is reduced by setting the window within the structure with improved sealing.

## 4.2 Cost Benefit Analysis for Design and Retrofit Options

In this section, four design + retrofit options are created and their LCC calculated. Four different options are evaluated, namely the LCC over a period of 30 years for:

1. the current oil-based heating system
2. a geothermal GSHP system with no building retrofit
3. a geothermal GSHP system with medium level retrofit, which includes window replacement and attic insulation to R42
4. a geothermal GSHP system with deep level retrofit, which includes window replacement, attic insulation to R42, an overall sealing of the building and wall insulation to R21

The specific details and assumptions about cost components and LCC related parameters, such as discount rate, is included in the next section.

### 4.2.1 Acquiring Cost Information and Assumptions

Overall cost components are divided and discussed based on the category they fall into. Capital costs include the overall cost for the geothermal GSHP installation, window replacement, attic insulation and sealing, envelope insulation and sealing. Annual cost includes annual oil consumption and electricity consumption for the pumps in the GSHP system. Additional assumptions about annual maintenance costs and salvage value is discussed. Discount rate,  $i$ , for capital cost, oil and electricity are calculated or obtained from reliable sources, which are also included in this section.

Table 4.1: Building Dimensions and Pump Power of the Field House

Parameters	Value
Building Length (ft)	92.125
Building Width (ft)	36.83
Floor-To-Floor Height (ft)	8
Tilted Roof Length (ft)	52
Gross Area ( $ft^2$ )	6781
Roof Area ( $ft^2$ )	1872
Total Wall Cavity ( $ft^2$ )	4126.56
Number of Windows	34
Oil Consumption (gal)	1979.5
Total Pump Annual Energy Consumption, Geothermal only (kWh)	36870
Total Pump Annual Energy Consumption, Geothermal + Medium (kWh)	30778
Total Pump Annual Energy Consumption, Geothermal + Deep (kWh)	27846

## Capital Cost

The overall installation cost for a geothermal GSHP system, including the cost of drilling, piping, labor, as well as the cost for heat pumps, is estimated via two methods. Review has been done to examine the overall geothermal GSHP installation capital cost in existing projects for a similar institutional context. Technical and economic parameters in geothermal systems in 17 college, universities and other institutions have been evaluated, and an average cost for the overall capital installation cost is \$50,000 per well (complete spreadsheet in Appendix F). Estimates have also been made by MEP Associates to be about \$46,000 per well (at a depth of 600 ft per well). Both numbers agree fairly well and a capital cost of \$ 46,000 per well is selected, since there is a consistency in borehole depth per well between this design and MEP's.

Total installed window replacement cost of \$1500 per window is obtained through personal conversation with Professor Denise McKahn and Facilities Management staff based on previous contracts for windows of this size (notes see Appendix H.2). According to the CAD drawing, there are currently 36 windows at the Field House. A field investigation indicates that there are two windows that have been removed, shown in Figure 4.2. There is one extra window on the attic that is not documented in the CAD drawing, and two that half-size in comparison to the others, shown in Figure 4.3, and is adjusted to half of a regular window in terms of cost. Therefore, the adjusted number of windows is 34. In Trace 700, window replacement is done by adjusting the u-factor of each window. Pre-retrofit, the u-factor of a double-pane clear 1/8" window is set to  $0.6 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$ . Post-retrofit, the window u-factor is  $0.3 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$ , based on local building code regulations on building retrofit thermal performances [30].

Insulation cost is estimated, based on information obtained via personal conversation with Professor Denise McKahn shown in Appendix H.2, at an installed cost of \$15,000 for insulating a  $1400 \text{ ft}^2$  building with spray foam to achieve R21 at 3.0 inches thick. A cost per square foot is calculated, see Appendix H.2, by dividing \$15,000 over the total area of wall cavity and roof, and is equal to  $\$4.55/\text{ft}^2$ . Total building wall cavity is calculated using existing building dimensions shown in Table 4.1. The cost for wall sealing, which is one of the actions for a deep retrofit, is calculated by multiplying \$4.55 with the total wall cavity surface area. In Trace 700, wall insulation is done by adjusting the u-factor of wall material. R21 is added in series to the original R-value of  $0.122 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$  for a 4" HW Concrete with 2" insulation and converted to a u-factor of  $0.034 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$ . It is important to note that this cost does not account for building false walls within the interior of the load bearing masonry building, which currently has no wall cavity.

For attic insulation, the rate of  $\$4.55/\text{ft}^2$  is doubled and applied to the total roof area of the attic, to achieve R42. Adjusted attic roof u-factor is calculated by adding R42 in series with the original roof u-factor,  $0.157 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$ , as  $0.02 \text{ Btu/hr} \cdot \text{ft}^2 \cdot ^\circ F$ . In addition, when adding insulation, spray foam is also applied as part of the process, which reduces the infiltration rate in the attic, from 0.7 ACH to 0.3 ACH, an average post-sealing rate based on blower door tests for Morris and Lawrence House (Appendix C).

Additional cost for overall building sealing (excluding the attic) is estimated based on personal



Figure 4.2: One of the Two Windows at the Field House that were Removed



Figure 4.3: One of the Two Half-Size Windows (left) at the Field House

conversation with Professor Denise McKahn (notes in Appendix H.2). The overall schedule is assumed to be two days, with 8 hours of work per day, done by three people at a rate of \$30/hr. This results in a total cost of \$1440 for overall building sealing. In Trace 700, an overall building sealing is reflected by adjusting infiltration rate of all rooms, except for the basement, from 0.7 ACH to 0.3 ACH, for similar reasonings as the attic sealing.

For discount rate, it is assumed that this project is federally funded and all capital cost follows federal discount rates, which is about 2.5% based on reports by the Federal Reserve Bank of New York [22].

## **Annual Cost**

The schedule and components for annual maintenance for both the oil-based or the geothermal-based heating system are assumed to be the same, regardless of the degree of retrofit. Therefore, there is no calculation of annual maintenance cost in LCC calculations, since all four options have the same rate.

For the oil-based heating system, the costs for #2 oil is \$2.75/gallon, based on personal conversation with Karl Kowitz. The total oil consumption is 2031 gallons for academic year 2014 to 2015 and 1928 gallons for academic year 2015 to 2016 (obtained from personal conversation with Gary Hartwell). An average of 1979.5 gallons is used and assumed as the annual oil consumption for thirty years. An escalation rate is manually calculated using data provided by the EIA database. The rate for #2 oil on April 16th, 2009 is \$1.422/gallon, while the rate on April 16th, 2019 is \$2.082 [1]. Equation 4.4 is used to manually calculate the escalation rate, which is 4% for #2 oil.

The consumption of electricity for the heat pumps and water pumps is calculated for options 2, 3 and 4 in the same way as described in Section 3.2.5 by assuming these pumps are in operation full day for the entire heating season of 8 months, which is likely to be an overestimation. After buildings have been retrofitted, an efficiency increase and a drop in heating demand may lead to less number of borehole BHEs. The cost of electricity is \$0.155/kWh and will escalate to \$0.187/kWh in year 20 (obtained from personal conversation with Karl Kowitz). An approach similar to oil discount rate calculation is used and a discount rate is calculated manually using Equation 4.2, as 1%.

## **4.2.2 Results and Comparisons**

Figure 4.4 illustrates the total present worth for all four design and retrofit options. A medium retrofit reduces 17.2% of total annual heating demand (Appendix E.2), while a deep retrofit reduces 28.9% (Appendix E.3). The total present worth of three geothermal design options are ranked from high to low as Geothermal + Medium > Geothermal + Deep > Geothermal only, which indicates that a medium degree retrofit is both costly, on average \$6/ft<sup>2</sup> more than a geothermal-only option, and inadequate in effective energy reduction, more than 10% less energy reduction than a deep retrofit option (Full LCC calculation table in Appendix G).

	Current	Geothermal	Geothermal + Medium	Geothermal + Deep
<b>Capital Cost</b>				
<b>Installation</b>		\$138,000.00	\$138,000.00	\$92,000.00
<b>Retrofit</b>			\$68,035.20	\$88,251.05
window replacement			\$51,000.00	\$51,000.00
attic insulation/sealing			\$17,035.20	\$17,035.20
envelope insulation				\$18,775.85
envelope sealing				\$1,440.00
<b>Total Capital Cost</b>	\$0.00	\$138,000.00	\$206,035.20	\$180,251.05
<b>Annual Cost</b>				
Oil Purchase	\$5,443.63			
Electricity Purchase		\$5,714.84	\$4,770.55	\$4,316.12
<b>Total Annual Cost</b>	\$5,443.63	\$5,714.84	\$4,770.55	\$4,316.12
<b>Present Worth</b>				
Capital Cost -> Present Worth	\$0.00	\$138,000.00	\$206,035.20	\$180,251.05
Annual Cost -> Present Worth	\$94,131.16	\$147,486.79	\$123,116.97	\$111,389.04
Discount Rate for Annual	4.00%	1.00%	1.00%	1.00%
Present Worth Factor for Annual	17.29	25.81	25.81	25.81
<b>Total Present Worth</b>	\$94,131.16	\$285,486.79	\$329,152.17	\$291,640.09
<b>S.F. Cost</b>	\$13.88	\$42.10	\$48.54	\$43.01

Figure 4.4: Life Cycle Cost Calculation for Four Design + Retrofit Options

Figures 4.5 and 4.6 show the overall comparison of present worth and present worth per square foot of the four options. Cost per square foot is very close for a system with only the geothermal system and that with a deep level retrofit. This is achieved because the amount of heating reduction a deep retrofit is able to accomplish is enough to reduce the number of wells from three to two, which reduces the overall electricity consumption of the pumps. Specifically, while the capital cost is higher for a deep retrofit option, due to a total cost of \$88,251 on the deep retrofit, annual electricity consumption of the pumps drastically reduces compared to the options with three heat pumps as specific heat pump power is shown in Table 4.1.

Overall, there are several points worth noticing. First, the total cost of any geothermal system is significantly larger than the original oil-based system. This is due to a shift from oil to electricity as well as a capital investment for the GSHP system, whereas the initial installation of the existing boilers system is not included in the LCC calculations and still has significant life remaining.

For future geothermal system designs, borehole configurations with higher efficiency and control methods such as system dynamic control and thermal modeling should be considered in order to maximize system thermal performance to reduce unnecessary annual and capital cost. In order to optimize the cost-benefit relationship between building retrofit and building system design/upgrade, thorough simulation of building retrofit consequences should be made and quantified in terms of energy reduction as well as life cycle cost reduction. This ties into the third point, which is that based on results from the LCC and cost-benefit studies of the four options, a medium level building retrofit is not recommended as an action towards effective energy reduction nor cost reduction, as the total






Figure 4.5: Total Life Cycle Present Worth Comparisons For Four Design and Retrofit Options at Year 30




Figure 4.6: Total Life Cycle Present Worth per Square Foot For Four Design and Retrofit Options

cost for a medium option ranks the highest among the four options over a period of thirty years. Perhaps, an “all or nothing” strategy should be adopted. Load bearing masonry buildings should not be retrofit at all, unless a deep level retrofit is performed. The reasoning for a geothermal only system is its economic viability, while a deep level retrofit is beneficial from both the environmental and economic perspectives.

# Chapter 5

## Conclusion and Future Work

This chapter concludes the thesis work on building energy simulation, ground source heat pump system design and life cycle cost analysis for the Field House. Directions for future work are also identified.

### 5.1 Conclusion

The goal of this thesis was to (1) design a vertical ground source heat pump system for the Smith College Field House and (2) conduct life cycle costs analysis over a period of thirty years and compare calculated cost-benefits of four different design coupled retrofit options.

A building energy model of the Field House was constructed in Trace 700 following a procedure of 1) information acquisition, 2) sensitivity analysis of unknown parameters, and 3) model calibration. The model was validated against oil consumption data. A sensitivity analysis identified eight sensitive unknown design parameters including wall construct, ventilation and infiltration rate, window, wall and floor u-factor and wall height. Assumptions about these parameters are made, with additional adjustments made for the geometry of the basement and the domestic hot water usage. The model was tuned to existing oil usage data for academic year 2014-2015 and 2015-2016. A calibrated model estimates a total energy consumption of 286,498 kBTU/yr, which is within 4% difference from the oil data.

The design and calculation process of a GSHP was discussed and two of the five most important design variables were selected as the borehole thermal resistance and the mass flow of the circulating fluid. The overall design included the calculation and assumptions for five key parameters, namely the total and individual borehole flow rate, borehole thermal resistance, total borehole length, number of boreholes and the power of the water and heat pumps. Two methods of borehole length calculation, one that incorporates only one set of heating demand and the other accounts for three heating demands over a different period of time, were compared. The effect of thermal interference was briefly addressed quantitatively by the temperature penalty. A final design specifies the system setup of three boreholes at 600 ft, with a flow rate of 2.4 gpm per well coupled with three heat pumps of 0.6 tons.

A life cycle cost analysis was conducted over a period of thirty years for four design options, including (1) the current oil-based system, (2) a GSHP system with no building retrofit (3) a GSHP system with medium level building retrofit and (4) a GSHP system with deep level building retrofit. The GSHP only option required the least total converted present worth, \$285,486, among the three geothermal based design options, closely followed by GSHP + Deep of \$291,640, which also reduced the annual heating demand by 28.9%. Recommendations regarding the level of retrofit were given for future design projects. Specifically, an “all or nothing” strategy was proposed that suggested either not to retrofit or retrofit at a deep level. Additional observations were also made about the significant increase in cost from an oil-based system to a geothermal based system, which could be alleviated by designing systems of higher energy efficiency.

## **5.2 Future Work**

Three potential directions for future work are identified. First, a thermal modeling of the borehole temperature profile is recommended, to provide a quantitative study of the thermal behavior of a BHE. More specifically, a control-oriented model can be used to monitor and respond to system changes quickly, which has the potential to improve the system efficiency. Temperature sensing along the depth of the borehole wells to obtain more accurate thermal profiles of the ground is also an area for future work. It is expected that a borehole will be drilled and instrumented during the summer of 2019. These results have influenced the decision not to retrofit the building prior to installation of the GSHP system.

In addition, other renewable energy sources can be incorporated in the design. For instance, the electricity needed for the three 0.6 ton heat pumps can be generated by a PV system. Prior design of a PV system for electricity generation has been made for the Field House, the documentation of which is attached in Appendix I for future reference.


Finally, as analyzed in Chapter 4, a deep level retrofit has the potential in reducing both system cost and energy demand. Future work is recommended to study the benefits of a deep retrofit at a more detailed level. For instance, studies can be done to identify the most optimal framework in devising a retrofit plan and selecting building attributes to retrofit. Life cycle cost analysis can also be conducted to compare more retrofit options, such as area-specific retrofits focusing on only the mechanical or the ventilation system, or a complete rebuild of a facility.

# **Appendices**

# Appendix A

## Trace 700 Model Inputs

### A.1 Weather Information



### A.2 Rooms

#### A.2.1 Kitchen

Alternative 1

Room description: Kitchen

Templates...

Room: Default | Length: 12 ft | Width: 12 ft

Internal: Default | Roof: 0 ft | 0 ft

Airflow: Medium | Equals floor

Tstat: Default

Constr: Medium

Wall..

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 1	12	8	0	30	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input type="checkbox"/>
	0	8	0	0	0	0	<input type="checkbox"/>

Internal loads...

People: 4 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0.08 | cfm/sq ft

Heating vent: 0.08 | cfm/sq ft

Cooling VAV min: 0 | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Kitchen

Templates...

Room: Default | Length: 12 ft | Width: 12 ft

Internal: Default | Height: 10 ft

Airflow: Medium | Plenum: 1 ft

Tstat: Default | Above ground: 0 ft

Constr: Medium | Duplicate... | Floor multiplier: 1

Rooms per zone: 1

Room mass/avg time lag: Time delay based on actual ma

Slab construction type: 12" LW Concrete

Room type: Conditioned

Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>-°F/Btu

Carpeted:

Design...

Cooling dry bulb: 75 °F

Heating dry bulb: 70 °F

Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F

Heating driftpoint: 64 °F

Cooling schedule: None

Heating schedule: None

Sensor Locations...

Thermostat: Zone

CO2 sensor: None

Humidity...

Moisture capacitance: Medium

Humidistat location: Room

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1 Apply

Room description Kitchen Close

Templates... Roof...

Room	<span style="border: 1px solid black; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid black; padding: 2px;"></span>	Construct	<span style="border: 1px solid black; padding: 2px;"></span>	New Roof
Internal	<span style="border: 1px solid black; padding: 2px; color: red;">Default</span>		<input type="radio"/> Equals floor	U-factor	<span style="border: 1px solid black; padding: 2px;">0</span>		Copy
Airflow	<span style="border: 1px solid black; padding: 2px;">Medium</span>		<input type="radio"/> Length	Length	<span style="border: 1px solid black; padding: 2px;">0</span>	Pitch	Delete
Tstat	<span style="border: 1px solid black; padding: 2px; color: red;">Default</span>		Width	<span style="border: 1px solid black; padding: 2px;">0</span>	<span style="border: 1px solid black; padding: 2px;">0</span>	deg	
Constr	<span style="border: 1px solid black; padding: 2px;">Medium</span>		Skylight...	<input type="checkbox"/> Roof area	<span style="border: 1px solid black; padding: 2px;">0</span>	% Type	<span style="border: 1px solid black; padding: 2px;"></span>
				<input type="checkbox"/> Length	<span style="border: 1px solid black; padding: 2px;">0</span>	U-factor	<span style="border: 1px solid black; padding: 2px;">0</span>
				Width	<span style="border: 1px solid black; padding: 2px;">0</span>	Sh. Coef	<span style="border: 1px solid black; padding: 2px;">0</span>
				Quantity	<span style="border: 1px solid black; padding: 2px;">0</span>	Ld to RA	<span style="border: 1px solid black; padding: 2px;">0</span> %

Shading...  
Internal Internal

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors

Alternative 1 Apply

Room description Kitchen Close

Templates... Wall...

Room	<span style="border: 1px solid black; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid black; padding: 2px;">Wall - 1</span>	Construct	<span style="border: 1px solid black; padding: 2px;">4" HW Concrete, 2" Ins</span>	New Wall
Internal	<span style="border: 1px solid black; padding: 2px; color: red;">Default</span>		Length	<span style="border: 1px solid black; padding: 2px;">12</span> ft	U-factor	<span style="border: 1px solid black; padding: 2px;">0.1220</span> Btu/h-ft <sup>2</sup> -°F	Copy Wall
Airflow	<span style="border: 1px solid black; padding: 2px;">Medium</span>		Height	<span style="border: 1px solid black; padding: 2px;">8</span> ft	Tilt	<span style="border: 1px solid black; padding: 2px;">0</span> deg	Delete Wall
Tstat	<span style="border: 1px solid black; padding: 2px; color: red;">Default</span>		Grnd reflect multiplier	<span style="border: 1px solid black; padding: 2px;">1</span>	Direction	<span style="border: 1px solid black; padding: 2px;">0</span> deg	
Constr	<span style="border: 1px solid black; padding: 2px;">Medium</span>		Pct wall area to underfloor plenum	<span style="border: 1px solid black; padding: 2px;"></span> %			

Openings... Opening - 1

		Tag	<span style="border: 1px solid black; padding: 2px;">Opening - 1</span>	<input checked="" type="radio"/> Window <input type="radio"/> Door		New Opening	
		<input checked="" type="checkbox"/> Wall area	<span style="border: 1px solid black; padding: 2px;">30</span> %	Type	<span style="border: 1px solid black; padding: 2px;">Double Clear 1/8"</span>	Copy Opening	
		<input type="checkbox"/> Length	<span style="border: 1px solid black; padding: 2px;">0</span> ft	Height	<span style="border: 1px solid black; padding: 2px;">0</span> ft	Delete Opening	
		U-factor	<span style="border: 1px solid black; padding: 2px;">0.6</span> Btu/h-ft <sup>2</sup> -°F	Sh. Coef	<span style="border: 1px solid black; padding: 2px;">0.88</span>	Ld to RA	<span style="border: 1px solid black; padding: 2px;">0</span> %

Shading...  
Internal None  
External Overhang - None

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors



Alternative 1 Apply

Room description  Close

Templates...

Room  People... Activity  Density

Internal  Schedule

Airflow  Sensible  Btu/h Latent  Btu/h

Tstat  Workstations...

Constr  Density

Lights... Type

ASHRAE Space/Area Type

Heat gain   Schedule

Miscellaneous loads...

Tag	Type	Energy	Schedule	Energy meter	Data Center Equipment	Buttons
Misc Load 1	<input type="text" value="None"/>	<input type="text" value="0"/> <input type="text" value="W/sq ft"/>	<input type="text" value="Base Util - Lodging"/>	<input type="text" value="None"/>	<input type="text" value="No"/>	<input type="button" value="New Load"/> <input type="button" value="Copy"/> <input type="button" value="Delete"/>

Single Sheet | Rooms | Roofs | Walls | **Int Loads** | Airflows | Partn/Floors

Alternative 1 Apply

Room description  Adjacent air transfer from room  Close

Templates...

Room  Main supply... Cooling  Heating

Internal  Auxiliary supply... Cooling  Heating

Airflow  Std 62.1-2004-2010... Clg Ez  % Htg Ez  % Er  % DCV Min OA Intake

Tstat  Ventilation... Method  Type  Cooling  cfm/sq ft Heating  cfm/sq ft Schedule

Constr  Infiltration... Type  Cooling  air changes/hr Heating  air changes/hr Schedule

Room exhaust... Rate  air changes/hr Schedule

VAV control... Clg VAV min  % Clg Airflow Htg VAV max  % Clg Airflow Schedule  Type

ARAE = All room air exhausted

Single Sheet | Rooms | Roofs | Walls | Int Loads | **Airflows** | Partn/Floors

Create Rooms - Partitions and Floors

Alternative 1

Room description: Kitchen

Templates...

Room: Default  
 Internal: Default  
 Airflow: Medium  
 Tstat: Default  
 Constr: Medium

Partition...

Tag:   
 Length: 0  
 Height: 0  
 Constr:   
 U-factor: 0  
 Adj room:

Adjacent space temperature...  
 Method:   
 Cooling:   
 Heating:

Floor...

Floor - 1

Tag: Floor - 1  
 Exposed  Slab on grade  
 Constr: 2" Wood Floor  
 Area: 154 ft<sup>2</sup> U-factor: 0.266E Btu/hr-ft<sup>2</sup>-F  
 Perim: 0 ft F-factor: 0 Btu/hr-ft<sup>2</sup>-F  
 Adj room: <<No adjacent room>>

External temperature...  
 Method: Hourly OADB  
 Cooling: °F  
 Heating: °F

Single Sheet | Rooms | Roofs | Walls | Jnt Loads | Airflows | **Partn/Floors**

Apply  
 Close  
 New Partition  
 Copy Part  
 Delete Part  
 New Floor  
 Copy Floor  
 Delete Floor

## A.2.2 Lounge

Alternative 1

Room description: Lounge

Templates...

Room: Default | Floor...: 34 ft | Width: 35 ft

Internal: Default | Roof...: 0 ft | 0 ft

Airflow: Default

Tstat: Default

Constr: Default

Equals floor:

Wall..

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 1	34	8	0	40   0	0	0	<input checked="" type="checkbox"/>
Wall - 2	34	8	90	40   0	0	0	<input checked="" type="checkbox"/>
Wall - 3	34	8	180	40   0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 4 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0.08 | cfm/sq ft

Heating vent: 0.08 | cfm/sq ft

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Lounge

Templates...

Room: Default | Floor...: 34 ft | Width: 35 ft

Internal: Default | Roof...: 0 ft | 0 ft

Airflow: Default

Tstat: Default

Constr: Default

Equals floor:

Wall..

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 2	34	8	90	40   0	0	0	<input checked="" type="checkbox"/>
Wall - 3	34	8	180	40   0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0   0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 4 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0.08 | cfm/sq ft

Heating vent: 0.08 | cfm/sq ft

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description Lounge

Design... Apply Close

Templates... Size... Design...

Room Default Length 34 ft Cooling dry bulb 75 °F

Internal Default Width 35 ft Heating dry bulb 70 °F

Airflow Default Height... Relative humidity 50 %

Tstat Default Floor to floor 10 ft Thermostat... Cooling driftpoint 81 °F

Constr Default Plenum 1 ft Heating driftpoint 64 °F

Duplicate... Above ground 0 ft Cooling schedule None

Floor multiplier 1 Heating schedule None

Rooms per zone 1 Sensor Locations... Thermostat Zone

Room mass/avg time lag Time delay based on actual ma... CO2 sensor None

Slab construction type 6" LW Concrete Humidity... Moisture capacitance Medium

Room type Conditioned Humidistat location Room

Acoustic ceiling resistance 1.786 hr-ft<sup>2</sup> °F/Btu

Carpeted

Single Sheet **Rooms** Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description Lounge

Design... Apply Close

Templates... Roof... Design... New Roof

Room Default Tag Construct

Internal Default  Equals floor U-factor 0

Airflow Default  Length 0 Pitch 0 deg

Tstat Default Width 0 Direction 0 deg

Constr Default Skylight...  Roof area 0 % Type



Length 0 U-factor 0

Width 0 Sh. Coef 0

Quantity 0 Ld to RA 0 %

Shading... Internal

Single Sheet Rooms **Roofs** Walls Int Loads Airflows Partn/Floors



**Create Rooms - Walls**

Alternative 1 Apply

Room description: Lounge Close

Templates... Wall...

Room: Default	Wall: Wall - 1	Tag: Wall - 3	Construct: 4" HW Concrete, 2" Ins	<span style="float: right;">New Wall</span>
Internal: Default	Wall: Wall - 2	Length: 34 ft	U-factor: 0.1220 Btu/h-ft <sup>2</sup> -F	<span style="float: right;">Copy Wall</span>
Airflow: Default	Wall: Wall - 3	Height: 8 ft	Tilt: 0 deg	<span style="float: right;">Delete Wall</span>
Tstat: Default		Grnd reflect multiplier: 1	Direction: 180 deg	
Constr: Default		Pct wall area to underfloor plenum: %		

Openings... Opening - 1

Tag: Opening - 1	<input checked="" type="radio"/> Window <input type="radio"/> Door	<span style="float: right;">New Opening</span>
<input checked="" type="checkbox"/> Wall area: 40 %	Type: Double Clear 1/8"	<span style="float: right;">Copy Opening</span>
<input type="checkbox"/> Length: 0 ft	Height: 0 ft	Quantity: 0
U-factor: 0.6 Btu/h-ft <sup>2</sup> -F	Sh. Coef: 0.88	Ld to RA: 0 %
Shading...		
Internal: None		
External: Overhang - None		

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

**Create Rooms - Internal Loads**

Alternative 1 Apply

Room description: Lounge Close

Templates...

Room: Default	People... Activity: None	Density: 4	People	<span style="float: right;">New Load</span>
Internal: Default	Schedule: Base Util - Lodging			<span style="float: right;">Copy</span>
Airflow: Default	Sensible: 250 Btu/h	Latent: 250 Btu/h		<span style="float: right;">Delete</span>
Tstat: Default	Workstations... Density: 1	workstation/person		
Constr: Default				

Lights... Type: Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type: Heat gain: 0 W/sq ft Schedule: Base Util - Lodging

Miscellaneous loads... Misc Load 1

Tag: Misc Load 1	Type: None	<span style="float: right;">New Load</span>
Energy: 0 W/sq ft	Schedule: Base Util - Lodging	<span style="float: right;">Copy</span>
Energy meter: None	Data Center Equipment: No	<span style="float: right;">Delete</span>

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Lounge

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 T stat: Default  
 Constr: Default

Main supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Ventilation...  
 Method: Sum of Outdoor Air  
 Type: Warehouse  
 Cooling: 0.08 cfm/sq ft  
 Heating: 0.08 cfm/sq ft  
 Schedule: Available (100%)

Infiltration...  
 Type: Pressurized, Poor Const.  
 Cooling: 0.7 air changes/hr  
 Heating: 0.7 air changes/hr  
 Schedule: Available (100%)

Auxiliary supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Std 62.1-2004-2010...  
 Clg Ez: Custom %  
 Htg Ez: Custom %  
 Er: Default based on system typ %  
 DCV Min OA Intake: None

Room exhaust...  
 Rate: 0 air changes/hr  
 Schedule: Available (100%)

VAV control...  
 Clg VAV min: % Clg Airflow  
 Htg VAV max: % Clg Airflow  
 Schedule: Available (100%)  
 Type: Default

ARAE = All room air exhausted

Single Sheet | Rooms | Roofs | Walls | Int Loads | **Airflows** | Partn/Floors

Alternative 1

Room description: Lounge

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 T stat: Default  
 Constr: Default

Partition...  
 Tag:   
 Length: 0  
 Height: 0  
 Constr:   
 U-factor: 0  
 Adj room:   
 Adjacent space temperature...: New Partition  
 Method:   
 Cooling:   
 Heating:   
 Copy Part  
 Delete Part

Floor...  
 Tag: Floor - 1  
 Exposed  Slab on grade   
 Constr: 2" Wood Floor  
 Area: 1120 ft² U-factor: 0.266 Btu/h ft²·F  
 Perim: 0 ft F-factor: 0 Btu/hr-ft·F  
 Adj room: <<No adjacent room>>  
 External temperature...: New Floor  
 Method: Hourly OADB  
 Cooling: °F  
 Heating: °F  
 Copy Floor  
 Delete Floor

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | **Partn/Floors**

### A.2.3 Middle

Alternative 1

Room description: Middle

Templates...

Room: Default, Floor: 21 ft, Width: 35 ft, Internal: Default, Roof: 0 ft, Airflow: Default, Tstat: Default, Constr: Default

Length: 21 ft, Width: 35 ft, Roof: 0 ft, Equals floor:

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 1	21	8	180	40	0	0	<input checked="" type="checkbox"/>
Wall - 2	21	8	0	10	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 4, Lighting: 0, Misc loads: 0

Airflows...

Cooling vent: 0.08 cfm/sq ft, Heating vent: 0.08 cfm/sq ft, Cooling VAV min: % Clg Airflow, Heating VAV max: % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Middle

Templates...

Room: Default, Length: 21 ft, Width: 35 ft, Internal: Default, Height: Floor to floor: 10 ft, Plenum: 1 ft, Above ground: 0 ft, Duplicate... Floor multiplier: 1, Rooms per zone: 1, Room mass/avg time lag: Time delay based on actual ma..., Slab construction type: 6" LW Concrete, Room type: Conditioned, Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>-F/Btu, Carpeted:

Design...

Cooling dry bulb: 75 °F, Heating dry bulb: 70 °F, Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F, Heating driftpoint: 64 °F, Cooling schedule: None, Heating schedule: None

Sensor Locations...

Thermostat: Zone, CO2 sensor: None

Humidity...

Moisture capacitance: Medium, Humidistat location: Room

Single Sheet | **Rooms** | Roofs | Walls | Int Loads | Airflows | Partn/Floors



Alternative 1 Apply

Room description Middle Close

Templates... Roof...

Room	Default	<input type="text"/>	Construct	[Dropdown]	New Roof
Internal	Default	<input type="radio"/> Equals floor	U-factor	0	Copy
Airflow	Default	<input type="radio"/> Length	Pitch	0 deg	Delete
T stat	Default	Width	Direction	0 deg	
Constr	Default				

Skylight...

<input type="checkbox"/> Roof area	0 %	Type	[Dropdown]
<input type="checkbox"/> Length	0	U-factor	0
Width	0	Sh. Coef	0
Quantity	0	Ld to RA	0 %

Shading...

Internal [Dropdown]

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1 Apply

Room description Middle Close

Templates... Wall...

Room	Default	Wall - 1	Tag	Wall - 1	Construct	4" HW Concrete, 2" Ins	New Wall
Internal	Default	Wall - 2	Length	21 ft	U-factor	0.1220 Btu/h-ft <sup>2</sup> -F	Copy Wall
Airflow	Default		Height	8 ft	Tilt	0 deg	Delete Wall
T stat	Default		Grnd reflect multiplier	1	Direction	180 deg	
Constr	Default		Pct wall area to underfloor plenum	[ ] %			

Openings...

Opening - 1	Tag	Opening - 1	<input checked="" type="radio"/> Window	<input type="radio"/> Door		New Opening	
	<input checked="" type="checkbox"/> Wall area	40 %	Type	Double Clear 1/8"		Copy Opening	
	<input type="checkbox"/> Length	0 ft	Height	0 ft	Quantity	0	Delete Opening
	U-factor	0.6 Btu/h-ft <sup>2</sup> -F	Sh. Coef	0.88	Ld to RA	0 %	

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Shading...

Internal [Dropdown]

External [Dropdown]

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description Middle

Templates...

Room Default Wall - 1 Wall - 2

Internal Default

Airflow Default

Tstat Default

Constr Default

Wall..

Tag Wall - 2 Construct 4" HW Concrete, 2" Ins

Length 21 ft U-factor 0.1220 Btu/h-ft<sup>2</sup>-F

Height 8 ft Tilt 0 deg

Grnd reflect multiplier 1 Direction 0 deg

Pct wall area to underfloor plenum %

Openings...

Opening - 1

Tag Opening - 1 Window Door

Wall area 10 % Type Double Clear 1/8"

Length 0 ft Height 0 ft Quantity 0

U-factor 0.6 Btu/h-ft<sup>2</sup>-F Sh. Coef 0.88 Ld to RA 0 %

Shading...

Internal None

External Overhang - None

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet Rooms Roofs **Walls** Int Loads Airflows Partn/Floors

Alternative 1

Room description Middle

Templates...

Room Default People... Activity None Density 4 People

Internal Default Schedule Base Util - Lodging

Airflow Default Sensible 250 Btu/h Latent 250 Btu/h

Tstat Default Workstations... Density 1 workstation/person

Constr Default

Lights... Type Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type

Heat gain 0 W/sq ft Schedule Base Util - Lodging

Miscellaneous loads...

Misc Load 1

Tag Misc Load 1 Type None

Energy 0 W/sq ft Schedule Base Util - Lodging

Energy meter None Data Center Equipment No

Single Sheet Rooms Roofs **Walls** **Int Loads** Airflows Partn/Floors

**Create Rooms - Airflows**

Alternative 1 Adjacent air transfer from room

Room description

Templates...		Main supply...		Auxiliary supply...	
Room	<input type="text" value="Default"/>	Cooling	<input type="text" value="To be calculated"/>	Cooling	<input type="text" value="To be calculated"/>
Internal	<input type="text" value="Default"/>	Heating	<input type="text" value="To be calculated"/>	Heating	<input type="text" value="To be calculated"/>
Airflow	<input type="text" value="Default"/>	Ventilation...		Std 62.1-2004-2010...	
Tstat	<input type="text" value="Default"/>	Method	<input type="text" value="Sum of Outdoor Air"/>	Clg Ez	<input type="text" value="Custom"/> %
Constr	<input type="text" value="Default"/>	Type	<input type="text" value="Warehouse"/>	Htg Ez	<input type="text" value="Custom"/> %
		Cooling	<input type="text" value="0.08"/> cfm/sq ft	Er	<input type="text" value="Default based on system typ"/> %
		Heating	<input type="text" value="0.08"/> cfm/sq ft	DCV Min OA Intake	<input type="text" value="None"/>
		Schedule	<input type="text" value="Available (100%)"/>	Room exhaust...	
		Infiltration...		Rate	<input type="text" value="0"/> air changes/hr
		Type	<input type="text" value="Pressurized, Poor Const."/>	Schedule	<input type="text" value="Available (100%)"/>
		Cooling	<input type="text" value="0.7"/> air changes/hr	VAV control...	
		Heating	<input type="text" value="0.7"/> air changes/hr	Clg VAV min	<input type="text" value=""/> % Clg Airflow
		Schedule	<input type="text" value="Available (100%)"/>	Htg VAV max	<input type="text" value=""/> % Clg Airflow
				Schedule	<input type="text" value="Available (100%)"/>
				Type	<input type="text" value="Default"/>

ARAE = All room air exhausted

**Create Rooms - Partitions and Floors**

Alternative 1

Room description

Templates...		Partition...		Adjacent space temperature...	
Room	<input type="text" value="Default"/>	Tag	<input type="text"/>	Method	<input type="text"/>
Internal	<input type="text" value="Default"/>	Length	<input type="text" value="0"/>	Cooling	<input type="text"/>
Airflow	<input type="text" value="Default"/>	Height	<input type="text" value="0"/>	Heating	<input type="text"/>
Tstat	<input type="text" value="Default"/>	Constr	<input type="text"/>		
Constr	<input type="text" value="Default"/>	U-factor	<input type="text" value="0"/>		
		Adj room	<input type="text"/>		
		Floor...		External temperature...	<input type="text" value="New Floor"/>
		Tag	<input type="text" value="Floor - 1"/>	Method	<input type="text" value="Adjacent Room"/>
		<input checked="" type="radio"/> Exposed <input type="radio"/> Slab on grade		Cooling	<input type="text" value=""/> °F
		Constr	<input conc"="" hw="" type="text" value="6"/>	Heating	<input type="text" value=""/> °F
		Area	<input type="text" value="735"/> ft²		
		Perim	<input type="text" value="0"/> ft		
		U-factor	<input type="text" value="0.6587"/> Btu/h ft² °F		
		F-factor	<input type="text" value="0"/> Btu/hr ft °F		
		Adj room	<input type="text" value="Basement-large"/>		

## A.2.4 Office Area

Alternative 1

Room description: Office Area

Templates...

Room: Default | Length: 23 ft | Width: 13 ft

Internal: Default | Roof: 0 ft | 0 ft

Airflow: Default |  Equals floor

Tstat: Default

Constr: Default

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 1	23	8	0	60 0	0	0	<input checked="" type="checkbox"/>
Wall - 2	13	8	270	20 0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0 0	0	0	<input type="checkbox"/>

Internal loads...

People: 4 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0.08 | cfm/sq ft

Heating vent: 0.08 | cfm/sq ft

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Office Area

Templates...

Room: Default | Length: 23 ft | Width: 13 ft

Internal: Default | Height: 10 ft

Airflow: Default | Plenum: 1 ft

Tstat: Default | Above ground: 0 ft

Constr: Default | Duplicate... | Floor multiplier: 1

Rooms per zone: 1

Room mass/avg time lag: Time delay based on actual ma-

Slab construction type: 6" LW Concrete

Room type: Conditioned

Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>-°F/Btu

Carpeted

Design...

Cooling dry bulb: 75 °F

Heating dry bulb: 70 °F

Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F

Heating driftpoint: 64 °F

Cooling schedule: None

Heating schedule: None

Sensor Locations...

Thermostat: Zone

CO2 sensor: None

Humidity...

Moisture capacitance: Medium

Humidistat location: Room

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1 Apply

Room description Office Area Close

Templates... Roof...

Room	Default	<input type="text"/>	Tag	<input type="text"/>	Construct	<input type="text"/>	<b>New Roof</b>
Internal	Default	<input type="text"/>	<input type="radio"/> Equals floor	U-factor	0		Copy
Airflow	Default	<input type="text"/>	<input type="radio"/> Length	0	Pitch	0 deg	Delete
Tstat	Default	<input type="text"/>	Width	0	Direction	0 deg	
Constr	Default	<input type="text"/>	Skylight...		<input type="checkbox"/> Roof area	0 %	Type <input type="text"/>
			<input type="checkbox"/> Length	0	U-factor	0	
			Width	0	Sh. Coef	0	
			Quantity	0	Ld to RA	0 %	

Shading...  
Internal

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1 Apply

Room description Office Area Close

Templates... Wall...

Room	Default	<b>Wall - 1</b>	Tag	Wall - 1	Construct	4" HW Concrete, 2" Ins	<b>New Wall</b>
Internal	Default	Wall - 2	Length	23 ft	U-factor	0.1220; Btu/h-ft <sup>2</sup> -F	Copy Wall
Airflow	Default		Height	8 ft	Tilt	0 deg	Delete Wall
Tstat	Default		Grnd reflect multiplier	1	Direction	0 deg	
Constr	Default		Pct wall area to underfloor plenum	<input type="text"/>			

Openings... Opening - 1

Tag	Opening - 1	<input type="checkbox"/> Wall area	60 %	Type	Double Clear 1/8"	<b>New Opening</b>	
<input type="checkbox"/> Length	0 ft	<input checked="" type="radio"/> Window	<input type="radio"/> Door	Height	0 ft	Quantity	0
U-factor	0.6 Btu/h-ft <sup>2</sup> -F	Sh. Coef	0.88	Ld to RA	0 %	Copy Opening	Delete Opening

Shading...  
Internal   
External

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Office Area

Templates...

Room: Default | Wall: Wall - 1 | Wall - 2

Internal: Default | Airflow: Default | Tstat: Default | Constr: Default

Wall - 2

Tag: Wall - 2 | Construct: 4" HW Concrete, 2" Ins

Length: 13 ft | U-factor: 0.1220 Btu/h-ft<sup>2</sup>-F

Height: 8 ft | Tilt: 0 deg

Grnd reflect multiplier: 1 | Direction: 270 deg

Pct wall area to underfloor plenum: %

Openings...

Opening - 1

Tag: Opening - 1 | Window | Door

Wall area: 20 % | Type: Double Clear 1/8"

Length: 0 ft | Height: 0 ft | Quantity: 0

U-factor: 0.6 Btu/h-ft<sup>2</sup>-F | Sh. Coef: 0.88 | Ld to RA: 0 %

Shading...

Internal: None | External: Overhang - None

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Buttons: Apply, Close, New Wall, Copy Wall, Delete Wall, New Opening, Copy Opening, Delete Opening

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description: Office Area

Templates...

Room: Default | People... Activity: None | Density: 4 People

Internal: Default | Schedule: Base Util - Lodging

Airflow: Default | Sensible: 250 Btu/h | Latent: 250 Btu/h

Tstat: Default | Workstations... Density: 1 workstation/person

Constr: Default

Lights...

Type: Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type:

Heat gain: 0 W/sq ft | Schedule: Base Util - Lodging

Miscellaneous loads...

Misc Load 1

Tag: Misc Load 1 | Type: None

Energy: 0 W/sq ft | Schedule: Base Util - Lodging

Energy meter: None | Data Center Equipment: No

Buttons: Apply, Close, New Load, Copy, Delete

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

**Create Rooms - Airflows**

Alternative 1 Adjacent air transfer from room

Room description

Templates...		Main supply...		Auxiliary supply...	
Room	<input type="text" value="Default"/>	Cooling	<input type="text" value="To be calculated"/>	Cooling	<input type="text" value="To be calculated"/>
Internal	<input type="text" value="Default"/>	Heating	<input type="text" value="To be calculated"/>	Heating	<input type="text" value="To be calculated"/>
Airflow	<input type="text" value="Default"/>	Ventilation...		Std 62.1-2004-2010...	
Tstat	<input type="text" value="Default"/>	Method	<input type="text" value="Sum of Outdoor Air"/>	Clg Ez	<input type="text" value="Custom"/> %
Constr	<input type="text" value="Default"/>	Type	<input type="text" value="Warehouse"/>	Htg Ez	<input type="text" value="Custom"/> %
		Cooling	<input type="text" value="0.08"/> cfm/sq ft	Er	<input type="text" value="Default based on system typ"/> %
		Heating	<input type="text" value="0.08"/> cfm/sq ft	DCV Min OA Intake	<input type="text" value="None"/>
		Schedule	<input type="text" value="Available (100%)"/>	Room exhaust...	
		Infiltration...		Rate	<input type="text" value="0"/> air changes/hr
		Type	<input type="text" value="Pressurized, Poor Const."/>	Schedule	<input type="text" value="Available (100%)"/>
		Cooling	<input type="text" value="0.7"/> air changes/hr	VAV control...	
		Heating	<input type="text" value="0.7"/> air changes/hr	Clg VAV min	<input type="text" value=""/> % Clg Airflow
		Schedule	<input type="text" value="Available (100%)"/>	Htg VAV max	<input type="text" value=""/> % Clg Airflow
		ARAE = All room air exhausted		Schedule	<input type="text" value="Available (100%)"/>
				Type	<input type="text" value="Default"/>

**Create Rooms - Partitions and Floors**

Alternative 1

Room description

Templates...		Partition...		Adjacent space temperature...	
Room	<input type="text" value="Default"/>	Tag	<input type="text"/>	Method	<input type="text"/>
Internal	<input type="text" value="Default"/>	Length	<input type="text" value="0"/>	Cooling	<input type="text"/>
Airflow	<input type="text" value="Default"/>	Height	<input type="text" value="0"/>	Heating	<input type="text"/>
Tstat	<input type="text" value="Default"/>	Constr	<input type="text"/>	<input type="button" value="New Partition"/>	
Constr	<input type="text" value="Default"/>	U-factor	<input type="text" value="0"/>	<input type="button" value="Copy Part"/>	
		Adj room	<input type="text"/>	<input type="button" value="Delete Part"/>	
		Floor...		External temperature...	
		Tag	<input type="text" value="Floor - 1"/>	Method	<input type="text" value="Hourly OADB"/>
		<input checked="" type="radio"/> Exposed <input type="radio"/> Slab on grade		Cooling	<input type="text"/> °F
		Constr	<input floor"="" type="text" value="2" wood=""/>	Heating	<input type="text"/> °F
		Area	<input type="text" value="182"/> ft²	<input type="button" value="New Floor"/>	
		Perim	<input type="text" value="0"/> ft	<input type="button" value="Copy Floor"/>	
		U-factor	<input type="text" value="0.266E"/> Btu/h-ft²-°F	<input type="button" value="Delete Floor"/>	
		F-factor	<input type="text" value="0"/> Btu/hr-ft-°F		
		Adj room	<input type="text" value="&lt;&lt;No adjacent room&gt;&gt;"/>		

## A.2.5 Stairs

Alternative 1

Room description: Stairs

Templates...

Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Floor...: 34 ft    Width: 22 ft  
 Roof...: 0 ft    0 ft  
 Equals floor

Wall..

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
Wall - 1	34	8	180	28 0	0	0	<input checked="" type="checkbox"/>
Wall - 2	22	8	270	8 0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0 0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 4 People  
 Lighting: 0 W/sq ft  
 Misc loads: 0 W/sq ft

Airflows...

Cooling vent: 0.08 cfm/sq ft  
 Heating vent: 0.08 cfm/sq ft  
 Cooling VAV min: % Clg Airflow  
 Heating VAV max: % Clg Airflow

Single Sheet   Rooms   Roofs   Walls   Int Loads   Airflows   Partn/Floors

Alternative 1

Room description: Stairs

Templates...

Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Size...

Length: 34 ft    Width: 22 ft  
 Height...

Floor to floor: 10 ft  
 Plenum: 1 ft  
 Above ground: 0 ft  
 Duplicate...    Floor multiplier: 1  
                     Rooms per zone: 1

Room mass/avg time lag: Time delay based on actual ma...  
 Slab construction type: 6" LW Concrete  
 Room type: Conditioned  
 Acoustic ceiling resistance: 1.786 hr ft<sup>2</sup> °F/Btu  
 Carpeted:

Design...

Cooling dry bulb: 75 °F  
 Heating dry bulb: 70 °F  
 Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F  
 Heating driftpoint: 64 °F  
 Cooling schedule: None  
 Heating schedule: None

Sensor Locations...

Thermostat: Zone  
 CO2 sensor: None

Humidity...

Moisture capacitance: Medium  
 Humidistat location: Room

Single Sheet   **Rooms**   Roofs   Walls   Int Loads   Airflows   Partn/Floors



Alternative 1

Room description: Stairs

Templates...

Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

Roof...

Tag:   
Construct:   
U-factor: 0  
Pitch: 0 deg  
Direction: 0 deg

Equals floor  
 Length: 0  
 Width: 0

Skylight...  
 Roof area: 0 %  
 Length: 0  
 Width: 0  
 Quantity: 0  
 Type:   
 U-factor: 0  
 Sh. Coef: 0  
 Ld to RA: 0 %

Shading...  
Internal:

Single Sheet | Rooms | **Roofs** | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Stairs

Templates...

Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

Wall...

Wall - 1  
 Wall - 2

Tag: Wall - 1  
Construct: 4" HW Concrete, 2" Ins  
Length: 34 ft  
Height: 8 ft  
U-factor: 0.1220 Btu/h-ft<sup>2</sup>-F  
Tilt: 0 deg  
Gmrd reflect multiplier: 1  
Direction: 180 deg  
Pct wall area to underfloor plenum: %

Wall area: 28 %  
 Length: 0 ft  
 U-factor: 0.6 Btu/h-ft<sup>2</sup>-F  
 Sh. Coef: 0.88  
 Ld to RA: 0 %

Window  Door  
 Type: Double Clear 1/8"  
 Height: 0 ft  
 Quantity: 0

Shading...  
Internal: None  
External: Overhang - None

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet | Rooms | Roofs | **Walls** | Int Loads | Airflows | Partn/Floors

**Create Rooms - Walls**

Alternative 1  
Room description: Stairs

Templates...  
Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

Wall...  
Wall - 1  
Wall - 2

Tag: Wall - 2  
Construct: 4" HW Concrete, 2" Ins  
Length: 22 ft  
Height: 8 ft  
Grnd reflect multiplier: 1  
Pct wall area to underfloor plenum: %

U-factor: 0.1220 Btu/h-ft<sup>2</sup>-F  
Tilt: 0 deg  
Direction: 270 deg

Openings...  
Opening - 1

Tag: Opening - 1  
 Window  Door  
 Wall area: 8 % Type: Double Clear 1/8"  
 Length: 0 ft Height: 0 ft Quantity: 0  
U-factor: 0.6 Btu/h-ft<sup>2</sup>-F Sh. Coef: 0.88 Ld to RA: 0 %

Shading...  
Internal: None  
External: Overhang - None

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Buttons: Apply, Close, New Wall, Copy Wall, Delete Wall, New Opening, Copy Opening, Delete Opening

Navigation: Single Sheet, Rooms, Roofs, **Walls**, Int Loads, Airflows, Partn/Floors

**Create Rooms - Internal Loads**

Alternative 1  
Room description: Stairs

Templates...  
Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

People... Activity: None Density: 4 People  
Schedule: Base Util - Lodging  
Sensible: 250 Btu/h Latent: 250 Btu/h

Workstations... Density: 1 workstation/person

Lights... Type: Fluorescent, hung below ceiling, 100% load to space  
ASHRAE Space/Area Type:  
Heat gain: 0 W/sq ft Schedule: Base Util - Lodging

Miscellaneous loads...  
Misc Load 1 Tag: Misc Load 1 Type: None  
Energy: 0 W/sq ft Schedule: Base Util - Lodging  
Energy meter: None Data Center Equipment: No

Buttons: Apply, Close, New Load, Copy, Delete

Navigation: Single Sheet, Rooms, Roofs, Walls, **Int Loads**, Airflows, Partn/Floors

Alternative 1

Room description: Stairs

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Main supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Ventilation...  
 Method: Sum of Outdoor Air  
 Type: Warehouse  
 Cooling: 0.08 cfm/sq ft  
 Heating: 0.08 cfm/sq ft  
 Schedule: Available (100%)

Infiltration...  
 Type: Pressurized, Poor Const.  
 Cooling: 0.7 air changes/hr  
 Heating: 0.7 air changes/hr  
 Schedule: Available (100%)

Auxiliary supply...  
 Cooling: To be calculated  
 Heating: To be calculated

Std 62.1-2004-2010...  
 Clg Ez: Custom %  
 Htg Ez: Custom %  
 Er: Default based on system typ %  
 DCV Min OA Intake: None

Room exhaust...  
 Rate: 0 air changes/hr  
 Schedule: Available (100%)

VAV control...  
 Clg VAV min: % Clg Airflow  
 Htg VAV max: % Clg Airflow  
 Schedule: Available (100%)  
 Type: Default

ARAE = All room air exhausted

Single Sheet | Rooms | Roofs | Walls | Int Loads | **Airflows** | Partn/Floors

Alternative 1

Room description: Stairs

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Partition...  
 Tag:   
 Length: 0  
 Height: 0  
 Constr:   
 U-factor: 0  
 Adj room:   
 Adjacent space temperature...: New Partition  
 Method:   
 Cooling:   
 Heating:   
 Copy Part  
 Delete Part

Floor...  
 Tag: Floor - 1  
 Exposed  Slab on grade   
 Constr: 2" Wood Floor  
 Area: 714 ft² U-factor: 0.266 Btu/hr-ft²-F  
 Perim: 0 ft F-factor: 0 Btu/hr-ft²-F  
 Adj room: <<No adjacent room>>  
 External temperature...: New Floor  
 Method: Hourly QADB  
 Cooling: °F  
 Heating: °F  
 Copy Floor  
 Delete Floor

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | **Partn/Floors**

## A.2.6 Attic

Alternative 1

Room description: Attic

Templates...

Room: Default | Length: 90 ft | Width: 35 ft

Internal: Default | Roof: 52 ft | 35 ft

Airflow: Default | Equals floor

Tstat: Default

Constr: Default

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 2 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0.08 | cfm/sq ft

Heating vent: 0.08 | cfm/sq ft

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Attic

Templates...

Room: Default | Length: 90 ft | Width: 35 ft

Internal: Default | Height: 10 ft

Airflow: Default | Plenum: 1 ft

Tstat: Default | Above ground: 10 ft

Constr: Default | Duplicate... | Floor multiplier: 1

Rooms per zone: 1

Room mass/avg time lag: Time delay based on actual ma

Slab construction type: 6" LW Concrete

Room type: Unconditioned

Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>-°F/Btu

Carpeted:

Design...

Cooling dry bulb: 75 °F

Heating dry bulb: 70 °F

Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F

Heating driftpoint: 64 °F

Cooling schedule: None

Heating schedule: None

Sensor Locations...

Thermostat: None



CO2 sensor: None

Humidity...

Moisture capacitance: Medium

Humidistat location: None

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors



Alternative 1

Room description: Attic

Templates...

Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

Wall...

Tag: Wall - 2  
Length: 22  
Height: 8  
Grnd reflect multiplier: 1  
Pct wall area to underfloor plenum: %

Construct:   
U-factor: 0.1220  
Tilt: 0 deg  
Direction: 270 deg

Openings...

Tag:   
Wall area: 0 %  
Length: 0  
U-factor: 0

Window  Door

Height: 0  
Quantity: 0  
Sh. Coef: 0  
Ld to RA: 0 %

Shading...

Internal:   
External:

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Buttons: Apply, Close, New Wall, Copy Wall, Delete Wall, New Opening, Copy Opening, Delete Opening

Navigation: Single Sheet, Rooms, Roofs, **Walls**, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description: Attic

Templates...

Room: Default  
Internal: Default  
Airflow: Default  
Tstat: Default  
Constr: Default

People... Activity: None  
Density: 2 People  
Schedule: Base Util - Lodging  
Sensible: 250 Btu/h  
Latent: 250 Btu/h

Workstations...  
Density: 1 workstation/person

Lights...  
Type: Fluorescent, hung below ceiling, 100% load to space  
ASHRAE Space/Area Type:   
Heat gain: 0 W/sq ft  
Schedule: Base Util - Lodging

Miscellaneous loads...

Misc Load 1  
Tag: Misc Load 1  
Energy: 0 W/sq ft  
Energy meter: None  
Type: None  
Schedule: Base Util - Lodging  
Data Center Equipment: No

Buttons: Apply, Close, New Load, Copy, Delete

Navigation: Single Sheet, Rooms, Roofs, Walls, **Int Loads**, Airflows, Partn/Floors

Alternative 1

Room description: Attic

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Main supply...  
 Cooling: To be calculated  
 Heating: To be calculated  
 Ventilation...  
 Method: Sum of Outdoor Air  
 Type: Warehouse  
 Cooling: 0.08 cfm/sq ft  
 Heating: 0.08 cfm/sq ft  
 Schedule: Available (100%)

Infiltration...  
 Type: Pressurized, Poor Const.  
 Cooling: 0.7 air changes/hr  
 Heating: 0.7 air changes/hr  
 Schedule: Available (100%)

Auxiliary supply...  
 Cooling: To be calculated  
 Heating: To be calculated  
 Std 62.1-2004-2010...  
 Clg Ez: Custom %  
 Htg Ez: Custom %  
 Er: Default based on system typ %  
 DCV Min OA Intake: None

Room exhaust...  
 Rate: 0 air changes/hr  
 Schedule: Available (100%)

VAV control...  
 Clg VAV min: % Clg Airflow  
 Htg VAV max: % Clg Airflow  
 Schedule: Available (100%)  
 Type: Default

ARAE = All room air exhausted

Single Sheet | Rooms | Roofs | Walls | Int Loads | **Airflows** | Partn/Floors

Alternative 1

Room description: Attic

Templates...  
 Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Partition...  
 Tag:   
 Length: 0  
 Height: 0  
 Constr:   
 U-factor: 0  
 Adj room:   
 Adjacent space temperature...: New Partition  
 Method:   
 Cooling:   
 Heating:   
 Copy Part  
 Delete Part

Floor...  
 Tag: Floor - 1  
 Exposed  Slab on grade   
 Constr: 2" Wood Floor  
 Area: 3150 ft²  
 Perim: 0 ft  
 U-factor: 0.2666 Btu/h ft²·F  
 F-factor: 0 Btu/hr ft·F  
 Adj room: <<No adjacent room>>  
 External temperature...: New Floor  
 Method: Hourly OADB  
 Cooling: °F  
 Heating: °F  
 Copy Floor  
 Delete Floor

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | **Partn/Floors**

## A.2.7 Basement-Large

Alternative 1

Room description: Basement-large

Templates...

Room: Default | Floor...: 21 ft | Width: 15 ft

Internal: Default | Roof...: 0 ft | 0 ft

Airflow: Default

Tstat: Default

Constr: Default

Wall..

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 1 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0 | cfm

Heating vent: 0 | cfm

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1

Room description: Basement-large

Templates...

Room: Default | Length: 21 ft | Width: 15 ft

Internal: Default | Height...: Floor to floor: 11 ft | Plenum: 2 ft | Above ground: -11 ft

Airflow: Default

Tstat: Default

Constr: Default

Duplicate... | Floor multiplier: 1 | Rooms per zone: 1

Room mass/avg time lag: Time delay based on actual ma... | Slab construction type: 6" LW Concrete

Room type: Unconditioned

Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>\*F/Btu

Carpeted:

Design...

Cooling dry bulb: 75 °F

Heating dry bulb: 70 °F

Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F

Heating driftpoint: 64 °F

Cooling schedule: None

Heating schedule: None

Sensor Locations...

Thermostat: None

CO2 sensor: None

Humidity...

Moisture capacitance: Medium

Humidistat location: None

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors



Alternative 1 Apply

Room description Basement-large Close

Templates... Roof...

Room	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid gray; padding: 2px;">Roof - 2</span>	Construct	<span style="border: 1px solid gray; padding: 2px;">[ ]</span>	<span style="border: 1px solid gray; padding: 2px;">New Roof</span>
Internal	<span style="border: 1px solid gray; padding: 2px;">Default</span>		<input type="radio"/> Equals floor	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.15749</span>		<span style="border: 1px solid gray; padding: 2px;">Copy</span>
Airflow	<span style="border: 1px solid gray; padding: 2px;">Default</span>		<input checked="" type="radio"/> Length	<span style="border: 1px solid gray; padding: 2px;">52</span>	Pitch	<span style="border: 1px solid gray; padding: 2px;">-60</span> deg	<span style="border: 1px solid gray; padding: 2px;">Delete</span>
Tstat	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Width	<span style="border: 1px solid gray; padding: 2px;">35</span>	Direction	<span style="border: 1px solid gray; padding: 2px;">0</span> deg	
Constr	<span style="border: 1px solid gray; padding: 2px;">Default</span>						

Skylight...

<input type="checkbox"/> Roof area	<span style="border: 1px solid gray; padding: 2px;">0</span> %	Type	<span style="border: 1px solid gray; padding: 2px;">[ ]</span>
<input type="checkbox"/> Length	<span style="border: 1px solid gray; padding: 2px;">0</span>	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.95</span>
Width	<span style="border: 1px solid gray; padding: 2px;">0</span>	Sh. Coef	<span style="border: 1px solid gray; padding: 2px;">0.95</span>
Quantity	<span style="border: 1px solid gray; padding: 2px;">1</span>	Ld to RA	<span style="border: 1px solid gray; padding: 2px;">0</span> %

Shading...

Internal [ ]

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors

Alternative 1 Apply

Room description Basement-large Close

Templates... Wall...

Room	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid gray; padding: 2px;">Wall - 2</span>	Construct	<span style="border: 1px solid gray; padding: 2px;">[ ]</span>	<span style="border: 1px solid gray; padding: 2px;">New Wall</span>
Internal	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Length	<span style="border: 1px solid gray; padding: 2px;">22</span>	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.1220</span>	<span style="border: 1px solid gray; padding: 2px;">Copy Wall</span>
Airflow	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Height	<span style="border: 1px solid gray; padding: 2px;">8</span>	Tilt	<span style="border: 1px solid gray; padding: 2px;">0</span> deg	<span style="border: 1px solid gray; padding: 2px;">Delete Wall</span>
Tstat	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Grnd reflect multiplier	<span style="border: 1px solid gray; padding: 2px;">1</span>	Direction	<span style="border: 1px solid gray; padding: 2px;">270</span> deg	
Constr	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Pct wall area to underfloor plenum	<span style="border: 1px solid gray; padding: 2px;">[ ]</span> %			

Openings...

	Tag	<span style="border: 1px solid gray; padding: 2px;">[ ]</span>	<input type="radio"/> Window	<input type="radio"/> Door		<span style="border: 1px solid gray; padding: 2px;">New Opening</span>
	<input type="checkbox"/> Wall area	<span style="border: 1px solid gray; padding: 2px;">0</span> %	Type	<span style="border: 1px solid gray; padding: 2px;">[ ]</span>		<span style="border: 1px solid gray; padding: 2px;">Copy Opening</span>
	<input type="checkbox"/> Length	<span style="border: 1px solid gray; padding: 2px;">0</span>	Height	<span style="border: 1px solid gray; padding: 2px;">0</span>	Quantity	<span style="border: 1px solid gray; padding: 2px;">0</span>
	U-factor	<span style="border: 1px solid gray; padding: 2px;">0</span>	Sh. Coef	<span style="border: 1px solid gray; padding: 2px;">0</span>	Ld to RA	<span style="border: 1px solid gray; padding: 2px;">0</span> %
						<span style="border: 1px solid gray; padding: 2px;">Delete Opening</span>

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Shading...

Internal [ ]

External [ ]

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors

Alternative 1

Room description: Basement-large

Templates...

Room: Default People... Activity: None Density: 1 People

Internal: Default Schedule: Base Util - Lodging

Airflow: Default Sensible: 250 Btu/h Latent: 250 Btu/h

Tstat: Default Workstations... Density: 1 workstation/person

Constr: Default

Lights... Type: Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type:

Heat gain: 0 W/sq ft Schedule: Base Util - Lodging

Miscellaneous loads...

Misc Load 1 Tag: Misc Load 1 Type: None

Energy: 0 W/sq ft Schedule: Base Util - Lodging

Energy meter: None Data Center Equipment: No

Buttons: Single Sheet, Rooms, Roofs, Walls, **Int Loads**, Airflows, Partn/Floors

Alternative 1

Room description: Basement-large

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...

Room: Default Main supply... Cooling: To be calculated Heating: To be calculated

Internal: Default Auxiliary supply... Cooling: To be calculated Heating: To be calculated

Airflow: Default Ventilation... Method: Sum of Outdoor Air

Tstat: Default Type: None

Constr: Default Cooling: 0 cfm Heating: 0 cfm

Schedule: Available (100%) Std 62.1-2004-2010... Clg Ez: Custom Htg Ez: Custom Er: Default based on system typ

DCV Min OA Intake: None

Room exhaust... Rate: 0 air changes/hr Schedule: Available (100%)

VAV control... Clg VAV min: % Clg Airflow Htg VAV max: % Clg Airflow Schedule: Available (100%) Type: Default

ARAE = All room air exhausted

Buttons: Single Sheet, Rooms, Roofs, Walls, Int Loads, **Airflows**, Partn/Floors

Alternative 1

Room description Basement-large

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition -

Partition -

Partition -

Partition -

Tag Partition - left

Length 21 ft

Height 6.5 ft

Constr 1" Wood Frame

U-factor 0.2145 Btu/h-ft<sup>2</sup>-°F

Adj room Basement-left

Adjacent space temperature...

Method Ground

Cooling °F

Heating °F

Floor...

Floor - 1

Tag Floor - 1

External temperature...

Method Ground

Cooling °F

Heating °F

Constr 2" HW Concrete

Area 630 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F

F-factor 0 Btu/hr-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description Basement-large

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition -

Partition -

Partition -

Partition -

Tag Partition - left adj

Length 10 ft

Height 1.5 ft

Constr 4" HW Conc

U-factor 0.5871 Btu/h-ft<sup>2</sup>-°F

Adj room Basement-left

Adjacent space temperature...

Method Adjacent Room

Cooling °F

Heating °F

Floor...

Floor - 1

Tag Floor - 1

External temperature...

Method Ground

Cooling °F

Heating °F

Constr 2" HW Concrete

Area 630 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F

F-factor 0 Btu/hr-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description Basement-large

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition - Partition -

Tag Partition - north

Length 35 ft

Height 8 ft

Constr 1" Wood Frame

U-factor 0.214E Btu/h-ft<sup>2</sup>-F

Adj room <<No adjacent room>>

Adjacent space temperature...

Method Ground

Cooling  °F

Heating  °F

Floor...

Floor - 1

Tag Floor - 1

Exposed  Slab on grade

Constr 2" HW Concrete

Area 630 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-F

F-factor 0 Btu/hr-ft<sup>2</sup>-F

Adj room <<No adjacent room>>

External temperature...

Method Ground

Cooling  °F

Heating  °F

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, **Partn/Floors**

Alternative 1

Room description Basement-large

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition - Partition -

Tag Partition - right

Length 21 ft

Height 6.5 ft

Constr 1" Wood Frame

U-factor 0.214E Btu/h-ft<sup>2</sup>-F

Adj room <<No adjacent room>>

Adjacent space temperature...

Method Ground

Cooling  °F

Heating  °F

Floor...

Floor - 1

Tag Floor - 1

Exposed  Slab on grade

Constr 2" HW Concrete

Area 630 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-F

F-factor 0 Btu/hr-ft<sup>2</sup>-F

Adj room <<No adjacent room>>

External temperature...

Method Ground

Cooling  °F

Heating  °F

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, **Partn/Floors**

Alternative 1 Apply

Room description Basement-large Close

Templates... Partition...

Room	Default	Partition -	Tag	Partition - right adj	Adjacent space temperature...	New Partition
Internal	Default	Partition -	Length	10 ft	Method	Adjacent Room
Airflow	Default	Partition -	Height	1.5 ft	Cooling	<input type="checkbox"/> °F
Tstat	Default	Partition -	Constr	4" HW Conc	Heating	<input type="checkbox"/> °F
Constr	Default		U-factor	0.5877 Btu/h-ft <sup>2</sup> -°F		
			Adj room	Basement-right		

Floor...

		Tag	Floor - 1	External temperature...	New Floor
			<input checked="" type="radio"/> Exposed <input type="radio"/> Slab on grade	Method	Ground
		Constr	2" HW Concrete	Cooling	<input type="checkbox"/> °F
		Area	630 ft <sup>2</sup>	U-factor	0.6507 Btu/h-ft <sup>2</sup> -°F
		Perim	0 ft	F-factor	0 Btu/hr-ft <sup>2</sup> -°F
		Adj room	<<No adjacent room>>	Heating	<input type="checkbox"/> °F

Single Sheet Rooms Roofs Walls Int Loads Airflows **Partn/Floors**

Alternative 1 Apply

Room description Basement-large Close

Templates... Partition...

Room	Default	Partition -	Tag	Partition - south	Adjacent space temperature...	New Partition
Internal	Default	Partition -	Length	35 ft	Method	Ground
Airflow	Default	Partition -	Height	8 ft	Cooling	<input type="checkbox"/> °F
Tstat	Default		Constr	1" Wood Frame	Heating	<input type="checkbox"/> °F
Constr	Default		U-factor	0.2145 Btu/h-ft <sup>2</sup> -°F		
			Adj room	<<No adjacent room>>		

Floor...

		Tag	Floor - 1	External temperature...	New Floor
			<input checked="" type="radio"/> Exposed <input type="radio"/> Slab on grade	Method	Ground
		Constr	2" HW Concrete	Cooling	<input type="checkbox"/> °F
		Area	630 ft <sup>2</sup>	U-factor	0.6507 Btu/h-ft <sup>2</sup> -°F
		Perim	0 ft	F-factor	0 Btu/hr-ft <sup>2</sup> -°F
		Adj room	<<No adjacent room>>	Heating	<input type="checkbox"/> °F

Single Sheet Rooms Roofs Walls Int Loads Airflows **Partn/Floors**

**Create Rooms - Partitions and Floors**

Alternative 1

Room description: Basement-large

Templates... Partition...

Room: Default  
 Internal: Default  
 Airflow: Default  
 Tstat: Default  
 Constr: Default

Partition...

Tag: Partition - top  
 Length: 21 ft  
 Height: 15 ft  
 Constr: 1" Wood Frame  
 U-factor: 0.2145 Btu/h-ft<sup>2</sup>-F  
 Adj room: Middle

Adjacent space temperature...  
 Method: Adjacent Room  
 Cooling: °F  
 Heating: °F

Floor...

Floor - 1

Tag: Floor - 1  
 Exposed  Slab on grade  
 Constr: 2" HW Concrete  
 Area: 630 ft<sup>2</sup> U-factor: 0.6507 Btu/h-ft<sup>2</sup>-F  
 Perim: 0 ft F-factor: 0 Btu/hr-ft<sup>2</sup>-F  
 Adj room: <<No adjacent room>>

External temperature...  
 Method: Ground  
 Cooling: °F  
 Heating: °F

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

## A.2.8 Basement-Left

Alternative 1

Room description **Basement-left**

Templates...

Room **Default** Floor... **10** ft **10** ft

Internal **Default** Roof...  **0** ft **0** ft

Airflow **Default**  Equals floor

Tstat **Default**

Constr **Default**

Wall...

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People **0** **People**

Lighting **0** **W/sq ft**

Misc loads **0** **W/sq ft**

Airflows...

Cooling vent **0** **cfm**

Heating vent **0** **cfm**

Cooling VAV min  **% Clg Airflow**

Heating VAV max  **% Clg Airflow**

**Single Sheet** Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description **Basement-left**

Templates...

Room **Default** Length **10** ft

Internal **Default** Width **10** ft

Airflow **Default** Height...

Tstat **Default** Floor to floor **3** ft

Constr **Default** Plenum **1** ft

Above ground **-3** ft

Duplicate... Floor multiplier **1**

Rooms per zone **1**

Room mass/avg time lag **Time delay based on actual ma...**

Slab construction type **6" LW Concrete**

Room type **Unconditioned**

Acoustic ceiling resistance **1.786** hr-ft<sup>2</sup>·°F/Btu

Carpeted

Design...

Cooling dry bulb **75** °F

Heating dry bulb **70** °F

Relative humidity **50** %

Thermostat...

Cooling driftpoint **81** °F

Heating driftpoint **64** °F

Cooling schedule **None**

Heating schedule **None**

Sensor Locations...

Thermostat **None**

CO2 sensor **None**

Humidity...

Moisture capacitance **Medium**

Humidistat location **None**

**Single Sheet** **Rooms** Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description: Basement-left

Templates... Room: Default, Internal: Default, Airflow: Default, Tstat: Default, Constr: Default

Roof... Tag: Roof - 2, Construct: [Dropdown], U-factor: 0.15749, Pitch: -60 deg, Direction: 0 deg

Skylight...  Roof area: 0 % Type: [Dropdown],  Length: 0, Width: 0, Quantity: 1, U-factor: 0.95, Sh. Coef: 0.95, Ld to RA: 0 %

Shading... Internal: [Dropdown]

Buttons: Apply, Close, New Roof, Copy, Delete

Navigation: Single Sheet, Rooms, **Roofs**, Walls, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description: Basement-left

Templates... Room: Default, Internal: Default, Airflow: Default, Tstat: Default, Constr: Default

Wall... Tag: Wall - 2, Construct: [Dropdown], Length: 22, Height: 8, U-factor: 0.1220, Tilt: 0 deg, Direction: 270 deg, Grnd reflect multiplier: 1, Pct wall area to underfloor plenum: [ ] %

Openings...  Wall area: 0 % Type: [Dropdown],  Length: 0, U-factor: 0, Sh. Coef: 0, Height: 0, Quantity: 0, Ld to RA: 0 %

Shading... Internal: [Dropdown], External: [Dropdown]

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Buttons: Apply, Close, New Wall, Copy Wall, Delete Wall, New Opening, Copy Opening, Delete Opening

Navigation: Single Sheet, Rooms, Roofs, **Walls**, Int Loads, Airflows, Partn/Floors



Alternative 1

Room description: Basement-left

Templates...

Room: Default People... Activity: None Density: 0 People

Internal: Default Schedule: Base Util - Lodging

Airflow: Default Sensible: 250 Btu/h Latent: 250 Btu/h

Tstat: Default Workstations... Density: 1 workstation/person

Constr: Default

Lights... Type: Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type:

Heat gain: 0 W/sq ft Schedule: Base Util - Lodging

Miscellaneous loads...

Misc Load 1 Tag: Misc Load 1 Type: None

Energy: 0 W/sq ft Schedule: Base Util - Lodging

Energy meter: None Data Center Equipment: No

Buttons: Single Sheet Rooms Roofs Walls **Int Loads** Airflows Partn/Floors

Alternative 1

Room description: Basement-left

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...

Room: Default Main supply... Cooling: To be calculated Heating: To be calculated

Internal: Default Auxiliary supply... Cooling: To be calculated Heating: To be calculated

Airflow: Default Ventilation... Method: Sum of Outdoor Air

Tstat: Default Type: None

Constr: Default Cooling: 0 cfm Heating: 0 cfm

Schedule: Available (100%) Std 62.1-2004-2010... Clg Ez: Custom Htg Ez: Custom Er: Default based on system typ

DCV Min OA Intake: None

Room exhaust... Rate: 0 air changes/hr Schedule: Available (100%)

VAV control... Clg VAV min: % Clg Airflow Htg VAV max: % Clg Airflow Schedule: Available (100%) Type: Default

ARAE = All room air exhausted

Buttons: Single Sheet Rooms Roofs Walls Int Loads **Airflows** Partn/Floors

Alternative 1

Room description Basement-left

Templates...

Partition...

Room Default  
Internal Default  
Airflow Default  
Tstat Default  
Constr Default

Partition - 1  
Partition - 2  
Partition - 3  
Partition - top

Tag Partition - 1  
Length 10 ft  
Height 2 ft  
Constr 1" Wood Frame  
U-factor 0.2145 Btu/h-ft<sup>2</sup>-F  
Adj room <<No adjacent room>>

Adjacent space temperature...  
Method Ground  
Cooling °F  
Heating °F

Floor...

Floor - 1

Tag Floor - 1  
External temperature...  
 Exposed  Slab on grade  
Method Hourly OADB  
Cooling °F  
Heating °F

Constr 2" HW Concrete  
Area 100 ft<sup>2</sup>  
Perim 0 ft  
U-factor 0.6507 Btu/h-ft<sup>2</sup>-F  
F-factor 0 Btu/hr-ft<sup>2</sup>-F  
Adj room <<No adjacent room>>

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description Basement-left

Templates...

Partition...

Room Default  
Internal Default  
Airflow Default  
Tstat Default  
Constr Default

Partition - 1  
Partition - 2  
Partition - 3  
Partition - top

Tag Partition - 2  
Length 10 ft  
Height 2 ft  
Constr 1" Wood Frame  
U-factor 0.2145 Btu/h-ft<sup>2</sup>-F  
Adj room <<No adjacent room>>

Adjacent space temperature...  
Method Ground  
Cooling °F  
Heating °F

Floor...

Floor - 1

Tag Floor - 1  
External temperature...  
 Exposed  Slab on grade  
Method Hourly OADB  
Cooling °F  
Heating °F

Constr 2" HW Concrete  
Area 100 ft<sup>2</sup>  
Perim 0 ft  
U-factor 0.6507 Btu/h-ft<sup>2</sup>-F  
F-factor 0 Btu/hr-ft<sup>2</sup>-F  
Adj room <<No adjacent room>>

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description Basement-left

Templates... Partition...

Room Default Partition - 1 Tag Partition - 3 Adjacent space temperature... New Partition

Internal Default Partition - 2 Length 10 ft Method Ground Copy Part

Airflow Default Partition - 3 Height 2 ft Cooling 0 °F Delete Part

Tstat Default Constr 1" Wood Frame Heating 0 °F

Constr Default U-factor 0.214E Btu/h-ft²·°F

Adj room <<No adjacent room>>

Floor... Floor - 1 Tag Floor - 1 External temperature... New Floor

Exposed Slab on grade Method Hourly OADB Copy Floor

Constr 2" HW Concrete Cooling 0 °F Delete Floor

Area 100 ft² U-factor 0.6507 Btu/h-ft²·°F Heating 0 °F

Perim 0 ft F-factor 0 Btu/hr-ft·°F

Adj room <<No adjacent room>>

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

Alternative 1

Room description Basement-left

Templates... Partition...

Room Default Partition - 1 Tag Partition - top Adjacent space temperature... New Partition

Internal Default Partition - 2 Length 10 ft Method Adjacent Room Copy Part

Airflow Default Partition - 3 Height 10 ft Cooling 0 °F Delete Part

Tstat Default Constr 1" Wood Frame Heating 0 °F

Constr Default U-factor 0.214E Btu/h-ft²·°F

Adj room Kitchen

Floor... Floor - 1 Tag Floor - 1 External temperature... New Floor

Exposed Slab on grade Method Hourly OADB Copy Floor

Constr 2" HW Concrete Cooling 0 °F Delete Floor

Area 100 ft² U-factor 0.6507 Btu/h-ft²·°F Heating 0 °F

Perim 0 ft F-factor 0 Btu/hr-ft·°F

Adj room <<No adjacent room>>

Single Sheet Rooms Roofs Walls Int Loads Airflows Partn/Floors

## A.2.9 Basement-Right

Create Rooms - Single Worksheet

Alternative 1

Room description: Basement-right

Templates...

Room: Default | Floor...: 10 ft | Length: 10 ft | Width: 10 ft

Internal: Default | Roof...: 0 ft | Roof...: 0 ft

Airflow: Default

Tstat: Default

Constr: Default

Wall...  Equals floor

Description	Length (ft)	Height (ft)	Direction	% Glass or Qty	Length (ft)	Height (ft)	Window
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>
	0	8	0	0	0	0	<input checked="" type="checkbox"/>

Internal loads...

People: 4 | People

Lighting: 0 | W/sq ft

Misc loads: 0 | W/sq ft

Airflows...

Cooling vent: 0 | cfm

Heating vent: 0 | cfm

Cooling VAV min: | % Clg Airflow

Heating VAV max: | % Clg Airflow

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Create Rooms - Rooms

Alternative 1

Room description: Basement-right

Templates...

Room: Default | Size...: Length: 10 ft | Width: 10 ft

Internal: Default | Height...: Floor to floor: 3 ft | Plenum: 1 ft

Airflow: Default | Above ground: -3 ft

Tstat: Default | Duplicate...: Floor multiplier: 1 | Rooms per zone: 1

Constr: Default

Room mass/avg time lag: Time delay based on actual ma-

Slab construction type: 6" LW Concrete

Room type: Unconditioned

Acoustic ceiling resistance: 1.786 hr-ft<sup>2</sup>-°F/Btu

Carpeted

Design...

Cooling dry bulb: 75 °F

Heating dry bulb: 70 °F

Relative humidity: 50 %

Thermostat...

Cooling driftpoint: 81 °F

Heating driftpoint: 64 °F

Cooling schedule: None

Heating schedule: None

Sensor Locations...

Thermostat: None

CO2 sensor: None

Humidity...

Moisture capacitance: Medium

Humidistat location: None

Single Sheet | Rooms | Roofs | Walls | Int Loads | Airflows | Partn/Floors

Alternative 1 Apply

Room description Basement-right Close

Templates... Roof...

Room	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid gray; padding: 2px;">Roof - 2</span>	Construct	<span style="border: 1px solid gray; padding: 2px;"></span>	<span style="border: 1px solid gray; padding: 2px;">New Roof</span>
Internal	<span style="border: 1px solid gray; padding: 2px;">Default</span>		<input type="radio"/> Equals floor	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.15749</span>		<span style="border: 1px solid gray; padding: 2px;">Copy</span>
Airflow	<span style="border: 1px solid gray; padding: 2px;">Default</span>		<input checked="" type="radio"/> Length	<span style="border: 1px solid gray; padding: 2px;">52</span>	Pitch	<span style="border: 1px solid gray; padding: 2px;">-60</span> deg	<span style="border: 1px solid gray; padding: 2px;">Delete</span>
Tstat	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Width	<span style="border: 1px solid gray; padding: 2px;">35</span>	Direction	<span style="border: 1px solid gray; padding: 2px;">0</span> deg	
Constr	<span style="border: 1px solid gray; padding: 2px;">Default</span>						

Skylight...

<input type="checkbox"/> Roof area	<span style="border: 1px solid gray; padding: 2px;">0</span> %	Type	<span style="border: 1px solid gray; padding: 2px;"></span>
<input type="checkbox"/> Length	<span style="border: 1px solid gray; padding: 2px;">0</span>	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.95</span>
Width	<span style="border: 1px solid gray; padding: 2px;">0</span>	Sh. Coef	<span style="border: 1px solid gray; padding: 2px;">0.95</span>
Quantity	<span style="border: 1px solid gray; padding: 2px;">1</span>	Ld to RA	<span style="border: 1px solid gray; padding: 2px;">0</span> %

Shading...

Internal

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors

Alternative 1 Apply

Room description Basement-right Close

Templates... Wall...

Room	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Tag	<span style="border: 1px solid gray; padding: 2px;">Wall - 2</span>	Construct	<span style="border: 1px solid gray; padding: 2px;"></span>	<span style="border: 1px solid gray; padding: 2px;">New Wall</span>
Internal	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Length	<span style="border: 1px solid gray; padding: 2px;">22</span>	U-factor	<span style="border: 1px solid gray; padding: 2px;">0.1220</span>	<span style="border: 1px solid gray; padding: 2px;">Copy Wall</span>
Airflow	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Height	<span style="border: 1px solid gray; padding: 2px;">8</span>	Tilt	<span style="border: 1px solid gray; padding: 2px;">0</span> deg	<span style="border: 1px solid gray; padding: 2px;">Delete Wall</span>
Tstat	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Grnd reflect multiplier	<span style="border: 1px solid gray; padding: 2px;">1</span>	Direction	<span style="border: 1px solid gray; padding: 2px;">270</span> deg	
Constr	<span style="border: 1px solid gray; padding: 2px;">Default</span>		Pct wall area to underfloor plenum	<span style="border: 1px solid gray; padding: 2px;"></span> %			

Openings...

	Tag	<span style="border: 1px solid gray; padding: 2px;"></span>	<input type="radio"/> Window	<input type="radio"/> Door		<span style="border: 1px solid gray; padding: 2px;">New Opening</span>
	<input type="checkbox"/> Wall area	<span style="border: 1px solid gray; padding: 2px;">0</span> %	Type	<span style="border: 1px solid gray; padding: 2px;"></span>		<span style="border: 1px solid gray; padding: 2px;">Copy Opening</span>
	<input type="checkbox"/> Length	<span style="border: 1px solid gray; padding: 2px;">0</span>	Height	<span style="border: 1px solid gray; padding: 2px;">0</span>	Quantity	<span style="border: 1px solid gray; padding: 2px;">0</span>
	U-factor	<span style="border: 1px solid gray; padding: 2px;">0</span>	Sh. Coef	<span style="border: 1px solid gray; padding: 2px;">0</span>	Ld to RA	<span style="border: 1px solid gray; padding: 2px;">0</span> %

Shading...

Internal

External

Note: Internal shading overwrites the u-factor and shading coefficient of the window.

Single Sheet
Rooms
Roofs
Walls
Int Loads
Airflows
Partn/Floors

Alternative 1

Room description: Basement-right

Templates...

Room: Default People... Activity: None Density: 4 People

Internal: Default Schedule: Base Util - Lodging

Airflow: Default Sensible: 250 Btu/h Latent: 250 Btu/h

Tstat: Default Workstations... Density: 1 workstation/person

Constr: Default

Lights... Type: Fluorescent, hung below ceiling, 100% load to space

ASHRAE Space/Area Type:

Heat gain: 0 W/sq ft Schedule: Base Util - Lodging

Miscellaneous loads...

Misc Load 1 Tag: Misc Load 1 Type: None

Energy: 0 W/sq ft Schedule: Base Util - Lodging

Energy meter: None Data Center Equipment: No

Buttons: Apply, Close, New Load, Copy, Delete

Navigation: Single Sheet, Rooms, Roofs, Walls, **Int Loads**, Airflows, Partn/Floors

Alternative 1

Room description: Basement-right

Adjacent air transfer from room: <<No adjacent air trans>>

Templates...

Main supply... Cooling: To be calculated Heating: To be calculated

Auxiliary supply... Cooling: To be calculated Heating: To be calculated

Airflow: Default

Tstat: Default

Constr: Default

Ventilation... Method: Sum of Outdoor Air

Type: None

Cooling: 0 cfm Heating: 0 cfm

Schedule: Available (100%)

Infiltration... Type: Pressurized, Tight Const.

Cooling: 0.7 air changes/hr Heating: 0.7 air changes/hr

Schedule: Available (100%)

Std 62.1-2004-2010... Clg Ez: Custom Htg Ez: Custom Er: Default based on system typ

DCV Min OA Intake: None

Room exhaust... Rate: 0 air changes/hr

Schedule: Available (100%)

VAV control... Clg VAV min: % Clg Airflow Htg VAV max: % Clg Airflow

Schedule: Available (100%)

Type: Default

ARAe = All room air exhausted

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, **Airflows**, Partn/Floors

Alternative 1

Room description Basement-right

Apply

Close

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition - 1

Partition - 2

Partition - 3

Partition - top

Tag Partition - 1

Length 10 ft

Height 2 ft

Constr 1" Wood Frame

U-factor 0.214E Btu/h-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

Adjacent space temperature...

Method Ground

Cooling  °F

Heating  °F

New Partition

Copy Part

Delete Part

Floor...

Floor - 1

Tag Floor - 1

External temperature...

Method Hourly OADB

Cooling  °F

Heating  °F

Constr 2" HW Concrete

Area 100 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F

F-factor 0 Btu/hr-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

New Floor

Copy Floor

Delete Floor

Single Sheet

Rooms

Roofs

Walls

Int Loads

Airflows

Partn/Floors

Alternative 1

Room description Basement-right

Apply

Close

Templates...

Room Default

Internal Default

Airflow Default

Tstat Default

Constr Default

Partition...

Partition - 1

Partition - 2

Partition - 3

Partition - top

Tag Partition - 2

Length 10 ft

Height 2 ft

Constr 1" Wood Frame

U-factor 0.214E Btu/h-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

Adjacent space temperature...

Method Ground

Cooling  °F

Heating  °F

New Partition

Copy Part

Delete Part

Floor...

Floor - 1

Tag Floor - 1

External temperature...

Method Hourly OADB

Cooling  °F

Heating  °F

Constr 2" HW Concrete

Area 100 ft<sup>2</sup>

Perim 0 ft

U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F

F-factor 0 Btu/hr-ft<sup>2</sup>-°F

Adj room <<No adjacent room>>

New Floor

Copy Floor

Delete Floor

Single Sheet

Rooms

Roofs

Walls

Int Loads

Airflows

Partn/Floors

Alternative 1

Room description Basement-right

Templates...

Room Default  
Internal Default  
Airflow Default  
Tstat Default  
Constr Default

Partition...

Partition - 1  
Partition - 2  
Partition - 3  
Partition - top

Tag Partition - 3  
Length 10 ft  
Height 2 ft  
Constr 1" Wood Frame  
U-factor 0.2145 Btu/h-ft<sup>2</sup>-°F  
Adj room <<No adjacent room>>

Adjacent space temperature...  
Method Ground  
Cooling °F  
Heating °F

Floor...

Floor - 1

Tag Floor - 1  
External temperature...  
 Exposed  Slab on grade  
Method Hourly OADB  
Cooling °F  
Heating °F

Constr 2" HW Concrete  
Area 100 ft<sup>2</sup> U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F  
Perim 0 ft F-factor 0 Btu/hr-ft<sup>2</sup>-°F  
Adj room <<No adjacent room>>

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors

Alternative 1

Room description Basement-right

Templates...

Room Default  
Internal Default  
Airflow Default  
Tstat Default  
Constr Default

Partition...

Partition - 1  
Partition - 2  
Partition - 3  
Partition - top

Tag Partition - top  
Length 10 ft  
Height 10 ft  
Constr 1" Wood Frame  
U-factor 0.2145 Btu/h-ft<sup>2</sup>-°F  
Adj room Lounge

Adjacent space temperature...  
Method Adjacent Room  
Cooling °F  
Heating °F

Floor...

Floor - 1

Tag Floor - 1  
External temperature...  
 Exposed  Slab on grade  
Method Hourly OADB  
Cooling °F  
Heating °F



Constr 2" HW Concrete  
Area 100 ft<sup>2</sup> U-factor 0.6507 Btu/h-ft<sup>2</sup>-°F  
Perim 0 ft F-factor 0 Btu/hr-ft<sup>2</sup>-°F  
Adj room <<No adjacent room>>

Buttons: Apply, Close, New Partition, Copy Part, Delete Part, New Floor, Copy Floor, Delete Floor

Navigation: Single Sheet, Rooms, Roofs, Walls, Int Loads, Airflows, Partn/Floors



## A.3 Systems



**Create Systems - Dedicated Ventilation**

Alternative 1  
 System description: **GSHP** Water Source Heat Pump  
 Configuration: **None** Control method: **Fixed Setpoints**

Apply  
Close

**Cooling/Heating Design Setpoints**

Cooling supply air dry bulb [ ] °F  
 Heating supply air dry bulb [ ] °F  
 Cooling supply air dew point [ ] °F

**Cooling/Heating Setpoint Limits**

Supply air dry bulb high limit [ ] °F  
 Supply air dry bulb low limit [ ] °F  
 Cooling SA dew point high limit [ ] °F  
 Cooling SA dew point low limit [ ] °F

**Dedicated Ventilation Schedules**

Cooling coil: **Available (100%)**  
 Heating coil: **Available (100%)**  
 Optional ventilation fan: **Available (100%)**

**Dedicated Ventilation Locations**

Deck: **Return/Outdoor Deck**  
 Level: **System**

Selection Options **Dedicated OA** Temp/Humidity Fans Coils Schematic

**Create Systems - Design Temperatures**

Alternative 1  
 System description: **GSHP** Water Source Heat Pump

Apply  
Close

**Design Air Temperature**

Cooling supply Max [ ] °F  
 Min [ ] °F  
 Leaving cooling coil Max [ ] °F  
 Min [ ] °F  
 Heating supply Max [ ] °F  
 Min [ ] °F  
 Supply duct temperature difference [ 0 ] °F

**Direct/Indirect Dehumidification Methods (System Simulation only)**

Type: **None**  
 Maximum room relative humidity [ ] %  
 Main cooling coil minimum allowable leaving (when throttling a chilled water coil downward during dehumidification or "wild coil" mode) [ ] °F

**Variable Fan Speed for capacity control (System Simulation only)**

Number of fan speeds: **None**  
 Percent airflow at low speed [ ] %  
 Percent airflow at medium speed [ ] %

**Humidification**

Design humidity ratio difference [ ] gr/lb  
 Minimum room relative humidity [ ] %

Selection Options **Dedicated OA** **Temp/Humidity** Fans Coils Schematic

Create Systems - Fan Overrides

Alternative 1

System description: **GSHP** Water Source Heat Pump

Fan cycling schedule: Cycle with heating loads only

Apply

Close

Overrides...  
90.1 Static Adjustments (0)

	Type	Static Pressure (in. wg)	Full Load Energy Rate	Full Load Energy Rate Units	Schedule
Primary	Hydronic in heat pump fan	0.5	0.000237	kW/Cfm	Available (100%)
Secondary	None	0	0	kW	Available (100%)
Return	None	0	0	kW	Available (100%)
System exhaust	None	0	0	kW	Available (100%)
Room exhaust	None	0	0	kW	Available (100%)
Optional vent	None	0	0	kW	Available (100%)
Auxiliary	None	0	0	kW	Available (100%)

Selection Options Dedicated OA Temp/Humidity **Fans** Coils Schematic

Create Systems - Heating and Cooling Coil Overrides

Alternative 1

System description: **GSHP** Water Source Heat Pump

Apply

Close

Capacity Overrides

	Capacity	Capacity Units	Schedule
Main cooling	100	% of Design Capacity by adjusting airflow	Available (100%)
Auxiliary cooling		% of Design Cooling Capacity	Available (100%)
Main heating	100	% of Design Capacity	Available (100%)
Auxiliary heating		% of Design Capacity	Available (100%)
Preheat	100	% of Design Capacity	Available (100%)
Reheat	100	% of Design Capacity	Available (100%)
Humidification	100	% of Design Capacity	Available (100%)

Warning: The fields marked in red require other entries for a correct simulation. Contact C.D.S. Support at 608-787-3926 for a detailed explanation.


Diversity

People: 100 %


Lights: 100 %

Misc loads: 100 %



Selection Options Dedicated OA Temp/Humidity Fans **Coils** Schematic



## A.4 Assign Rooms to Systems



## A.5 Plants



**Create Plants**

Heating Equipment - Alternative 1

Heating plant: Heating plant - 002

Equipment tag: Boiler - 001

Category: Boiler

Equipment type: Oil Fired Steam Boiler

Capacity: 0 Mbh

Energy rate: 83.3 Percent efficient

Thermal Storage

Type: None

Capacity: 0 ton-hr

Schedule: Storage

Controls

Equipment schedule: Available (100%)

Demand limiting priority: 0

Hot Water Pump

Type: None

Full load consumption: 0 ft water

Configuration    Cooling Equipment    **Heating Equipment**    Base Utility / Misc. Accessory

Buttons: Apply, Close, New Equip, Copy Equip, Delete Equip

**Create Plants**

Alternative 1

Miscellaneous accessories

Plant	Equipment tag	Type	Energy	Schedule
All	None	None	0 kW	Off (0%)

Type: None

Description:

Plant: Heating plant - 002

Equipment tag: All

Energy: 0 kW

Schedule: Off (0%)

Base utility

Plant	Type	Hourly demand	Schedule
Heating plant - 002	Domestic Hot ...	0 gal	Hot Water - Lodging

Type: Domestic Hot Water Load

Description: Domestic Hot Water Load

Plant: Heating plant - 002

Hourly demand: 0 gal


Schedule: Hot Water - Lodging

Demand limiting priority:

Configuration    Cooling Equipment    Heating Equipment    **Base Utility / Misc. Accessory**

Buttons: Apply, Close, New Misc, Copy Misc, Delete Misc, New Utility, Copy Utility, Delete Utility

## A.6 Assign Systems to Plants





# **Appendix B**

## **Trace Manual**

## B.1 Room Definition

Overview of Create Rooms

Page 1 of 1

### Overview of Create Rooms

[Overview of Rooms, Zones, and Systems](#)

#### Create Rooms tabs:

[Single Sheet tab](#)

[Rooms tab](#)

[Roofs tab](#)

[Walls tab](#)

[Int Loads tab](#)

[Airflows tab](#)

[Partn/Floors tab](#)

TRACE performs cooling and heating load calculations for each individual room, so a "room" is the smallest space for which you can calculate loads. A room can be a single office surrounded by walls or can be the perimeter portion of a large open-plan office area. In other areas of the program, you have the option of grouping rooms into zones and/or systems for higher level design calculations (i.e. design airflows, coil capacities, design temperatures, etc.).

When creating rooms, you essentially "assign" to it all of the components that contribute to or affect its cooling and heating loads. These load components include, but are not limited to:

- Size and mass of room
- Room design thermostat settings
- Size, construction, and direction of external walls and roofs
- Size, properties, and direction of external windows and skylights
- Internal loads, such as people, lights, and miscellaneous equipment
- Infiltration
- Ventilation requirements
- Partition walls and exposed or slab-on-grade floors

The Create Rooms screen is comprised of seven tabs. The first tab, named Single Sheet, is intended to allow you to enter the basic information about a room on a single screen. It also contains most of the information you might find on typical building blueprints. You may be able to use this tab only (along with the Templates) to enter room information for the majority of the rooms in your project. The remaining tabs can be used to enter more detailed information about the rooms. These tabs are simply a means of viewing the same information that you enter on the Single Sheet tab, plus a few more details.

The top area of the Create Rooms screen, displaying the [Room Description](#) and the [Templates](#), remains in view for all of the tabs. This allows you to select Templates from any of the tabs or to switch between rooms by using the Room Description drop-down list.

## B.2 Partition Definition

### Create Rooms - Partn/Floors

#### Overview of Create Rooms

On this tab, you can "assign" partition walls, exposed floors, and slab-on-grade floors to each room.

A **partition** is a wall that is not exposed to the outdoor environment, but affects the cooling or heating load on the room because of a "significant" temperature difference between the two rooms it separates. (It is not necessary to model a partition if there is not a significant thermal difference between the spaces adjacent to it, since partition loads are strictly based on conduction.)

An **exposed floor** is very similar to a partition wall, and may or may not be exposed to the outdoor environment. It affects the cooling or heating load on the room because of a "significant" temperature difference between the two rooms it separates.

A **slab-on-grade** is used to account for heating losses through the actual floor slab to the outdoor environment. Slab-on-grade losses are calculated for heating design calculations only.

### Field Explanations

#### Room Description

Templates	Partition	Adjacent space temperature
Room	Tag	Method
Internal	Length	Cooling
Airflow	Height	Heating
Tstat	Constr	
Constr	U-factor	
	Adj room	
	Floor	External temperature
	Tag	Method
	Slab-On-Grade	Cooling
	Perimeter (length)	Heating
	Loss coeff	
	Exposed Floor	
	Constr	
	Area	
	U-factor	
	Adj room	

## **Appendix C**

### **Blower Door Test Reports for Lawrence and Morris House from 2010**

## C.1 Morris House

### BUILDING LEAKAGE TEST COMPARISON

COZY HOME PERFORMANCE, LLC  
 74 Lyman Road  
 Northampton, MA 01060  
 Phone: 413.320.7611

Test #1	Test #2
Test File: Morris Hall Pre	Test File: Morris Hall Post
Date of Test: 12.28.10	Date of Test:
Customer: Smith College Morris Hall - Post Test Contact: Todd Holland Northampton, MA 01063	Customer:

#### Test Results

	Test #1	Test #2	Change	Percent
1. Airflow at 50 Pascals:	25525 CFM 7.12 ACH	13936 CFM 3.89 ACH	-11589 CFM -3.23 ACH	-45.4 % -45.4 %
2. CFM50 per ft2 Floor Area	1.10 CFM/ft2	0.60 CFM/ft2	-0.50 CFM/ft2	-45.4 %
3. Leakage Areas:				
Canadian EqLA @ 10 Pa:	3041.5 in2	1766.1 in2	-1275.4 in2	-41.9 %
LBL ELA @ 4 Pa:	1754.8 in2	1055.3 in2	-699.5 in2	-39.9 %
4. Minneapolis Leakage Ratio: (CFM50 per ft2 Surface Area)	0.94	0.51	-0.43	-45.4 %

#### Infiltration Estimates

1. Estimated Annual Average Infiltration Rate:	2245.3 CFM 0.63 ACH	1350.3 CFM 0.38 ACH	-895.0 CFM -0.25 ACH	-39.9 % -39.9 %
2. Estimated Design Infiltration Rate:				
Winter:	3265.2 CFM 0.91 ACH	1963.7 CFM 0.55 ACH	-1301.5 CFM -0.36 ACH	-39.9 % -39.9 %
Summer:	1846.5 CFM 0.52 ACH	1110.5 CFM 0.31 ACH	-736.0 CFM -0.21 ACH	-39.9 % -39.9 %

#### Cost Estimates

- Estimated Costs of Air Leakage for Heating:
- Estimated Costs of Air Leakage for Cooling:

## C.2 Lawrence House

### BUILDING LEAKAGE TEST COMPARISON

COZY HOME PERFORMANCE, LLC  
 74 Lyman Road  
 Northampton, MA 01060  
 Phone: 413.320.7611

Test #1	Test #2
Test File: Lawrence Hall Pre Test	Test File: Lawrence Hall Post Test
Date of Test: 12/28/10	Date of Test:
Customer: Smith College Lawrence Hall - Post Test Contact: Todd Holland Northampton, MA 01063	Customer:

Test Results	Test #1	Test #2	Change	Percent
1. Airflow at 50 Pascals:	21458 CFM 5.99 ACH	12604 CFM 3.52 ACH	-8854 CFM -2.47 ACH	-41.3 % -41.3 %
2. CFM50 per ft2 Floor Area	0.92 CFM/ft2	0.54 CFM/ft2	-0.38 CFM/ft2	-41.3 %
3. Leakage Areas:				
Canadian EqLA @ 10 Pa:	2579.9 in2	1479.6 in2	-1100.3 in2	-42.6 %
LBL ELA @ 4 Pa:	1496.1 in2	846.4 in2	-649.7 in2	-43.4 %
4. Minneapolis Leakage Ratio: (CFM50 per ft2 Surface Area)	0.79	0.47	-0.33	-41.3 %

Infiltration Estimates	Test #1	Test #2	Change	Percent
1. Estimated Annual Average Infiltration Rate:	1914.2 CFM 0.53 ACH	1083.0 CFM 0.30 ACH	-831.3 CFM -0.23 ACH	-43.4 % -43.4 %
2. Estimated Design Infiltration Rate:				
Winter:	2783.7 CFM 0.78 ACH	1574.9 CFM 0.44 ACH	-1208.9 CFM -0.34 ACH	-43.4 % -43.4 %
Summer:	1574.2 CFM 0.44 ACH	890.6 CFM 0.25 ACH	-683.6 CFM -0.19 ACH	-43.4 % -43.4 %

Cost Estimates
1. Estimated Costs of Air Leakage for Heating:
2. Estimated Costs of Air Leakage for Cooling:

# Appendix D

## Heat Pump Sizing Spreadsheet

Geothermal System Parameters			
	SI		IP
L	182.88	m	600 ft
rho_w	1000	kg/m3	
v_w	0.234044295	m/s	
V_w	0.00012618	m3/s	2 gpm
m_dot	0.12618000	kg/s	
r_pi	0.0131	m	
d_p	0.03175	m	1.25 in
r_po	0.015875	m	0.625 in
d_b	0.1524	m	6 in
r_b	0.0762	m	3 in
u_w	0.001307	Ns/m2	
A_p	0.000539129	m2	
Re_current	6898.892381		
Re_medium	8638.167828		
Re_deep	9473.065294		
T_in	4	C	277.15 K
T_out	14	C	
T_avg	9	C	
delT	6	C	
Depth per Bore	182.88	m	600 ft
T_ground	15	C	59 F
c_p	4180	J/kgK	
k_grount	1.73	m-°C/W	
k_p	0.46	m-°C/W	
k_ground	3	m-°C/W	
R_bore	0.138	m-°C/W	0.1922 h-ft-°F/Btu
R_conv	0.010009745	m-°C/W	
R_pipe	0.015625708	m-°C/W	
R_grount	0.088046459	m-°C/W	
R_6h	0.05	m-°C/W	
R_1m	0.088	m-°C/W	
R_10y	0.095	m-°C/W	
Calculated Variables			
m_dot_current	0.459330144	kg/s	
m_dot_medium	0.383421053	kg/s	
m_dot_deep	0.346889952	kg/s	
Current			
V_total	0.00045933	m3/s	7.280554 gpm
V_well	0.00015311	m3/s	2.426851 gpm
v_well	0.283995349	m/s	
Medium			
V_total	0.0003834211	m3/s	6.077367 gpm
V_well	0.000191711	m3/s	3.038683 gpm
v_well	0.355593239	m/s	
Deep			
V_total	0.0003468900	m3/s	5.498335 gpm
V_well	0.000173445	m3/s	2.749167 gpm
v_well	0.321713482	m/s	
Conversion			
gpm to m3/s	0.0006309		

HP Sizing (Geothermal only)			
HP_1 (Building)		HP_1	
		93 W	
		0.026444094 ton	
HP_2 (Main)		HP_2	
Q Annual heating	229198.4 kbtu/yr	11661.70492 W	
	39791.39 btu/hr		
	39.79139 kbtu/hr		
	11.6617 kW		
COP	3		
C factor btu/hr to ton	12000		
q_h	19200 W	2133.333333 W/well	
q_m	17283 W	6400 W	
q_yr	11661.7 W	0.61 ton/well	
HP_3 (Geothermal)		HP_3	
f	0.03503	1.026717795 W	
del_P	8136.93 Pa	0.000291942 ton	
Total Pump Power		6401.026718 W	
# of Wells (fixed delT)			
L_total	441.6 m	1448.818898 ft	
# of Wells	3		

### HP Sizing (Medium)

HP_1 (Building)		HP_1	
		93 W	
		0.026444094 ton	
HP_2 (Main)		HP_2	
Q Annual heating	189780 kbtu/yr	9656.081192 W	
	32947.91667 btu/hr		
	32.94791667 kbtu/hr		
	9.656081192 kW	Percentage Drop (%)	17.2
COP	3		
C factor btu/hr to ton	12000		
q_h	16027 W	1780.777778 W/well	
q_m	14543 W	5342.333333 W all wells	
q_yr	9656.081192 W	0.51 ton/well	

HP_3 (Geothermal)		HP_3	
f	0.035030442	1.026717795 W	
del_P	8136.929744 Pa	0.000291942 ton	
Total Pump Power		5343.360051 W	

# of Wells (fixed delT)		
L_total	368.621 m	1209.386483 ft
# of Wells	3	

Attic (Method 1 average)		
U	0.15749 R	6.349609499
Adding 6/7 of R42	36 U	0.027777778
Final U	0.023612969 U	42.3496095

Attic (Method 2 R42 in series)		
Original U	0.15749 IP	= R (IP)
Insulation R	42 IP	6.34961
New U	0.181299524 IP	*parallel
	0.02068269 IP	*series



### HP Sizing (Deep)

HP_1 (Building)		HP_1	
		93 W	
		0.026444094 ton	

HP_2 (Main)		HP_2	
Q Annual heating	163052 kbtu/yr	8296.150018 W	
	28307.63889 btu/hr		
	28.30763889 kbtu/hr		
	8.296150018 kW	Percentage Drop (%)	28.9
COP	3		
C factor btu/hr to ton	12000		
q_h	14500 W	2416.666667 W/well	
q_m	12391 W	4833.333333 W all wells	
q_yr	8296.150018 W	0.69 ton/well	

HP_3 (Geothermal)		HP_3	
f	0.035030442	1.026717795 W	
del_P	8136.929744 Pa	0.000291942 ton	
Total Pump Power		4834.360051 W	

# of Wells (fixed delT)		
L_total	333.5 m	1094.160105 ft
# of Wells	2	

Wall			
Original U	0.12207 IP	= R (IP)	8.192021
False Wall R	21 IP		
New U	0.034255936 IP		

## **Appendix E**

# **Field House Energy Consumption Reports**

Reports follow the order: geothermal only, medium, deep; annual, monthly, hourly.

## E.1 Geothermal Only

### ENERGY CONSUMPTION SUMMARY

By ACADEMIC

	Elect Cons. (kWh)	Oil Cons. (kBtu)	Water Cons. (1000 gals)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
<b>Alternative 1</b>						
<b>Primary heating</b>						
Primary heating		262,590		91.7 %	262,590	276,410
Other Htg Accessories	4,180		4	5.0 %	14,265	42,799
<b>Heating Subtotal</b>	<b>4,180</b>	<b>262,590</b>	<b>4</b>	<b>96.6 %</b>	<b>276,855</b>	<b>319,210</b>
<b>Primary cooling</b>						
Cooling Compressor				0.0 %	0	0
Tower/Cond Fans				0.0 %	0	0
Condenser Pump				0.0 %	0	0
Other Clg Accessories				0.0 %	0	0
<b>Cooling Subtotal...</b>				<b>0.0 %</b>	<b>0</b>	<b>0</b>
<b>Auxiliary</b>						
Supply Fans	2,825			3.4 %	9,643	28,931
Pumps				0.0 %	0	0
Stand-alone Base Utilities				0.0 %	0	0
<b>Aux Subtotal...</b>	<b>2,825</b>			<b>3.4 %</b>	<b>9,643</b>	<b>28,931</b>
<b>Lighting</b>						
Lighting				0.0 %	0	0
<b>Receptacle</b>						
Receptacles				0.0 %	0	0
<b>Cogeneration</b>						
Cogeneration				0.0 %	0	0
<b>Totals</b>						
<b>Totals**</b>	<b>7,005</b>	<b>262,590</b>	<b>4</b>	<b>100.0 %</b>	<b>286,498</b>	<b>348,141</b>

\* Note: Resource Utilization factors are included in the Total Source Energy value.

\*\* Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

Project Name:  
Dataset Name: 44\_Current.TRC

TRACE® 700 v6.3.3 calculated at 01:02 AM on 04/09/2019  
Alternative - 1 Energy Consumption Summary report page 1

## MONTHLY ENERGY CONSUMPTION

By ACADEMIC

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
<b>Alternative: 1      Field House</b>													
<b>Electric</b>													
On-Pk Cons. (kWh)	922	892	904	610	269	326	500	345	163	326	842	907	7,005
On-Pk Demand (kW)	1	1	1	1	1	1	2	1	1	1	1	1	2
<b>Oil</b>													
Cons. (therms)	464	530	436	220	86	0	0	0	5	99	346	440	2,626
<b>Water</b>													
Cons. (1000gal)	1	1	1	0	0	0	0	0	0	0	1	1	4
<b>Energy Consumption</b>													
Building	42,250 Btu/(ft2-year)												
Source	51,341 Btu/(ft2-year)												
<b>Environmental Impact Analysis</b>													
	CO2 8,399 lbm/year												
	SO2 26 gm/year												
	NOX 7 gm/year												
Floor Area	6,781 ft2												

ONLY

## BUILDING COOL HEAT DEMAND

By ACADEMIC

January Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	23.3	21.1	-80,851	0.0	-66,144	0.0	-62,314	0.0	-62,098	0.0	-62,848	0.0
2	22.4	20.2	-76,403	0.0	-66,310	0.0	-64,256	0.0	-64,122	0.0	-64,945	0.0
3	22.1	20.0	-76,106	0.0	-67,705	0.0	-65,916	0.0	-65,800	0.0	-66,631	0.0
4	22.3	20.2	-76,480	0.0	-68,483	0.0	-66,806	0.0	-66,703	0.0	-67,539	0.0
5	23.0	20.7	-76,648	0.0	-68,858	0.0	-67,268	0.0	-67,176	0.0	-68,016	0.0
6	24.1	22.0	-76,482	0.0	-68,048	0.0	-66,542	0.0	-66,461	0.0	-67,306	0.0
7	25.5	23.4	-75,822	0.0	-66,585	0.0	-65,151	0.0	-65,079	0.0	-65,927	0.0
8	27.2	25.1	-74,272	0.0	-64,890	0.0	-63,717	0.0	-63,653	0.0	-64,104	0.0
9	29.1	26.9	-61,878	0.0	-58,467	0.0	-58,178	0.0	-58,123	0.0	-57,968	0.0
10	31.0	28.5	-46,005	0.0	-49,910	0.0	-51,314	0.0	-51,274	0.0	-51,536	0.0
11	32.9	30.0	-26,854	0.0	-44,102	0.0	-41,673	0.0	-41,639	0.0	-42,128	0.0
12	34.6	31.3	-3,288	0.0	-36,817	0.0	-35,502	0.0	-35,470	0.0	-36,333	0.0
13	36.0	32.1	0	0.0	-33,200	0.0	-32,015	0.0	-31,985	0.0	-32,894	0.0
14	37.1	32.7	0	0.0	-30,168	0.0	-28,995	0.0	-28,967	0.0	-29,898	0.0
15	37.8	33.1	0	0.0	-29,637	0.0	-28,470	0.0	-28,443	0.0	-29,379	0.0
16	38.1	33.1	0	0.0	-30,984	0.0	-30,247	0.0	-30,223	0.0	-30,741	0.0
17	37.7	33.2	-23,943	0.0	-36,770	0.0	-35,860	0.0	-35,837	0.0	-36,541	0.0
18	36.8	32.9	-38,422	0.0	-43,065	0.0	-42,157	0.0	-42,137	0.0	-42,868	0.0
19	35.3	31.9	-50,449	0.0	-49,282	0.0	-48,219	0.0	-48,202	0.0	-49,117	0.0
20	33.4	30.4	-54,722	0.0	-52,011	0.0	-50,852	0.0	-50,838	0.0	-51,887	0.0
21	31.2	28.3	-58,279	0.0	-50,394	0.0	-52,181	0.0	-52,165	0.0	-50,162	0.0
22	28.9	26.3	-61,264	0.0	-57,408	0.0	-54,292	0.0	-54,276	0.0	-57,291	0.0
23	26.7	24.2	-63,896	0.0	-58,573	0.0	-57,376	0.0	-57,361	0.0	-58,432	0.0
24	24.8	22.5	-66,058	0.0	-61,276	0.0	-60,270	0.0	-60,257	0.0	-61,142	0.0
February Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	15.6	13.2	-79,861	0.0	-80,230	0.0	-77,528	0.0	-77,312	0.0	-77,744	0.0
2	14.1	11.9	-82,435	0.0	-80,429	0.0	-78,750	0.0	-78,627	0.0	-79,185	0.0
3	13.1	10.9	-84,053	0.0	-80,983	0.0	-79,673	0.0	-79,583	0.0	-80,185	0.0
4	12.8	10.7	-85,318	0.0	-81,583	0.0	-80,471	0.0	-80,395	0.0	-80,991	0.0
5	13.1	11.2	-86,144	0.0	-82,425	0.0	-81,415	0.0	-81,353	0.0	-81,910	0.0
6	14.1	12.2	-86,416	0.0	-82,090	0.0	-81,124	0.0	-81,071	0.0	-81,643	0.0
7	15.6	13.8	-86,076	0.0	-81,162	0.0	-80,243	0.0	-80,198	0.0	-80,777	0.0
8	17.6	15.9	-81,681	0.0	-78,725	0.0	-78,029	0.0	-77,987	0.0	-78,373	0.0
9	19.9	18.1	-70,989	0.0	-73,050	0.0	-72,537	0.0	-72,472	0.0	-72,504	0.0
10	22.4	20.4	-52,163	0.0	-62,677	0.0	-62,051	0.0	-62,007	0.0	-62,304	0.0
11	24.9	22.1	-37,112	0.0	-54,869	0.0	-53,675	0.0	-53,635	0.0	-54,546	0.0
12	27.2	23.8	-26,775	0.0	-51,680	0.0	-51,047	0.0	-51,020	0.0	-51,430	0.0
13	29.2	25.6	-16,316	0.0	-48,569	0.0	-47,517	0.0	-47,493	0.0	-48,362	0.0
14	30.7	26.8	-4,523	0.0	-46,038	0.0	-44,925	0.0	-44,902	0.0	-45,850	0.0
15	31.7	27.4	-6,703	0.0	-44,462	0.0	-43,348	0.0	-43,328	0.0	-44,291	0.0
16	32.0	27.7	-21,545	0.0	-44,337	0.0	-43,649	0.0	-43,631	0.0	-44,179	0.0
17	31.7	27.3	-26,898	0.0	-47,938	0.0	-47,077	0.0	-47,060	0.0	-47,793	0.0
18	30.7	26.7	-42,141	0.0	-53,617	0.0	-52,749	0.0	-52,731	0.0	-53,456	0.0
19	29.2	25.8	-56,753	0.0	-59,768	0.0	-58,757	0.0	-58,739	0.0	-59,607	0.0
20	27.2	24.1	-67,115	0.0	-64,767	0.0	-63,760	0.0	-63,744	0.0	-64,624	0.0
21	24.9	22.0	-71,897	0.0	-67,620	0.0	-66,622	0.0	-66,608	0.0	-67,493	0.0
22	22.4	19.6	-75,448	0.0	-70,473	0.0	-69,489	0.0	-69,475	0.0	-70,361	0.0
23	19.9	17.3	-77,555	0.0	-72,383	0.0	-71,412	0.0	-71,401	0.0	-72,285	0.0
24	17.6	15.1	-79,548	0.0	-76,145	0.0	-75,501	0.0	-75,490	0.0	-76,092	0.0

Project Name:  
Dataset Name: 44\_Current.TRC

TRACE® 700 v6.3.3 calculated at 12:19 PM on 04/12/2019  
Alternative - 1 System Load Profiles report Page 1 of 6

## E.2 Geothermal + Medium

### ENERGY CONSUMPTION SUMMARY

By ACADEMIC

	Elect Cons. (kWh)	Oil Cons. (kBtu)	Water Cons. (1000 gals)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
<b>Alternative 1</b>						
<b>Primary heating</b>						
Primary heating		214,901		90.6 %	214,901	226,212
Other Htg Accessories	3,549		3	5.1 %	12,112	36,340
<b>Heating Subtotal</b>	<b>3,549</b>	<b>214,901</b>	<b>3</b>	<b>95.7 %</b>	<b>227,013</b>	<b>262,551</b>
<b>Primary cooling</b>						
Cooling Compressor				0.0 %	0	0
Tower/Cond Fans				0.0 %	0	0
Condenser Pump				0.0 %	0	0
Other Clg Accessories				0.0 %	0	0
<b>Cooling Subtotal...</b>				<b>0.0 %</b>	<b>0</b>	<b>0</b>
<b>Auxiliary</b>						
Supply Fans	2,992			4.3 %	10,212	30,638
Pumps				0.0 %	0	0
Stand-alone Base Utilities				0.0 %	0	0
<b>Aux Subtotal....</b>	<b>2,992</b>			<b>4.3 %</b>	<b>10,212</b>	<b>30,638</b>
<b>Lighting</b>						
Lighting				0.0 %	0	0
<b>Receptacle</b>						
Receptacles				0.0 %	0	0
<b>Cogeneration</b>						
Cogeneration				0.0 %	0	0
<b>Totals</b>						
<b>Totals**</b>	<b>6,541</b>	<b>214,901</b>	<b>3</b>	<b>100.0 %</b>	<b>237,225</b>	<b>293,190</b>

\* Note: Resource Utilization factors are included in the Total Source Energy value .

\*\* Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

Project Name:  
Dataset Name: 1014\_Duplicate\_updated.trc

TRACE® 700 v6.3.3 calculated at 08:57 AM on 04/09/2019  
Alternative - 1 Energy Consumption Summary report page 1

## MONTHLY ENERGY CONSUMPTION

By ACADEMIC

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
<b>Alternative: 1      Field House</b>													
<b>Electric</b>													
On-Pk Cons. (kWh)	868	853	846	458	173	379	545	418	171	198	779	852	6,541
On-Pk Demand (kW)	1	1	1	1	2	2	2	2	2	1	1	1	2
<b>Oil</b>													
Cons. (therms)	395	446	368	163	51	0	0	0	0	62	288	376	2,149
<b>Water</b>													
Cons. (1000gal)	1	0	1	0	0	0	0	0	0	0	1	1	3
<b>Energy Consumption</b>													
Building	34,984 Btu/(ft2-year)												
Source	43,237 Btu/(ft2-year)												
<b>Floor Area</b>													
	6,781 ft2												
<b>Environmental Impact Analysis</b>													
	CO2 7,843 lbm/year												
	SO2 25 gm/year												
	NOX 7 gm/year												

ONLY

## BUILDING COOL HEAT DEMAND

By ACADEMIC

January Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	23.3	21.1	-66,471	0.0	-57,286	0.0	-53,819	0.0	-53,560	0.0	-54,305	0.0
2	22.4	20.2	-63,151	0.0	-57,147	0.0	-55,551	0.0	-55,385	0.0	-55,988	0.0
3	22.1	20.0	-63,163	0.0	-57,877	0.0	-56,533	0.0	-56,447	0.0	-57,011	0.0
4	22.3	20.2	-63,697	0.0	-58,477	0.0	-57,226	0.0	-57,133	0.0	-57,742	0.0
5	23.0	20.7	-64,012	0.0	-58,826	0.0	-57,892	0.0	-57,593	0.0	-58,222	0.0
6	24.1	22.0	-64,004	0.0	-58,544	0.0	-57,477	0.0	-57,396	0.0	-58,038	0.0
7	25.5	23.4	-63,553	0.0	-57,842	0.0	-56,803	0.0	-56,730	0.0	-57,382	0.0
8	27.2	25.1	-62,295	0.0	-56,822	0.0	-56,024	0.0	-55,957	0.0	-56,382	0.0
9	29.1	26.9	-55,540	0.0	-51,977	0.0	-51,381	0.0	-51,283	0.0	-51,328	0.0
10	31.0	28.5	-38,749	0.0	-43,427	0.0	-42,754	0.0	-42,689	0.0	-42,990	0.0
11	32.9	30.0	-19,035	0.0	-34,609	0.0	-33,841	0.0	-33,796	0.0	-34,308	0.0
12	34.6	31.3	0	0.0	-29,663	0.0	-28,522	0.0	-28,480	0.0	-29,381	0.0
13	36.0	32.1	0	0.0	-26,550	0.0	-25,344	0.0	-25,300	0.0	-26,254	0.0
14	37.1	32.7	0	0.0	-23,795	0.0	-22,426	0.0	-22,377	0.0	-23,503	0.0
15	37.8	33.1	0	0.0	-23,451	0.0	-22,159	0.0	-22,116	0.0	-23,155	0.0
16	38.1	33.1	0	0.0	-24,925	0.0	-24,229	0.0	-24,194	0.0	-24,843	0.0
17	37.7	33.2	0	0.0	-30,751	0.0	-29,794	0.0	-29,758	0.0	-30,485	0.0
18	36.8	32.9	-23,742	0.0	-37,050	0.0	-36,094	0.0	-36,063	0.0	-36,831	0.0
19	35.3	31.9	-43,406	0.0	-41,876	0.0	-40,754	0.0	-40,720	0.0	-41,637	0.0
20	33.4	30.4	-48,581	0.0	-43,324	0.0	-42,217	0.0	-42,185	0.0	-43,095	0.0
21	31.2	28.3	-51,833	0.0	-45,519	0.0	-44,425	0.0	-44,396	0.0	-45,308	0.0
22	28.9	26.3	-54,439	0.0	-47,978	0.0	-46,902	0.0	-46,874	0.0	-47,785	0.0
23	26.7	24.2	-55,869	0.0	-50,603	0.0	-49,543	0.0	-49,519	0.0	-50,427	0.0
24	24.8	22.5	-57,264	0.0	-53,050	0.0	-52,007	0.0	-51,984	0.0	-52,892	0.0
February Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	15.6	13.2	-65,771	0.0	-67,106	0.0	-64,504	0.0	-64,294	0.0	-64,714	0.0
2	14.1	11.9	-69,019	0.0	-66,968	0.0	-65,488	0.0	-65,377	0.0	-65,897	0.0
3	13.1	10.9	-70,771	0.0	-67,379	0.0	-66,224	0.0	-66,145	0.0	-66,697	0.0
4	12.8	10.7	-72,040	0.0	-67,947	0.0	-66,907	0.0	-66,842	0.0	-67,408	0.0
5	13.1	11.2	-72,870	0.0	-68,804	0.0	-67,819	0.0	-67,761	0.0	-68,337	0.0
6	14.1	12.2	-73,194	0.0	-68,585	0.0	-67,644	0.0	-67,593	0.0	-68,176	0.0
7	15.6	13.8	-72,980	0.0	-67,854	0.0	-66,954	0.0	-66,909	0.0	-67,498	0.0
8	17.6	15.9	-68,765	0.0	-65,960	0.0	-65,028	0.0	-64,988	0.0	-65,356	0.0
9	19.9	18.1	-60,268	0.0	-61,431	0.0	-61,222	0.0	-61,189	0.0	-61,185	0.0
10	22.4	20.4	-43,591	0.0	-55,624	0.0	-55,023	0.0	-54,974	0.0	-55,272	0.0
11	24.9	22.1	-28,497	0.0	-46,644	0.0	-45,949	0.0	-45,918	0.0	-46,399	0.0
12	27.2	23.8	-14,098	0.0	-42,107	0.0	-40,847	0.0	-40,821	0.0	-41,649	0.0
13	29.2	25.6	0	0.0	-39,647	0.0	-40,409	0.0	-40,390	0.0	-41,367	0.0
14	30.7	26.8	0	0.0	-38,001	0.0	-37,191	0.0	-37,173	0.0	-38,143	0.0
15	31.7	27.4	0	0.0	-36,781	0.0	-35,770	0.0	-35,753	0.0	-36,727	0.0
16	32.0	27.7	0	0.0	-36,780	0.0	-35,772	0.0	-35,757	0.0	-36,708	0.0
17	31.7	27.3	-9,710	0.0	-40,370	0.0	-39,577	0.0	-39,564	0.0	-40,304	0.0
18	30.7	26.7	-39,711	0.0	-46,267	0.0	-45,479	0.0	-45,465	0.0	-46,200	0.0
19	29.2	25.8	-51,606	0.0	-52,397	0.0	-51,471	0.0	-51,458	0.0	-52,339	0.0
20	27.2	24.1	-57,930	0.0	-56,257	0.0	-55,713	0.0	-55,706	0.0	-56,225	0.0
21	24.9	22.0	-60,933	0.0	-58,022	0.0	-57,371	0.0	-57,363	0.0	-57,986	0.0
22	22.4	19.6	-63,428	0.0	-59,788	0.0	-59,137	0.0	-59,130	0.0	-59,754	0.0
23	19.9	17.3	-65,526	0.0	-60,963	0.0	-60,326	0.0	-60,320	0.0	-60,933	0.0
24	17.6	15.1	-67,255	0.0	-63,220	0.0	-62,586	0.0	-62,580	0.0	-63,192	0.0

Project Name: 1014\_Duplicate\_updated.rc  
 Dataset Name: 1014\_Duplicate\_updated.rc

TRACE® 700 v6.3.3 calculated at 08:57 AM on 04/09/2019  
 Alternative - 1 System Load Profiles report Page 1 of 6



## E.3 Geothermal + Deep

### ENERGY CONSUMPTION SUMMARY

By ACADEMIC

	Elect Cons. (kWh)	Oil Cons. (kBtu)	Water Cons. (1000 gals)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
<b>Alternative 1</b>						
<b>Primary heating</b>						
Primary heating		181,734		89.2 %	181,734	191.2
Other Htg Accessories	3,189		3	5.3 %	10,886	32.6
<b>Heating Subtotal</b>	<b>3,189</b>	<b>181,734</b>	<b>3</b>	<b>94.5 %</b>	<b>192,620</b>	<b>223.9</b>
<b>Primary cooling</b>						
Cooling Compressor				0.0 %	0	
Tower/Cond Fans	222			0.4 %	759	2.2
Condenser Pump				0.0 %	0	
Other Clg Accessories				0.0 %	0	
<b>Cooling Subtotal....</b>	<b>222</b>			<b>0.4 %</b>	<b>759</b>	<b>2.2</b>
<b>Auxiliary</b>						
Supply Fans	3,058			5.1 %	10,436	31.3
Pumps				0.0 %	0	
Stand-alone Base Utilities				0.0 %	0	
<b>Aux Subtotal....</b>	<b>3,058</b>			<b>5.1 %</b>	<b>10,436</b>	<b>31.3</b>
<b>Lighting</b>						
Lighting				0.0 %	0	
<b>Receptacle</b>						
Receptacles				0.0 %	0	
<b>Cogeneration</b>						
Cogeneration				0.0 %	0	
<b>Totals</b>						
<b>Totals**</b>	<b>6,470</b>	<b>181,734</b>	<b>3</b>	<b>100.0 %</b>	<b>203,815</b>	<b>257,5</b>

\* Note: Resource Utilization factors are included in the Total Source Energy value.

\*\* Note: This report can display a maximum of 7 utilities. If additional utilities are used, they will be included in the total.

Project Name:  
Dataset Name: 1014\_DUPLICATE.TRC

TRACE® 700 v6.3.3 calculated at 06:57 AM on 04/15/201  
Alternative - 1 Energy Consumption Summary report page

## MONTHLY ENERGY CONSUMPTION

By ACADEMIC

----- Monthly Energy Consumption -----

Utility	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Total
<b>Alternative: 1      Field House</b>													
<b>Electric</b>													
On-Pk Cons. (kWh)	837	818	815	381	135	468	638	493	210	185	663	827	6,470
On-Pk Demand (kW)	1	1	1	2	1	2	2	2	2	1	1	1	2
<b>Oil</b>													
Cons. (therms)	339	380	315	124	37	0	0	0	0	52	243	326	1,817
<b>Water</b>													
Cons. (1000gal)	0	0	0	0	0	0	0	0	0	0	0	0	3
<b>Energy Consumption</b>													
Building	30,057 Btu/(ft2-year)												
Source	37,981 Btu/(ft2-year)												
<b>Floor Area</b>													
	6,781 ft2												
<b>Environmental Impact Analysis</b>													
	CO2 7,757 lbm/year												
	SO2 24 gm/year												
	NOX 7 gm/year												

ONLY

## BUILDING COOL HEAT DEMAND

By ACADEMIC

January Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	23.3	21.1	-57,816	0.0	-50,042	0.0	-47,390	0.0	-47,262	0.0	-47,981	0.0
2	22.4	20.2	-51,257	0.0	-50,337	0.0	-48,937	0.0	-48,857	0.0	-48,620	0.0
3	22.1	20.0	-51,434	0.0	-51,423	0.0	-50,184	0.0	-50,109	0.0	-50,875	0.0
4	22.3	20.2	-52,250	0.0	-52,094	0.0	-50,904	0.0	-50,837	0.0	-51,608	0.0
5	23.0	20.7	-52,629	0.0	-52,339	0.0	-51,193	0.0	-51,133	0.0	-51,910	0.0
6	24.1	22.0	-52,624	0.0	-51,873	0.0	-50,766	0.0	-50,712	0.0	-51,495	0.0
7	25.5	23.4	-52,115	0.0	-50,934	0.0	-49,864	0.0	-49,816	0.0	-50,604	0.0
8	27.2	25.1	-50,548	0.0	-49,463	0.0	-48,810	0.0	-48,768	0.0	-49,176	0.0
9	29.1	26.9	-40,224	0.0	-43,770	0.0	-43,708	0.0	-43,708	0.0	-43,515	0.0
10	31.0	28.5	-25,927	0.0	-36,759	0.0	-36,329	0.0	-36,295	0.0	-36,564	0.0
11	32.9	30.0	0	0.0	-27,657	0.0	-27,051	0.0	-27,020	0.0	-27,476	0.0
12	34.6	31.3	0	0.0	-22,391	0.0	-21,480	0.0	-21,460	0.0	-22,256	0.0
13	36.0	32.1	0	0.0	-19,514	0.0	-18,542	0.0	-18,526	0.0	-19,406	0.0
14	37.1	32.7	0	0.0	-17,269	0.0	-16,156	0.0	-16,147	0.0	-17,156	0.0
15	37.8	33.1	0	0.0	-17,520	0.0	-16,575	0.0	-16,568	0.0	-17,444	0.0
16	38.1	33.1	0	0.0	-19,426	0.0	-19,057	0.0	-19,053	0.0	-19,371	0.0
17	37.7	33.2	0	0.0	-25,386	0.0	-24,714	0.0	-24,708	0.0	-25,331	0.0
18	36.8	32.9	0	0.0	-31,797	0.0	-31,086	0.0	-31,079	0.0	-31,740	0.0
19	35.3	31.9	0	0.0	-37,469	0.0	-36,583	0.0	-36,574	0.0	-37,410	0.0
20	33.4	30.4	-35,531	0.0	-39,668	0.0	-38,688	0.0	-38,677	0.0	-39,605	0.0
21	31.2	28.3	-41,105	0.0	-38,830	0.0	-40,528	0.0	-40,517	0.0	-38,759	0.0
22	28.9	26.3	-43,008	0.0	-43,370	0.0	-40,052	0.0	-40,045	0.0	-43,320	0.0
23	26.7	24.2	-44,819	0.0	-44,383	0.0	-43,809	0.0	-43,803	0.0	-44,334	0.0
24	24.8	22.5	-46,334	0.0	-46,458	0.0	-45,621	0.0	-45,615	0.0	-46,414	0.0
February Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	15.6	13.2	-58,195	0.0	-59,281	0.0	-57,610	0.0	-57,482	0.0	-57,950	0.0
2	14.1	11.9	-59,404	0.0	-59,982	0.0	-58,823	0.0	-58,742	0.0	-59,285	0.0
3	13.1	10.9	-60,433	0.0	-60,847	0.0	-59,824	0.0	-59,755	0.0	-60,320	0.0
4	12.8	10.7	-61,341	0.0	-61,582	0.0	-60,621	0.0	-60,560	0.0	-61,137	0.0
5	13.1	11.2	-61,946	0.0	-62,249	0.0	-61,328	0.0	-61,274	0.0	-61,859	0.0
6	14.1	12.2	-62,146	0.0	-62,140	0.0	-61,252	0.0	-61,203	0.0	-61,795	0.0
7	15.6	13.8	-61,900	0.0	-61,558	0.0	-60,701	0.0	-60,658	0.0	-61,256	0.0
8	17.6	15.9	-57,581	0.0	-58,967	0.0	-58,374	0.0	-58,335	0.0	-58,703	0.0
9	19.9	18.1	-44,545	0.0	-52,854	0.0	-52,569	0.0	-52,516	0.0	-52,491	0.0
10	22.4	20.4	-28,378	0.0	-43,419	0.0	-42,952	0.0	-42,917	0.0	-43,189	0.0
11	24.9	22.1	0	0.0	-36,960	0.0	-36,365	0.0	-36,341	0.0	-36,795	0.0
12	27.2	23.8	0	0.0	-32,831	0.0	-31,909	0.0	-31,888	0.0	-32,689	0.0
13	29.2	25.6	0	0.0	-29,892	0.0	-28,951	0.0	-28,934	0.0	-29,778	0.0
14	30.7	26.8	0	0.0	-27,978	0.0	-27,044	0.0	-27,031	0.0	-27,885	0.0
15	31.7	27.4	0	0.0	-27,064	0.0	-26,137	0.0	-26,127	0.0	-26,985	0.0
16	32.0	27.7	0	0.0	-27,198	0.0	-26,672	0.0	-26,663	0.0	-27,130	0.0
17	31.7	27.3	0	0.0	-30,672	0.0	-29,966	0.0	-29,958	0.0	-30,615	0.0
18	30.7	26.7	0	0.0	-37,860	0.0	-37,141	0.0	-37,134	0.0	-37,806	0.0
19	29.2	25.8	-29,526	0.0	-43,792	0.0	-42,924	0.0	-42,915	0.0	-43,730	0.0
20	27.2	24.1	-47,205	0.0	-48,033	0.0	-47,166	0.0	-47,158	0.0	-47,978	0.0
21	24.9	22.0	-51,347	0.0	-50,086	0.0	-49,217	0.0	-49,209	0.0	-50,032	0.0
22	22.4	19.6	-53,819	0.0	-52,060	0.0	-51,196	0.0	-51,189	0.0	-52,011	0.0
23	19.9	17.3	-55,983	0.0	-53,836	0.0	-52,977	0.0	-52,970	0.0	-53,792	0.0
24	17.6	15.1	-57,214	0.0	-56,543	0.0	-55,745	0.0	-55,739	0.0	-56,518	0.0

Project Name: 1014\_DUPLICATE.TRG  
 Dataset Name: 1014\_DUPLICATE.TRG

TRACE® 700 v6.3.3 calculated at 06:57 AM on 04/15/2019  
 Alternative - 1 System Load Profiles report Page 1 of 6

**Appendix F**

**Geothermal System Review Spreadsheet**

	Skidmore	Saltstate	Princeton	Richard Stockton	Dunbar High School	Oberlin College	University of Ontario Institute of Techn	The Motherhouse	Bates College
Location	Saratoga Springs, NY	Muncie, Indiana	Princeton, New Jersey	Atlantic County, New Jersey	washington DC	Ohio	Oshawa, Ontario, Canada	Michigan	
Orientation	Vertical	Vertical	Vertical	Vertical	Vertical	Vertical	Vertical	Vertical	
Thermal Conductivity	2.3 Btu/hr-ft-F				1.5 Btu/hr-F-ft				
Working Fluid (GHX)		water		water	35% Propylene glycol	water + glycol	glycol solution		
Mass Flow of working fluid GHX				water, 4000 gallons/minute					
Borehole Diameter		4.5 in.		4 in.	5.5-6 in	24			
Number of Boreholes		471	3800 200	400	362	18	384	232	
Notes on # boreholes	Currently 231 - after 2017 - 471 total	3800-4100							
Working fluid in HP		Refrigerant 134a							
Borehole Spacing		15 ft apart		at least 15 ft	Roughly 20 ft				
Diameter of HDPE		1-1/4 inch		1 1/2 inch	1.25 in HDPE				
Number of Heat Pumps		4 Heat Pump Chillers (2500 tons each)		119 roof mounted HPs on buildings					
Depth of boreholes (ft)	400	400/500 ft	400	425		500 300	700		
Notes on depth	between 400-500								
Soil Type	moist coarse sand and fine grain clay			aquifer, confining bed	Grey Clay, Blue clay				
Rock Type	dolomite						impermeable limestone at 50 - 200 m		
% total heating/cooling provided by geother	40% of total heating and air-conditioning 88% when fully engaged, meeting 80% of colleges needs after 240 more boreholes installed								
ODP for Heating	3.8			3.4					
ODP for Cooling	2.9								
Cost		70000000		4,004,594	\$127,906,735		15500000		
Notes on cost									
Average Subsurface temp					59 F				
Miles of piping		1000 mi		64 mi	68 mi				
Heating/Cooling Load				5.91 MW; cooling: 106 feet/ton bentonite	Their cooling load much higher 2,837,907 kBtu		cooling: 7,000 kW.		
Ground Used Thermal conductivity					Thermal bentonite 1.2 BTU/hr-F-ft				
Tools used for drilling		Mud rotary			Mud rotary then air rotary after 147 ft				
Surface area for boreholes				4 acres	8.5 acres		7,000 m2 = 1.7 acres		
Company used		MEP Associates Jim Lowe (765) 285-2805 jlowe@osu.edu	Architects - Studio Ma, Developer - American Campus Communities, Engineering - Daehler Engineering		DGS construction;				
Faculty							Ken Bright		
Current/Previous Infrastructure		Heat plant, 4 coal fired boilers, 3 natural gas fired boilers - chilled water plant, 5 electrical centrifugal chillers, replace coal boilers with geothermal	Electricity - (115 MW Gas Turbine Generator as cogeneration (certified to run on biodiesel); Steam Generation - (1) Heat Recovery Boiler - (2) Auxiliary Boilers; Chilled Water Production - (3) Steam-Driven Chillers - (5) Electric Chillers - (1) Thermal Storage Tank.		482 kW photovoltaic array, two 20,000-gallon cisterns, \$0.085 per kWh				50% Purchased Electricity, 9,417 MTCOE; 40% On Campus stationary sources 7,502 MTCOE; plan to convert main steam plant to a biomass cogeneration facility by 2020
Configuration	Decentralized, Each area has a GHX with its own HP distributed to multiple buildings	3 GHX fields as energy hubs feeding centralized hot and chilled water to buildings		One bore field under 4 acre parking lot. Likely Centralized. Reverse Return - Twenty wells are fed from one 4-inch diameter lateral in a 'reverse return' configuration to equalize the pressure drop (and presumably the flow) through each of the 20 wells.	GHX in one bore field under athletic field - unclear about location/configuration of heat pumps		Centralized system; Hydronic		
Building Square footage (gsf)			382,000	350,000	280,000				
Notes on square footage			(also see 323,000)	(or 400,000) out of 440,000 SF					
Scale of GSHHP system									
<b>Summary Statistics</b>									
\$ Cost/well	0	19444.44444	0	10011.485	\$353.334	861111.1111	0	0	#DIV/0!
Notes on cost/well:	\$50/well is rule of thumb, most of that cost is to set up rigging, makes phased approach more expensive, there are several good papers on this, Stanford has a decent model								
Wells/1000 gsf	#DIV/0!	#DIV/0!	0.5235602094	1.142857143	1.292857143	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
\$ Cost/1000 gsf	#DIV/0!	#DIV/0!	0	11441.89714	\$458.810	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!



# Appendix G

## Life Cycle Cost Spreadsheet

Field House Parameters				
	SI		IP	
Gross Area	2066.8488	m <sup>2</sup>	6781	ft <sup>2</sup>
Roof Area	173.9144909	m <sup>2</sup>	1872	ft <sup>2</sup>
Roof length		m	52	ft
Wall length		m	92.125	ft
Wall width		m	36.83	ft
Wall height			8	ft
Total Wall Cavity			4126.56	ft <sup>2</sup>
Raw oil data			1979.5	gallon
Type 2 oil heating value			139400	btu/gallon
Current oil consumption	80870.7	kwh/yr	275942.3	kbtu/yr
Cost per gallon of oil			2.75	\$/gallon
#windows on the first floor	34			

Cost Specifics			
Cost of electricity	0.155	\$/kwh	
Cost per well	46000	\$	
Cost per window	1500	\$	
Cost for sealing (total)	1440	\$	3 people, 2 full days, \$ 30/
Costs for insulation	4.55	\$/ft2	
interest for electricity	0.01		
interest for oil	0.04		
interest for federal fund	0.025		
Geothermal only			
Total Pump	6401.026718	W	
	1.32732E+11	J	
	36869.91389	kWh	
Medium			
Total Pump	5343.360051	W	
	1.108E+11	J	
	30777.75389	kWh	
Deep			
Total Pump	4834.360051	W	
	1.00245E+11	J	
	27845.91389	kWh	


Life Cycle Cost Analysis

	Current	Geothermal	Geothermal + Medium	Geothermal + Deep
<b>Capital Cost</b>				
<b>Installation</b>		\$138,000.00	\$138,000.00	\$92,000.00
<b>Retrofit</b>			\$68,035.20	\$88,251.05
window replacement			\$51,000.00	\$51,000.00
attic insulation/sealing			\$17,035.20	\$17,035.20
envelope insulation				\$18,775.85
envelope sealing				\$1,440.00
<b>Total Capital Cost</b>	\$0.00	\$138,000.00	\$206,035.20	\$180,251.05
<b>Annual Cost</b>				
Oil Purchase	\$5,443.63			
Electricity Purchase		\$5,714.84	\$4,770.55	\$4,316.12
<b>Total Annual Cost</b>	\$5,443.63	\$5,714.84	\$4,770.55	\$4,316.12
<b>Present Worth at Year 0</b>				
Capital Cost -> Present Worth	\$0.00	\$138,000.00	\$206,035.20	\$180,251.05
Annual Cost -> Present Worth	\$94,131.16	\$147,486.79	\$123,116.97	\$111,389.04
Discount Rate for Annual	4.00%	1.00%	1.00%	1.00%
Present Worth Factor for Annual	17.29	25.81	25.81	25.81
<b>Total Present Worth</b>	\$94,131.16	\$285,486.79	\$329,152.17	\$291,640.09
<b>S.F. Cost</b>	\$13.88	\$42.10	\$48.54	\$43.01
<b>Future Worth at Year 30</b>				
Capital Cost -> Future Worth	\$0.00	\$289,464.33	\$432,172.76	\$378,088.75
Discount Rate for Capital	2.50%	2.50%	2.50%	2.50%
Future Worth Factor for Capital	2.10	2.10	2.10	2.10
Annual Cost -> Future Worth	\$305,305.16	\$198,815.74	\$165,964.64	\$150,155.11
Discount Rate for Annual	4.00%	1.00%	1.00%	1.00%
Future Worth Factor for Annual	56.08	34.78	34.78	34.78
<b>Total Future Worth</b>	\$305,305.16	\$488,282.19	\$598,139.51	\$528,245.99
<b>S.F. Cost</b>	\$45.02	\$72.01	\$88.21	\$77.90



**Appendix H**  
**Scanned Notes**

# H.1 Field House Field Investigation Notes



ins fiberglass, no air barrier - no air infiltration  
 16in on center load bear. Mason

have gaps: moving air spider web.

Cross section - well

foundation - basements? 1ft to rodent?  
 brick below grid

no wall cavity added concrete

8-20' wide masonry total wall, concrete or brick

fauces IF IF (4 showers)

shower heads: new

roof: ins bottom (cellulose) no ins space no on top 15' to the rafter full dip  
 make up air (dir in)

## H.2 Building Insulation Cost Estimation


Spray foam - 8000 ft<sup>2</sup>, just attic

sealing - 3 people, 2 full day, \$30/hr = \$1440  
 cost is half labor & half materials  
 + \$1,000 for blower door


w

you can add  
 $\frac{1}{2}(8-4) \frac{1}{2}$

\$15,000 to spray foam a 1400ft<sup>2</sup> house



insulated  
 can not be  
 surface area  
 total 1400  
 $\frac{1}{2} = \frac{1}{2}$



$$\left( (22 \times 8) 2 + (30 \times 8) 2 \right) 2 + (13.6 \times 30) 2 (2)$$

$$(352 + 480) \times 2$$

= ~~2480~~ ft<sup>2</sup> of cavity  
 3296 ft<sup>2</sup>

\$4.55 / ft<sup>2</sup> of surface insulated - sets R-21  
 remember to double for attics

5 inches of insulation  
 we will go to 6"

twice thickness

# **Appendix I**

## **PV System Design Report**

This Appendix presents a design process and framework that could be applied to size a PV array at the Field House. The GSHP design has been updated in this thesis. However, the PV sizing is applicable for this work.

Lily Li  
EGR 388-Assignment 2  
11/13/2017  
Prof. Denise McKahn

## PV System Design Report for Field House

### Summary

This report details the design of a grid-tied PV system, coupled with a geothermal ground source heat pump for the field house. The main components of this PV system include 72 PV modules and a grid-tied inverter. Initial cost of the system is \$30,778.41 and total life cycle cost is \$45,422.06, with a life cycle of 30 years.

The motivation and background of the project is summarized in Introduction. Design Criteria describes the specific design requirements that need to be met during the design. Major equations used for the design, load analysis and component sizing are elaborated in Design Process. A list and detailed descriptions of all system components are included in Component Specification and life cycle cost analysis is estimated in the corresponding section.

### Introduction

In response to the Smith College Sustainability and Climate Action Plan to reduce carbon emission by 2030, a pilot project to examine the feasibility of transforming to geothermal energy for heating is launched at the field house. A single borehole, geothermal ground source heat pump will be installed for heating the field house and a grid-tied PV system is coupled to the heat pump for electricity supply.

This PV system is grid-tied, in order to best resemble the current and future buildings on Smith campus, as most of the buildings on campus is connected to the grid. Field house is an ideal location for a pilot project, because of its small scale, 4000 square feet in footprint, which lowers the price of both the geothermal and the PV system, and the limited amount of human activities happening inside of it, making the heating and electricity load easier to estimate (i.e. less incidental fluctuation) using Etta's building energy model from 2009.

Overall, the field house stands in plain sight, without much shading. Although there is a tree on the south side of the field house that sometimes shades the target roof by a small amount, shading is not taken into consideration during the design process.

### Design Criteria

This section elaborates the design requirements and constraints that must be considered in the design of an adequate system. Overall, these important criteria are 1) the total electricity load for the PV system; 2) the availability of solar insolation for the PV modules; 3) the physical space of the roof that the modules will be mounted on; and 4) economic considerations, for instance, reasonable maintenance fee.

The primary goal of the design is to make sure electricity generated by the PV modules adequately covers the total load required by the geothermal system. To estimate the total load, the coupled system configuration must be understood. A diagram of the geothermal heating system is shown in Figure 1. An entire geothermal heating system consists of a water loop geothermal borehole, a heat pump and a water loop heat distribution. Therefore, the total load for the PV system is the combined electricity inputs:

$$W_{\text{total}} = W_1 + W_2 + W_3 \quad \text{Eqn. 1}$$

in which,  $W_1$  and  $W_2$  are the electricity inputs for water pumps and  $W_3$  is the electricity input for a turbine. Detailed assumptions made to estimate the load will be discussed in Design Process. Final total load is estimated to be 34.5 kWh/day.

The number of PV modules needed for the PV system depends on the annual availability of solar insolation. Based on previous calculations (Appendix A, Table 1.), an annual solar insolation of 1571 kWh/m<sup>2</sup>\*yr is available to Northampton and is used as the available annual solar insolation on the roof of the field house. An annual average daily solar insolation is calculated by dividing 1571 kWh/m<sup>2</sup>\*yr with 365 days/year, which

equals 4.3 kWh/m<sup>2</sup>\*day. Therefore, the peak sun hours, which is the number of hours per day for which an equivalent of 1 kW/m<sup>2</sup> is generated by the modules, equals 4.3 hours/day. The sun hour is crucial to the calculation for PV system output current, which will also be discussed in detail in Design Process. A total of 72 modules, 24 in series for 3 parallel strings, is the final configuration that harness the most of the available solar energy to power the load of 34.5 kWh/day.




Figure 1. System Diagram for the Geothermal Heating System

The physical space available for the PV modules is the south side of the roof of the field house. The total area is calculated by estimating distance on Google Map and trigonometry. The side of the roof is shown in Figure 2. Trigonometry is used, demonstrated in Figure 3, assuming the angle  $\alpha = 40^\circ$ , that gives the width,  $b = 21$  ft. Measured with Google Map, the length  $l = 90$  ft, which gives a total available area  $A = 1890$  ft<sup>2</sup>.



Figure 2. Side Shot of the Roof of Field House




Figure 3. Estimation of the width using Trigonometry

And since the optimal tilt angle  $\beta = 41.4^\circ$  (see Appendix A, Table 1.), is almost the same as the roof angle  $\alpha = 40^\circ$ , and to save the cost for adjustable mounting brackets, the modules will be directly mounted to the roof. Based on calculation, 72 PV modules, 24 in series for 3 parallel strings, is the best configuration. The dimensions of a single panel is 3.9ft by 1.8ft (See specification for Panel RNG-100D in Appendix B). Therefore, the space on the roof is more than sufficient for such a system configuration, with 72 panels adding up to only 1/3 of the surface area, leaving the rest for separation space between the panels.

The entire system consists of PV modules, a inverter and wires, of which the inverter will be replaced once at the 20<sup>th</sup> year and the modules be cleaned every two weeks in the winter season (from November to March) for snow. The cost for the listed two items above is \$15000, and is approximately 33% of the total life cycle cost. This is a reasonable amount that makes the design economically justifiable.

## Design Process

### Load analysis

As analyzed in Design Criteria (Eqn 1.), the total load is the sum of the electricity inputs in a geothermal heating system, written as  $W_{total} = W_1 + W_2 + W_3$ . The following assumptions are made for load calculation:

1. Due to a lack of information on an actual geothermal heat distribution pump, a Taco pump, specific model unknown, that's used in a residential house (Professor McKahn's house) is used to estimate  $W_1$ . A power of 93 W is used as the power per pump. There is a total of 4 pumps for the heat distribution system. Therefore a total of  $93 \text{ W} * 4 = 372 \text{ W}$  is the power of this sub-system.
2. For estimation of  $W_2$ , these assumptions are made:
  - a) Field house has load bearing masonry exterior walls, concrete substructure and wood superstructure. A wall R-value of 5.5 is used based on Etta Grover-Silva's building model, 2009.
  - b) The roof of the field house is asphalt shingles and ceiling is exposed wood, with double wood windows. Based on Etta's model, an attic R-value of 44.5 is used.
  - c) Three different gross area are given from different sources: 6910 ft<sup>2</sup>, 8133 ft<sup>2</sup> and 9758 ft<sup>2</sup>. In this design, the biggest gross area,  $A = 9758 \text{ ft}^2$  is used, which means  $W_2$  is likely to be an overestimation.
  - d) The field house will undergo a retrofit before it is installed with the new system. To find a heat load estimate per square feet, the degree to which this retrofit will go is assumed to be sealing + attic + walls. This gives a heating rate of 30631.15 BTU/ft<sup>2</sup>\*yr, based on Etta's model and 2a) and 2b).
  - e) COP is 3 for the turbine.
3. Also due to a lack of information, the geothermal pump is assumed to be 10 times more powerful than the distribution pump, out of the consideration that a much larger amount of work is required to pump water down to 400-500 ft and back up, in a borehole water loop. Therefore, power for one single pump is  $93 \text{ W} * 10 = 930 \text{ W}$ .
4. Overall, based on operating information from Professor McKahn's residential pump, a total of 1/3 of a day, 8 hours, is assumed as the operating duration per day for all three parts of the geothermal system. However, for convenience, the unit will still be "per day".

Detailed calculation is attached in Appendix C. The final load analysis result is shown in Table 1.

Table 1. Load Analysis Results.

Distribution Load (kWh/day)	Heat Pump Load (kWh/day)	Geothermal Load (kWh/day)	Total Load (kWh/day)
2.9783808	24.0568511	7.445952	34.4811839

### Inverter Selection

Because the load is in AC and the output of the PV module is in DC, an inverter is required in between to convert the voltage signal. A model, Xantrex GT5.0-NA-240/208 UL-05, is selected with the following

specification summary in Table 2 (Detailed specs see Appendix D). This model has a large maximum voltage and current input, to lower the numbers of PV modules needed.

Table 2. Specs Summary of Inverter

Model	Inverter Vmax (V)	Inverter Imax (A)	Inverter Efficiency (%)
Xantrex GT5.0-NA-240/208 UL-05	550 VDC	22 ADC	95.9

### PV Modules Configuration

Two criteria are considered when choosing a PV module: efficiency and cost. This design leaned to favor cost than efficiency and used the RNG-100D model, a 100W Monocrystalline Solar Panel, with an efficiency of only 15.47% (See specification for Panel RNG-100D in Appendix B). To find the best configuration of modules, system voltage and current must be determined. Equation 2 relates sun hours, system voltage and inverter efficiency and total load:

$$I_{sys} = \frac{AC\ Load}{V_{DC,sys} \times Derate\ Factor \times \eta_{inverter} \times peak\ sun\ hours} \quad \text{Eqn. 2}$$

in which AC Load = 34.5 kWh/day, Derate Factor = 0.9,  $\eta_{inverter} = 95.9\%$  and peak sun hours = 4.3 hrs/day. System voltage is varied from 0 V to maximum voltage input  $V_{max}$  of the inverter to find a good configuration of panels that satisfies the condition that 1)  $I_{sc} * \# \text{ Parallel} < I_{max}$  and 2)  $V_{oc} * \# \text{ Series} < V_{max}$ , in which  $\# \text{ Parallel} = I_{sys}/I_{mp}$ ,  $\# \text{ Series} = V_{sys}/V_{mp}$ . A summary of the PV module specifications and sizing result is shown in Table 3.

Table 3. Summary of PV Specification and Configuration Calculation

Annual Solar Insolation (kWh/m <sup>2</sup> *yr)	Sun hours (hrs/day)		
1570.966791	4.304018604		
$I_{mp}$ (A)	$V_{mp}$ (V)	$I_{sc}$ (A)	$V_{oc}$ (V)
5.29	18.9	5.75	22.5
$I_{system}$ (A)	$V_{system}$ (V)	Theoretical $P_{system}$ (W)	Real $P_{system}$ (W)
20.17850936	460	9282.114305	100W * 72 Panels = 7200
# of Panels in parallel	# of Panels in series	# of Panels Total	
3	24	72	
<b>Check:</b>			
$I_{sc} * \# \text{ Parallel} < I_{max}$	$V_{oc} * \# \text{ Series} < V_{max}$		
17.25	540		

And since the number of panels must be an integer, both cells, “# of Panels in Parallel” and “# of Panels in Series” have displayed a rounded down result. Therefore, the real power output of the PV modules is 7200 W rather than 9282 W. Notice that this configuration has passed both current and voltage checks. A detailed wiring diagram will be shown in Component Specification.

### Sizing of the Wires

Assuming the connection between each panel in series is 1 ft and that between each string in parallel is 3 ft, 32 ft for one-way connection between PV module and the indoor inverter and another 32 ft for one-way connection between the inverter and the AC load gives a total length of 209 ft. Applied with a factor of safety of 2, the total wire length is 418 ft.

System current is estimated by multiplying the  $I_{sys}$  with a general factor of safety of 1.25 and with another 1.25 to account for cloud focusing or reflection, to be 31.5 A. The 8 AWG wire is selected, with an ampacity of 40 A and a total of 488 ft, satisfying all requirements listed above.

## Component Specification



The entire system has 72 PV modules, 1 grid-tied inverter and 418 ft long of 8 AWG wire. A summary of component specifications is listed in Table 4. A proposed budget for the PV system is around \$ 40,000-\$50,000, which is the average price for one geothermal borehole, based on the spreadsheet Rison Naness and I have compiled during the Summer of 2017.

Table 4. Component Specifications for a Grid-Tied PV System for Field House

Component	PV Module	Inverter	Wire
Manufacturer and P/N	Renogy RNG-100D	Xantrex GT5.0-NA-240/208 UL-05	Type THHN/THWN-2 building wire
Dimensions	L: 47.3 in W: 21.3 in H: 1.4 in	L: 15.88 in W: 31.4 in H: 5.39 in	Outside Diameter = 0.212 inches Weight = 0.069 lbs/ft
Key Design Specs	$P_{max} = 100 \text{ W}$ $V_{mp} = 18.9 \text{ V}$ $I_{mp} = 5.29 \text{ A}$ $V_{oc} = 22.5 \text{ V}$ $I_{sc} = 5.75 \text{ A}$	Max Input Current = 22 ADC Max Input Voltage = 550 VDC	Max Voltage = 600 V
Nominal Voltage (V)	12	240	240
Quantity	72	1	418 ft
Warranty (years)	25	10	Assumed: 30
Unit Price	\$140	\$3850.41	\$ 0.36/ft

A complete wiring diagram is shown in Figure 4.




Figure 4. Wiring Diagram for a Grid-Tied PV System

### Life Cycle Cost Analysis

The life cycle is assumed to be 30 years, and is justifiable because this is only 5 years more than the warranty of PV module. The replacement cycle for inverter is assumed to be twice the time of the warranty, to

be 20 years. The wire is assumed to have a life of 30 years. Installation fee is \$2.4/W with an extra \$300 of permitting fee. The discount rate is 6%. Salvage rate is assumed to be 20% of the original module cost. Annual maintenance mostly includes removal of snow in the winter (5 month, from November to March), with 4 hours of work every two weeks per month, at a rate of \$25/hour.

Based on these assumptions, initial cost = \$30820.89, total life cycle cost = \$45,464.54. A detailed LCC is attached in Appendix E.

## Appendix A: Array Sizing Report from Assignment 1

### Plane of Array Design for Field House

#### Introduction

In response to the Smith College Sustainability and Climate Action Plan to achieve carbon neutrality by 2030, a geothermal energy based heating/cooling system will be installed, replacing the natural gas boilers. As a pilot project, the smith college field house, 4000 square feet in footprint<sup>1</sup> with a stand-alone system, will be equipped with a single borehole, geothermal heat exchanger to test how the system performs on a small scale. A PV system is designed, utilizing solar energy to cover the electricity usage of the heat pump.

This report presents the parameter calculations and optimization for plane of array of the PV system using an excel sheet model. Final results include ideal and actual monthly average insolation, comparisons of monthly insolation on site between different tilt angles of the plane and an optimal tilt angle that yields a maximum annual solar insolation.

The model utilizes the relationship between  $\overline{H_T}$  and  $\beta$  described in the following equation:

$$\overline{H_T} = \overline{H} \left( 1 - \frac{\overline{H_d}}{\overline{H}} \right) \overline{R_b} + \overline{H_d} \left( \frac{1 + \cos(\beta)}{2} \right) + \overline{H} \rho_g \left( \frac{1 - \cos(\beta)}{2} \right)$$

where  $\overline{H_T}$  is monthly average daily total insolation on a tilted surface,  $\overline{H}$  is horizontal monthly average daily insolation,  $\overline{H_d}$  is the diffuse component of the horizontal monthly average daily insolation,  $\overline{R_b}$  is the direct beam tilt factor,  $\rho_g$  is the ground reflectivity and  $\beta$  is the tilt angle.

Equations that describe the unknown variables above are listed below:

$$\overline{H_d} = (1.391 - 3.56\overline{K_T} + 4.189\overline{K_T}^2 - 2.137\overline{K_T}^3) \times \overline{H} \text{ for } \omega s \leq 81.4^\circ$$

$$\overline{H_d} = (1.311 - 3.022\overline{K_T} + 3.427\overline{K_T}^2 - 1.821\overline{K_T}^3) \times \overline{H} \text{ for } \omega s > 81.4^\circ$$

where  $\omega s$  is hour angle,  $K_T$  is the clearness index,  $K_T = \overline{H}/\overline{H_0}$

$$\overline{R_b} = \frac{\cos(\varphi - \beta) \cos(\delta) \sin(\omega' s) + \frac{\pi}{180} \omega' s \sin(\varphi - \beta) \sin(\delta)}{\cos(\varphi) \cos(\delta) \sin(\omega s) + \frac{\pi}{180} \omega s \sin(\varphi) \sin(\delta)}$$

where  $\varphi$  is the latitude of the site,  $\delta$  is the declination of the earth on a certain day.

#### Design Procedure

This model calculates and optimizes monthly average daily solar insolation  $\overline{H_T}$  and the annual solar energy received by the PV system on the field house roof for any plane with a tilt angle from 0 to 90 degrees. In the excel, columns are designated for the variables mentioned above and rows are designated for the 12 months. Monthly data are calculated for each of the variables by relating which using the equations listed above.

Some assumptions are made for this model:

1.  $\overline{H_T}$  is the insolation of the most representative day of the month, and is assumed to be that of the midday of a month (the 15th).
2. The monthly average solar insolation on a horizontal surface,  $\overline{H}$  (kWh/m<sup>2</sup>\*day), is obtained from the NASA Atmospheric Science Data Center<sup>2</sup>, for Northampton (latitude = 42.3 deg, longitude= -72.6 deg), based on which  $\overline{H_d}$  (kWh/m<sup>2</sup>\*day) is calculated.
3. The surface reflectivity  $\rho_g$  depends on ground conditions in Northampton which is assumed as: from November to April the ground is covered by snow (0.75), from May to August is green grass (0.26), September is dry grass (0.2) and October is dead leaves (0.3).

#### Results and Discussion

Performing an optimization using the Solver module in excel to maximize the annual solar energy production

<sup>1</sup> Etta's spreadsheet, 2009

<sup>2</sup> It is an average of 22 years' monthly daily insolation, from 1983-2005.

at the field house, by altering the variable tilt angle  $\beta$  within the constraint  $0^\circ \leq \beta \leq 90^\circ$ , yields a maximum annual solar production = 1570.966791 kWh/m<sup>2</sup>\*month at an optimal tilt angle of  $\beta = 41.43032396^\circ$ . Corresponding monthly average daily solar insolation and total annual solar energy are listed below:

Table 1. Ideal  $\overline{H}_T$  and maximum annual solar energy collected at Optimal  $\beta$  at Field House

Month	$\overline{H}_T$ (kWh/m <sup>2</sup> *day)	Tilt Angle $\beta =$
January	3.350021437	41.43032396 °
February	4.345347741	
March	4.697309677	Annual Solar Production =
April	4.766856629	1570.966791 kWh/m <sup>2</sup> *yr
May	4.761721426	
June	4.960265786	
July	5.087690991	
August	4.914465915	
September	4.60334629	
October	4.057430634	
November	3.188133155	
December	2.929392112	

To visualize the change of monthly average daily insolation with the change of tilt angle, three angles, the angle of the site roof, horizontal and optimal tilt, are selected and their corresponding solar insolation are calculated using the model and graphed below. Estimated by eye, the rooftop of the field house is at an angle of approximately  $40^\circ$ . Roof angle is very close to the optimal angle ( $41.4^\circ$ ), therefore their insolation curves almost overlap (yellow and black). The horizontal insolation curve, compared with a much bigger tilt angle (both the roof and the optimal angle), is considerably steeper, starting at a lower value in the winter and rising quickly to a higher value in the summer. This is explained by the fact that the sun is less normal to a horizontal plane in the winter and more normal to it in the summer comparing with a tilted plane.




Figure 1. Comparisons between Monthly Average Daily Solar Insolation at Different Angles

However, in reality, it is unlikely to achieve the entire amount of the calculated annual energy production, due to system efficiency limits. To get a more realistic prediction, the three sets of insolation data from the above comparison is multiplied with a 18% efficiency rate and with the area of the south side of the roof of the field house, to get the actual monthly average daily and annual total energy production (listed below). The area is estimated by walking stride length (1m/stride) and trigonometry, to be approximately 40m\*10m = 400 m<sup>2</sup>. At the bottom row, a rate of \$0.2/kWh is multiplied with the annual energy production to get corresponding profits.

Table 2. Actual Monthly Average Daily and Annual Energy Production at Different Angles

Month	Roof Tilt (kWh/day)	Horizontal (kWh/day)	Optimal Tilt (kWh/day)
January	7391.297736	3950.64	7477.247738
February	8684.991176	5382.72	8760.22095
March	10445.84424	8079.84	10484.39515
April	10303.73724	9460.8	10296.41033
May	10708.10935	11427.84	10628.16233
June	10808.62635	12031.2	10714.17422
July	11450.98279	12543.84	11355.72642
August	11035.57994	11182.32	10969.08801
September	9965.075098	8791.2	9943.228018
October	9018.11157	6405.84	9056.185127
November	6816.815202	3952.8	6886.367524
December	6459.355766	3348	6538.403091
Annual (kWh/yr)	113088.5265	96557.04	113109.6089
Profit (\$/yr)	22617.70529	19311.408	22621.92178

### Conclusion

In summary, a model predicting annual solar energy production of PV system of the smith college field house is established to facilitate the sizing of the plane of array. Calculations of ideal and realistic situations are conducted and presented. For the next step, shading factors should be examined and included in the model. Geothermal borehole sizing and modeling should also be conducted.

## Appendix B: Specification for the PV Module

# RNG-100D

## 100W Monocrystalline Solar Panel

### Electrical Data

Maximum Power at STC*	100 W
Optimum Operating Voltage ( $V_{mp}$ )	18.9 V
Optimum Operating Current ( $I_{mp}$ )	5.29 A
Open Circuit Voltage ( $V_{oc}$ )	22.5 V
Short Circuit Voltage ( $I_{sc}$ )	5.75 A
Module Efficiency	15.47%
Maximum System Voltage	600 VDC UL
Maximum Series Fuse Rating	15 A


### Thermal Characteristics

Operating Module Temperature	-40°C to +80°C
Nominal Operating Cell Temperature (NOCT)	47±2°C
Temperature Coefficient of Pmax	-0.44%/°C
Temperature Coefficient of Voc	-0.30%/°C
Temperature Coefficient of Isc	0.04%/°C

### Junction Box

IP Rating	IP 65
Diode Type	HY 10SQ050
Number of Diodes	2 Diode(s)
Output Cables	12 AWG (2.10 ft long)

### Module Diagram



### Mechanical Data

Solar Cell Type	Monocrystalline (4.92 x 4.92 in)
Number of Cells	36 (4 x 9)
Dimensions	47.3 x 21.3 x 1.4in (1202 x 541 x 35mm)
Weight	16.5 lbs (7.5 kg)
Front Glass	Tempered Glass 0.13 in (3.2 mm)
Frame	Anodized Aluminium Alloy
Connectors	MC4 Connectors
Fire Rating	Class C


### MC4 Connectors

Rated Current	30A
Maximum Voltage	1000VDC
Maximum AWG Size Range	10 AWG
Temperature Range	-40°F to 194°F
IP Rating	IP 67

### Certifications



### IV-Curve



\*All specifications and data described in this data sheet are tested under Standard Test Conditions (STC - Irradiance: 1000W/m<sup>2</sup>, Temperature: 25°C, Air Mass: 1.5) and may deviate marginally from actual values. Renogy and any of its affiliates has reserved the right to make any modifications to the information on this data sheet without notice. It is our goal to supply our customers with the most recent information regarding our products. These data sheets can be found in the downloads section of our website, [www.renogy.com](http://www.renogy.com)

## Appendix D: Specification for Inverter

# A

## Specifications

Appendix A contains specifications for the Xantrex Grid Tie Solar Inverter.

The topics in this appendix are organized as follows:

- “Electrical Specifications” on page A-1
- “Output Power Versus Ambient Temperature” on page A-13
- “Environmental Specifications” on page A-13
- “User Display” on page A-13
- “Mechanical Specifications” on page A-14
- “Regulatory Approvals” on page A-14

### Electrical Specifications

#### GT5.0

##### Input

	GT5.0-NA-240/208 UL-05	GT5.0-NA-240/208-POS UL-05
Model number	864-1009-02	864-1011-02
Input voltage, Maximum Power Point range	Certified operating range: 240–550 VDC. (Unit is operable as low as 235 VDC.)	
Absolute maximum array open circuit voltage	600 VDC	
Maximum input current	22.0 ADC (240 V), 20.0 ADC (208 V)	
Maximum array short circuit current	24 ADC	
Reverse polarity protection	Short circuit diode	
Ground fault protection	GF detection, $I_{DIF} > 1 \text{ A}$	

Specifications

**Output**

Nominal output voltage	240 V	208 V
Maximum output power	5000 W	4500 W
Operating range, utility voltage (phase to phase)*	212–263 VAC	184–228 VAC
Operating range, utility voltage (phase to neutral)*	106.1–131.5 VAC	
Nominal output frequency	60 Hz	
Operating range, utility frequency*	59.3–60.5 Hz	
Startup current	0 Aac	
Maximum continuous output current	21 A	22 A
Maximum output fault current	30 A	
Maximum output overcurrent protection	30 A RMS	
Maximum utility backfeed current	0 A	
Total Harmonic Distortion	<3%	
Power factor	>0.99% (at rated power), >0.95% (full power range)	
Utility monitoring	AC voltage, AC frequency, and anti-islanding protection	
Output characteristics	Current source	
Output current waveform	Sine wave	

\*Factory settings can be adjusted with the approval of the utility. This unit is provided with adjustable trip limits and may be aggregated above 30 kW on a single Point of Common Coupling. See “Adjustable Voltage, Frequency, and Reconnection Settings” on page A-12.

**Efficiency**

	240 V	208 V
Maximum peak efficiency	95.9%	95.5%
CEC efficiency	95.5%	95.0%
Night-time tare loss	1 W	



## Appendix E: Life Cycle Cost Analysis

Table 1. Life Cycle Cost for a 30-Year System with PV Modules and One Inverter.

Item	Single Present Worth Year	Uniform Present Worth Year	Cost	Present Worth Factor	Present Worth Amount
<b>Initial Costs</b>					
Solar PV Equipment	0		\$9,240.00	1	\$9,240.00
Installation Cost	0		\$17,580.00	1	\$17,580.00
Inverter	0		\$3,850.41	1	\$3,850.41
Wires	0		\$150.48	1	\$150.48
Total Initial Cost					\$30,820.89
<b>Annual Costs</b>					
Annual Maintenance		30	\$1,000.00	13.76483115	\$13,764.83
<b>Repair &amp; Replacement</b>					
Inverter Replacement	20		\$3,850.41	0.311804727	\$1,200.58
<b>Salvage Value</b>					
Salvage is 20% of Initial Equipment Cost	30		-\$1,848.00	0.174110131	-\$321.76
<b>Total Life Cycle Cost</b>					\$45,464.54

## **Bibliography**

- [1] U.S. Energy Information Administration. New york harbor no. 2 heating oil future contract 1 (dollars per gallon). [https://www.eia.gov/dnav/pet/hist/EER\\_EPD2F\\_PE1\\_Y35NY\\_DPGD.htm](https://www.eia.gov/dnav/pet/hist/EER_EPD2F_PE1_Y35NY_DPGD.htm), 2019.
- [2] Isabella Caitlin Casini. Estimating product composition and thermal dynamics in a continuous feed biomass torrefier. *Theses, Dissertations, and Projects. 1813.*, 2017.
- [3] Andrew D. Chiasson. *Geothermal heat pump and heat engine systems: theory and practice.* ASME Press and John Wiley & Sons, Ltd., 2016.
- [4] Smith College. Sustainability and climate action management plan. 2010.
- [5] Omar Ellabban, Haitham Abu-Rub, and Frede Blaabjerg. Renewable energy resources: Current status, future prospects and their enabling technology. *Renewable and Sustainable Energy Reviews*, 39:748–764.
- [6] Per Eskilson. Thermal analysis of heat extraction boreholes. 1987.
- [7] Ingvar Birgir Fridleifsson and Málfríður Ómarsdóttir. Geothermal energy in developing countries and the mdgs. <https://unu.edu/publications/articles/geothermal-energy-in-developing-countries-and-the-mdgs.html>, 2013.
- [8] Integral Group. Smith college campus energy decarbonization study. 2017.
- [9] Etta Grover-Silva. Cost effective efficiency improvements of building thermal envelopes. *Theses, Dissertations, and Projects. 1512.*, 2010.
- [10] Etta Grover-Silva, D.A. McKahn, and D. Weisbord. Campus assessment of building heating energy consumption - informing the climate action plan. In *ASME 2010 International Mechanical Engineering Congress & Exposition.* American Society of Mechanical Engineers, 2010.
- [11] Göran Hellström. Ground heat storage : thermal analyses of duct storage systems. 1991.
- [12] Stephen P. Kavanaugh and Kevin D. Rafferty. *Geothermal heating and cooling: design of ground-source heat pump systems.* W. Stephen Comstock, 2014.
- [13] Wenxin Li, Xiangdong Li, Yong Wang, and Jiyuan Tu. An integrated predictive model of the long-term performance of ground source heat pump (gshp) systems. *Energy and Buildings*, 159(15):309–318, 2018.
- [14] John W. Lund, Derek H. Freeston, and Tonya L. Boyd. Direct utilization of geothermal energy 2010 worldwide review. *Geothermics*, 40(3):159–180.
- [15] Denise A. McKahn, Arne Jacobson, and Richard Engel. Lecture notes in life cycle cost analysis for photovoltaic and fuel cell system design, November 2017.
- [16] Tidewater Mechanical. Geothermal heat pumps. <http://tidewatermechanical.com/geothermal-heat-pumps/>.
- [17] The United Nations. The sustainable development goals report 2018, 2018.
- [18] NCEES. *FE Reference Handbook 9.5 version for computer-based testing.* 2013.

- [19] U.S. Department of Energy. Geothermal-hydrothermal resources. <https://www.energy.gov/eere/geothermal/hydrothermal-resources>.
- [20] U.S. Department of Energy. Weatherize-air sealing for new home construction. <https://www.energy.gov/energysaver/air-sealing-your-home/air-sealing-new-home-construction>.
- [21] U.S. Department of Energy. Weatherize-insulation. <https://www.energy.gov/energysaver/weatherize/insulation>.
- [22] Federal Reserve Bank of New York. Federal funds data. <https://apps.newyorkfed.org/markets/autorates/fed%20funds>, 2019.
- [23] Smith College Study Group on Climate Change. Report of the smith college study group on climate change. 2017.
- [24] The Intergovernmental Panel on Climate Change. Global warming of 1.5 °c. 2018.
- [25] Richard Paradis. Retrofitting existing buildings to improve sustainability and energy performance. <https://www.wbdg.org/resources/retrofitting-existing-buildings-improve-sustainability-and-energy-performance>, 2016.
- [26] Breanna Jane Parker. Designing a proxy carbon price strategy for smith college. *Theses, Dissertations, and Projects. 2051.*, 2018.
- [27] Industrial P.E.S. and Productive Company. Hdpe pipes dimensions. <http://www.pespipe.com/hdpe-pipes/Dimension.htm>.
- [28] Mikael Philippe, Michael Bernier, and Dominique Marchio. Sizing calculation spreadsheet for vertical geothermal borefields. *ASHRAE Journal*, 52(7):20–28, 2010.
- [29] Billy J. Roberts. Geothermal resource of the united states. [https://www.nrel.gov/gis/images/geothermal\\_resource2009-final.jpg](https://www.nrel.gov/gis/images/geothermal_resource2009-final.jpg), 2009.
- [30] Energy Star. Thermal bypass checklist guide, version 1.1.
- [31] G. V. Tomarov and A. A. Shipkov. The world geothermal congress wgc-2010. *Thermal Engineering*, 57(11):989–992, 2010.
- [32] The Engineering Toolbox. Fuel oil combustion values. [https://www.engineeringtoolbox.com/fuel-oil-combustion-values-d\\_509.html](https://www.engineeringtoolbox.com/fuel-oil-combustion-values-d_509.html).
- [33] INEOS Olefins & Polymers USA. Typical engineering properties of high density polyethylene.