



## SWEDISH TYPE APPROVAL 1665 WITH DECISION ON PRODUCTION CONTROL

### Holder: Oras Ltd

P.O. Box 40, 26101 Rauma, Finland

Phone: +46 21 81 61 31

E- mail: info.sweden@oras.com

Homepage: www.oras.com

### Oras Clinica, wall mounted single-lever washbasin faucets

#### Product description

Washbasin faucets in brass (EN 817) with loop-lever.

The faucets have in-built limitation options for water temperature and maximum flow-rate and are healthcare-adapted.

#### Intended use

Single-lever faucets for hot and cold tap water intended to be used in washbasins.

#### Scope

Models:

5616, 5626, 5636, 5618

#### Approval

The products meet the requirements of Chapter 8, Section 4, of the "Planning and Building Act" (PBA) regarding the technical characteristics of construction works, protection regarding hygiene, health and the environment, depending on, that what is stated in this approval is followed. The products are approved according to the following section(s) of "Boverket's Building Regulations" (BBR):

Construction products with assessed properties	1:4
Tap water installations	6:62 (first sentence and paragraph 2 and general recommendations)
Tap water flow	6:623 (first sentence)
Backflow	6:624
Design	6:625 (paragraph 1 and 4)

#### Marking

Marking must be affixed on the product or, if there are special reasons, on the packaging or the delivery note. Marking shall indicate the following information:

Holder:	Oras Ltd
Product name, and relevant article number:	Product name (article number)
Production site:	Applicable production site
Traceability to the production:	(e.g. yyyy-mm-dd or batchnumber)
The registered trademark of Boverket No 241 217:	
Certification Body:	Kiwa Certification AB
Accreditation number:	1913
Type Approval No:	1665
Inspection Body:	Kiwa Certification AB

CERTIFIKAT

### Kiwa Certification AB

Campus Gräsvik 1  
SE-371 75 Karlskrona  
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

[se.bygg@kiwa.com](mailto:se.bygg@kiwa.com)

[www.kiwa.se](http://www.kiwa.se)



Accred. no. 1913  
Certification of  
Products  
ISO/IEC 17065

**Production site(s)**

RAU

**Control**

The manufacturers' continuing internal control is combined with surveillance inspections conducted by an accredited Inspection Body.

Inspection Body: **Kiwa Certification AB**      Inspection agreement: **1168/17**

Factory production control shall be carried out in accordance with the current instructions for control.

During inspection at the construction site, the building proprietor must verify the identity of the product by means of the marking. Furthermore, the building proprietor must ensure that the correct products are delivered and that they are installed in accordance with the manufacturer's instructions in the accompanying documents. It must also be verified that the product is accompanied by a manufacturer's declaration that certifies that production has been carried out in accordance with the documents that formed the basis for this type approval.

The validity of the Swedish Type Approval also implies that the factory production control is carried out according to the current agreement and that the holder annually fulfils the requirement in "Boverket's regulations and general recommendations for type approval", BFS 2013:6, § 5 (TYP 7), on continuing internal control. The holder shall annually, at the latest on the 15th of December, report to Kiwa Certification AB at the e-mail address [se.annualreporting@kiwa.com](mailto:se.annualreporting@kiwa.com) about continuing surveillance.

**Associated documents**

Oras Clinica - Installation and maintenance guide, 166138\_943347-05-22

**The assessment basis for the approval**

Test reports:

190800059-TR-Rev1 (Kiwa Nederland BV)

EUF129-20002034-T1 och EUF129-20000931-T1 (Eurofins)

Assessment reports:

571/20, 0273/2022 (Kiwa Certification AB)

**Comments**

The faucets have been tested according to EN 817:2008 and BRL-K607:2018.

Models:

5616\*, wall mounted faucet with swivel spout 100 mm

5626\*, wall mounted faucet with swivel spout 200 mm

5636\*, wall mounted faucet with swivel spout 300 mm

5618\*, wall mounted faucet with swivel spout 138 mm

\*) Flow rate 9,5 - 10,5 l/min


The Type approval is valid provided that the product shall neither be CE marked according to the Construction Product Regulation (EU) No 305/2011 (CPR), nor has it been suspended or withdrawn by Kiwa Certification AB.

Date of decision: 2022-08-22

Registration number: 0273/2022

Valid until: 2025-11-23

Previous registration number: 0571/20

  
**Magnus Jerlmark**

  
**Bengt-Olov Andin**