

## **EU DECLARATION OF CONFORMITY**

Distributor: JBM CAMPLLONG, S.L.U.

Address: CIM La Selva – Crta. Aeroport Km 1.6 Nave 2.2, 17185 Vilobí d'Onyar, Girona

CIF (VAT number): ESB17419292

Description of the product: Single-phase solar inverter 8KW 230V



Manufacturer's reference: R5-8K-S2

Distributor's reference: 15443

The object of the declaration is in conformity with the following standards:

Standard UNE 206006	<b>Title</b> Performance tests for islanding detection of multiple grid-connected photovoltaic inverters in parallel	Edition/Date 2011
UNE 206007-1	Requirements for connecting to the power system. Part 1: Grid-connected inverters.	2013
RD 1699	Royal Decree 1699/2011, of 18 November, which regulates the connection to the grid of small power production facilities.	2011
RD 661	Royal Decree 661/2007 of 25 May 2007, which regulates the production of electricity under the special regime.	2007
RD 413	Royal Decree 413/2014, of 6 June, which regulates the activity of electricity production from renewable energy sources, cogeneration and waste.	2014

Signed by:



Eduard Godoy

Purchasing Department Director

Girona, 12<sup>th</sup> August, 2021

(R) CERTIFICADO TÜVRheinland de conformidad Adjunto a Attachment to AK 50445522 0001 Número de registro: Registration No. 50284969 001 Reporte no: Report No. Tipo de produccion: Conectado a la red PV Inversor Type of production Modelo: R5-3K-S2, R5-3.6K-S2, R5-4K-S2, R5-5K-S2, Model R5-6K-S2, R5-7K-S2, R5-8K-S2 Versión de firmware: V2.011 Firmware version Normas: UNE 206006:2011 IN Standards Ensayos de detección de funcionamiento en isla de múltiples inversores fotovoltaicos conectados a red en paralelo UNE 206007-1:2013 IN Requisitos de conexión a la red eléctrica Parte 1: Inversores para conexión a la red de distribución RD1699/2011 Real Decreto 1699/2011, de 18 de noviembre, por el que se regula la conexión a red de instalaciones de producción de energía eléctrica de pequeña potencia. RD 661/2007 Real Decreto 661/2007, de 25 de mayo, por el que se regula la actividad de producción de energía eléctrica en régimen especial. RD 413/2014 Real Decreto 413/2014, de 6 de junio, por el que se regula la actividad de producción de energía eléctrica a partir de fuentes de energía renovables, cogeneración y residuos. Fecha de emisión: 02.09.2019 Válido hasta el: 01.09.2022 Date of issue Valid until the El certificado de conformidad se refiere al producto mencionado anteriormente. Esto es para cartificar que el espécimen está en conformidad con el requisito de evaluación mencionado anteriormente. Este certificado ne inplica una evaluación de la producción del producto y no permite el uso de una marca de conformada TCV Repeland. The certificate of conformity refers to the above mentioned product. This is to certify the second of conformity with the assessment requirement mentioned above. This certificate does not imply assessment on the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. TUVRhomland Organismo de certificación A Cher TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

	CERTIFICATE of Conformity
	Registration No.: AK 50445522 0001
	Report No.: 50284969 001
Product:	<u>PV-Inverter</u> (Grid-tied PV Inverter)
Identification:	Type Designation : R5-3K-52 R5-3.6K-S2 R5-4K-S2 R5-5K-S2 R5-6K-S2 R5-7K-S2 R5-8K-S2 Serial Number : R5S2502G1928E00955 Firmware Version : V2.011 Remark : Refer to test report 50284969 001 for details.
Tested acc. to:	UNE 206006 IN:2011 UNE 206007-1 IN:2013 RD 1699:2011 RD 661:2007 RD 413:2014
is in conformity with th	rmity refers to the above mentioned product. This is to caryte that the specim re assessment requirement mentioned above. This certificate does not imply uction of the product and does not permit the use of a TUV meinland, mark of TUV meinland, mark of Certification Body
Date 02.09.2019	A. Chen
TÜV Rheinland L	GA Products GmbH - Tillystraße 2 - 90431 Nürnberg



TÜV Rheinland (China) Ltd. Member of TÜV Rheinland Group

Date : 30/08/2019 Our ref. : zhangco 02 Your ref.: P.P

## Ref : AK Certificate of Conformity

Type of Equipment : Grid-tied PV Inverter Model Designation : See Certificate Certificate No. : AK 50445522 0001 : 50284969 001 Report No.

Dear Mr. Li Yun,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body

Shen

Enclosure

证书的详细资料清整陌www.certipedia.com查阅,或拨打我司客服务线800 999 3668 / 400 883 1300咨询

TÜV Rheinland (China) Ltd. 莱茵检测认证服务(中国)有限公司 Unit 707, AVIC Bldg., No. 108, Central Road, East 3rd Ring Road, Chaoyang District, 部编: 100022 Beijing, 100022, P.R.China

北京市朝阳区东三环中路乙10号 艾维克大量707室

Tel: (8610)6566 6660 Fax: (8610)6566 6667 e-mail: info@bj.chn.tuv.com Internet: http://www.chn.tuv.com