

**Date Filed: November 19, 2024**

**Question**

**MG-1 SUPPLEMENT**

In its November 7, 2024, response to MG-1, the Company stated that minor modifications were necessarily made to the Project Site as a result of a rigorous permitting process and input from local and state agencies subsequent to the Department's initial review of the Company's 30 percent design plan. Please explain how the alignment of the soundwall has changed since June 30, 2023.

**Response:**

The soundwall is not straight across the property. The movement of the wall averages 14 feet across the northern span along Milford Street. Specifically, the average distance between the previous wall and the house at 56 Milford Street was 137 feet and is now approximately 123 feet, a delta of 14 feet. Similarly, the distance between the previous wall and the house at 54 Milford Street was approximately 137 feet. The average distance between the current wall and the house at 54 Milford Street is 123 feet, a delta of 14 feet. The far eastern side of the northern wall along Milford Street shifted approximately 1-2 feet on average further into the Project Site and away from the street.

The wall on the east side of the site that runs in a north to south direction shifted approximately 3 feet into the Project Site and away from the wetlands and the brook.