



**Department
of Health**

KATHY HOCHUL
Governor

MARY T. BASSETT, M.D., M.P.H.
Commissioner

KRISTIN M. PROUD
Acting Executive Deputy Commissioner

April 14, 2022

Dustin Martin
Saranac Lake Village Water System
39 Main Street
Saranac Lake, NY 12983

Re: Boil Water Order – Lifted
Lake Flower Avenue Area
Saranac Lake V., Essex County

Dear Dustin:

This is to confirm that the Partial Boil Water Order issued to the Saranac Lake V on April 12, 2022 has been lifted. The Boil Water Order was issued for Lake Flower Avenue from Colony Court to Turtle Pond Road including Cortez Lane, Crossfield Road, Duprey St., Tara Drive, Poplar Lane, Edwards St., Lakeview Terrace, Will Rogers Drive, and Turtle Pond Road and is no longer necessary based on full repairs to the system, satisfactory chlorine residuals in the system, and satisfactory bacteriological sample results.

Your efforts to provide safe quality water to your consumers are always appreciated.

Sincerely,

Marlene R. Martin, P.E.
Professional Engineer