

ADDENDUM #2 – South Wheelock Road, FEMA No. 808322

June 23, 2026

TO ALL BIDDERS OF RECORD:

This Addendum consists of 1 page.

Acknowledge receipt of this Addendum by entering its number and date on the Bid Form. This Addendum forms a part of the Contract Documents and modifies them as follows:

Questions and Answers:

The following question and answer was omitted from the list in Addendum 1:

1. Is the guardrail to be removed and reused or replaced entirely?

*Refer to Sheet C-03 and C-07. The existing guardrail should be salvaged and reinstalled where possible, and installed following VTrans standard detail G-1.*