For best results editing this document in Microsoft Word, remove these paragraphs and immediately save this document (File/Save As) in the default Word Document format.

The Spanish and Hmong statements below are included in the generated CCR to promote readership by non-English speaking people that either reside or work in your community. These are translations of the following statement:

This report contains important information about your drinking water. Have someone translate it for you or talk to someone who understands it.

These statements must remain in your CCR unless you can document that no more than 5 percent of your consumers are non-English speaking. If you choose to remove these statements, documentation that demonstrates this shall be submitted to your DNR Rep along with a copy of the CCR and the CCR Certification Page.

## 2024 Consumer Confidence Report Data ALBANY WATERWORKS, PWS ID: 12300717

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.

#### **Water System Information**

If you would like to know more about the information contained in this report, please contact Dan Blumer at (608) 862-3246.

# Opportunity for input on decisions affecting your water quality

First Monday of every month at 6:30 pm

#### **Health Information**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

## Source(s) of Water

Source I	D Source	Depth (in feet)	Status
1	Groundwater	345	Active
2	Groundwater	376	Active

To obtain a summary of the source water assessment please contact, Dan Blumer at (608) 862-3246.

#### **Educational Information**

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

• Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

## **Definitions**

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HA and HAL	HA: Health Advisory. An estimate of acceptable drinking water levels for a chemical substance based on health effects information. HAL: Health Advisory Level is a concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice. Health Advisories are determined by US EPA.
НІ	HI: Hazard Index: A Hazard Index is used to assess the potential health impacts associated with mixtures of contaminants. Hazard Index guidance for a class of contaminants or mixture of contaminants may be determined by the US EPA or Wisconsin Department of Health Services. If a Health Index is exceeded a system may be required to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs

Term	Definition
	do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
PHGS	PHGS: Public Health Groundwater Standards are found in NR 140 Groundwater Quality. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
RPHGS	RPHGS: Recommended Public Health Groundwater Standards: Groundwater standards proposed by the Wisconsin Department of Health Services. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

#### **Detected Contaminants**

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

#### **Inorganic Contaminants**

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2024)	Violation	Typical Source of Contaminant
BARIUM (ppm)		2	2	0.018	0.016 - 0.018	8/8/2023	No	Discharge of drilling wastes; Discharge from metal

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2024)	Violation	Typical Source of Contaminant
								refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.2	0.1 - 0.2	8/8/2023	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
SODIUM (ppm)		n/a	n/a	1.77	1.75 - 1.77	8/8/2023	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	Range	# of Results	Sample Date (if prior to 2024)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.3270	0.0644 - 0.6910	above	8/29/2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	0.56	0.00 - 9.04	0 of 10 results were above the action level.	8/29/2023	No	Corrosion of household plumbing systems; Erosion of natural deposits

## **Radioactive Contaminants**

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2024)	Violation	Typical Source of Contaminant
GROSS BETA PARTICLE ACTIVITY (pCi/l)		n/a	n/a	2.7	2.1 - 2.7	8/8/2023	No	Decay of natural and man-made deposits. MCL units are in millirem/year. Calculation for compliance with MCL is not possible unless level found is greater than 50 pCi/l.
GROSS ALPHA, EXCL. R & U (pCi/l)		15	0	6.6	6.3 - 6.6	8/8/2023	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)		5	0	2.9	2.6 - 2.9	8/8/2023	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	6.6	6.3 - 6.6	8/8/2023	No	Erosion of natural deposits

#### **Volatile Organic Contaminants**

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2024)	Violation	Typical Source of Contaminant
TOLUENE (ppm)		1	1	0.0002	0.0000 - 0.0002		No	Discharge from petroleum factories

#### **Additional Health Information**

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Albany Waterworks is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one

point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Albany Waterworks (Dan Blumer at (608) 862-3246). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at https://www.epa.gov/safewater/lead.

#### Additional Information on Service Line Materials

We are required to develop an initial inventory of service lines connected to our distribution system by October 16, 2024 and to make the inventory publicly accessible. You can access the service line inventory here/by: 206 N. Water St. Albany WI. 53502

## **Other Compliance**

#### **Monitoring Violations**

Description	Contaminant	Sample	Compliance	Compliance
	Group	Location	Period Beginning	Period Ending
DBP Monitoring/Reporting	Dbp	Distribution System	7/1/2024	9/30/2024

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted in the above table, we did not complete all monitoring or testing for the contaminant(s) noted, and therefore cannot be sure of the quality of your drinking water during that time.

#### **Actions Taken**

The village took the samples in mid September the village was called about 7 to 10 days later State Lab of Hygiene call said because of a lab mistake that the sample were no good. That same day I sent up on of the crew to get new sample bottle and the village took new sample and ran them up the same day up when we got the sample back from the State Lab of Hygiene it was after the 9/30 2024 date. But all the sample that the village set in came back good.

#### 2024 CONSUMER CONFIDENCE REPORT (CCR) CERTIFICATION

Community Water System Name: ALBANY WATERWORKS Community Water System ID: 12300717

You must complete and send this form, along with an actual copy of the CCR, by July 1, 2025 to your Regional DNR Drinking Water Representative at the following address:

LAUREN BELZ, 3911 FISH HATCHERY RD, FITCHBURG, WI 53711, 608-800-2915

I confirm that this system's Consumer Confidence Report was distributed to customers as indicated below and information contained in the CCR is correct and consistent with compliance data submitted to DNR.

Certified by: (Name, Title) _Lonnie W. Gill_ (Phone)publicworks@villageofalbanywi.gov	(Date) _May 8, 2025
<b>Required Delivery:</b> This system has 501-10,000 consumers. In addit request, <u>at least one</u> of the following delivery methods is required. C required information. *Electronic delivery requires completion of additional control of the control of th	Check the option that was completed and include the
Option 1 - CCR was distributed by mail or direct delivery  List method and date of delivery:	
_x Option 2 - CCR was distributed electronically to all custo the method of electronic delivery used from the back page	
_xOption 3 -CCR was published in a local newspaper and e was informed in newspaper, water bill or other method the upon request.  List method of notification that CCR will not be mailed: _Attach copy, name of publication and date.	at CCR will not be mailed but is available
Option 4 - CCR was distributed by mail, electronically or the water system and CCR was also published in a local rational method and date of delivery:  Attach copy, name of publication and date.	newspaper.
Good Faith Effort: If you have any non-bill paying consumers (e.g. good faith effort to also reach these water users. At least one of the formethod(s) selected above for your population. The same method may above. Check all that were completed and attach the required information Published CCR in local newspaper. Copy attached.  Posted CCR in public places. List of locations attached.  Advertised availability of CCR upon request. Announcem x Posted CCR on the Internet at: http:// @albanyone Mailed CCR to postal patrons in service area. Zip codes u Delivered multiple CCR copies to single bill addresses ser employers, etc. List of addresses attached.  Delivered CCR to community organizations. Attach list.  Other. Description attached.	following methods is required, in addition to the y not be used for both this section and the section formation.  ent attached. wi.orgsed are attached.

**Electronic Delivery:** If electronic delivery was used in lieu of mailing the CCR, you must provide the additional information outlined on the back page.

Electronic Delivery Information - check which method of electronic delivery was used:
Option 1 - A bill or other mailing to customers contained a link (URL) that takes the reader directly to the CCR. The URL was prominently displayed in the mailing. It included an option for the customer to reques paper CCR and included a statement about water quality to promote readership. In addition, a separate notification was given to customers who use electronic payment, since not all customers who electronically pay their bills may receive a paper bill or open a paper bill if they do receive it.
A copy of the bill or mailing is attached.
A copy of the notification given to customers who use electronic payment is attached.
Option 2 - An e-mail was sent to consumers containing a link (URL) that takes the reader directly to the CCR. The e-mail included a statement encouraging readership. It also instructed how to request a paper CCR. E-mails that bounced back as undeliverable were addressed by sending the customer a CCR by anot direct delivery method.
A copy of the e-mail message is attached.
Undeliverable e-mail messages were addressed by doing the following:
Option 3 - An e-mail was sent to consumers containing an electronic copy of the CCR as an attachment in format that can be viewed without paying for additional software (e.g., PDF format). The e-mail included statement encouraging readership. It also instructed how to request a paper CCR. E-mails that bounced base undeliverable were addressed by another direct delivery method.
A copy of the e-mail message is attached.
Undeliverable e-mail messages were addressed by doing the following:
Option 4 - An e-mail was sent to consumers containing the CCR as text and tables within the message. The e-mail included a statement encouraging readership. It also instructed how to request a paper CCR. E-mail that bounced back as undeliverable were addressed by sending the customer a CCR by another direct delivery method.
A copy of the e-mail message is attached.
Undeliverable e-mail messages were addressed by doing the following:
The Places that the CCR Report was Posted
1) The Village Hall
2) Greenwoods Bank (Albany WI.)

3) The Albany Post Office