

2025 TREATMENT SYSTEM ANNUAL PERFORMANCE REPORT

GENERAL INFORMATION:

Facility/System Name:	Town of Clarkton Treatment Plant
Responsible Entity:	Town of Clarkton
Contact Person:	Alton Boswell (910) 519-0406
Applicable Permit:	NPDES NC0021610

DESCRIPTION OF TREATMENT PLANT:

The Town of Clarkton is permitted to treat 024 MGD of wastewater. Currently the treatment process consists of an influent pump station, mechanical bar screen, parabolic screen, extended aeration with tertiary filters package plant and UV disinfection. The treated wastewater is discharged to a receiving stream.

TREATMENT PERFORMANCE:

The Town of Clarkton treated 28.26 MG of wastewater during 2025. The Town of Clarkton had no Notice of Violations with the State.

2025 WASTEWATER COLLECTION SYSTEM ANNUAL PERFORMANCE REPORT

GENERAL INFORMATION:

Facility/System Name:	Town of Clarkton Treatment Plant
Responsible Entity:	Town of Clarkton
Contact Person:	Alton Boswell (910) 519-0406
Applicable Permit:	WQCS00252

DESCRIPTION OF COLLECTION SYSTEM:

The collection system consists of approximately 6 miles of sewer mains varying in size and material. It includes one sewer pumping station. Main sizes range from 8" to 12". Wastewater is collected from 361 customers in the Town of Clarkton and the surrounding community. The wastewater is sent to the Town of Clarkton Treatment Plant.

SYSTEM PERFORMANCE:

During the year 2025, approximately 28.26 MG of wastewater was conveyed to the Town of Clarkton Treatment Plant.