

HOLLAND SANITARY DISTRICT TREATMENT FACILITY OVERFLOW **PUBLIC NOTICE**

Notice is hereby given pursuant of s. NR 210.21 (5) that the Holland Sanitary District Wastewater Treatment Plant experienced a Treatment Facility Overflow (TFO) event March 14th 2021.

The TFO is the result of a plugged pipe in the plant. The spill was contained to the grass within the plant grounds and there was never any human exposure nor exposure to any water way. The issue has been resolved. The TFO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).

Published by the Authority of the Holland Sanitary District.