

# **2021 Consumer Confidence Report Data WISCONSIN DELLS WATERWORKS, PWS ID: 11101134**

**Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.**

**Dlaim ntawv tshaabzu nuav muaj lug tseemceb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.**

## **Water System Information**

If you would like to know more about the information contained in this report, please contact Scott McClyman at (608) 844-0085.

## **Opportunity for input on decisions affecting your water quality**

Public Works Meetings are held every 2nd Monday of every month.

## **Health Information**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

## Source(s) of Water

Source ID	Source	Depth (in feet)	Status
1	Groundwater	395	Active
2	Groundwater	390	Inactive as of 04/23/20
3	Groundwater	454	Active
4	Groundwater	200	Active
5	Groundwater	410	Active
6	Groundwater	400	Active
7	Groundwater	450	Active

To obtain a summary of the source water assessment please contact, Scott McClyman at (608) 844-0085.

## Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

# Definitions

<b>Term</b>	<b>Definition</b>
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAL	Health Advisory Level: The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

## Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.

### Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
HAA5 (ppb)	E-2	60	60	0	0		No	By-product of drinking water chlorination
TTHM (ppb)	E-2	80	0	3.5	3.5		No	By-product of drinking water chlorination

### Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ARSENIC (ppb)		10	n/a	1	0 - 1	9/11/2020	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)		2	2	0.027	0.005 - 0.027	9/11/2020	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.7	0.0 - 0.7	9/11/2020	No	Erosion of natural deposits; Water additive which promotes strong

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
								teeth; Discharge from fertilizer and aluminum factories
NITRATE (N03-N) (ppm)		10	10	4.60	0.18 - 5.40		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SODIUM (ppm)		n/a	n/a	76.70	1.76 - 76.70	9/11/2020	No	n/a
THALLIUM TOTAL (ppb)		2	0.5	0.2	0.0 - 0.2	9/11/2020	No	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.2290	0 of 10 results were above the action level.	8/15/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	2.50	0 of 10 results were above the action level.	8/15/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)		15	0	10.8	-0.9 - 10.8	9/11/2020	No	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)		5	0	2.8	0.8 - 2.8	9/11/2020	No	Erosion of natural deposits
GROSS ALPHA, INCL. R & U (n/a)		n/a	n/a	10.9	-0.5 - 10.9	9/11/2020	No	Erosion of natural deposits
COMBINED URANIUM (ug/l)		30	0	0.6	0.0 - 0.6	9/10/2020	No	Erosion of natural deposits

## Synthetic Organic Contaminants including Pesticides and Herbicides

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ATRAZINE (ppb)		3	3	0.1	0.1	9/11/2020	No	Runoff from herbicide used on row crops

## Contaminants with a Health Advisory Level or a Secondary Maximum Contaminant Level

The following tables list contaminants which were detected in your water and that have either a Health Advisory Level (HAL) or a Secondary Maximum Contaminant Level (SMCL), or both. There are no violations for detections of contaminants that exceed Health Advisory Levels, Groundwater Standards or Secondary Maximum Contaminant Levels. Secondary Maximum Contaminant Levels are levels that do not present health concerns but may pose aesthetic problems such as objectionable taste, odor, or color. Health Advisory Levels are levels at which concentrations of the contaminant present a health risk.

Contaminant (units)	Site	SMCL (ppm)	HAL (ppm)	Level Found	Range	Sample Date (if prior to 2021)	Typical Source of Contaminant
CHLORIDE (ppm)		250		54.00	2.80 - 54.00	8/23/2017	Runoff/leaching from natural deposits, road salt, water softeners
IRON (ppm)		0.3		0.11	0.00 - 0.11	8/23/2017	Runoff/leaching from natural deposits, industrial wastes
ZINC (ppm)		5		0.01	0.00 - 0.01	8/23/2017	Runoff/leaching from natural deposits, industrial wastes

## Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wisconsin Dells Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Other Compliance

### Uncorrected Significant Deficiencies

Deficiency Description and Progress to Date	Date System Notified	Scheduled Correction Date
Past inspection deficiencies have not been corrected as required.	3/11/2020	12/31/2021

### Actions Taken

#### 2021 – Failure to address significant deficiencies.

The deficiencies include:

Improve value exercising frequency and record keeping.

Reorganize inspection frequencies for non-residential cross connection customers and improve inspection frequencies.

DNR Approved Plan and schedule for correction.

1. Public Notice. The Water Supplier shall provide and comply with a public notice informing all consumers of the failure to correct significant deficiencies. The Water Supplier shall repeat the public notice every 3 months until the Water Supplier returns to compliance with the treatment technique requirements. The Water Supplier shall report all public notices to the department.
2. Corrective Action. The Water Supplier shall take corrective action to return to compliance with treatment technique requirements.
  - a) Records of Valve Exercising. By 12/31/2022, the Water Supplier shall create a comprehensive record system for all exercising and maintenance of system valves. At a minimum, record keeping shall be sufficient to ensure proper scheduling.
  - b) Valve Exercising. By 08/01/2023, the Water Supplier shall exercise all valves to establish a basis for demonstrating that all valves have been exercised at the required frequency.
    - i. By 12/31/2022, the Water Supplier shall exercise at least 400 valves to ensure the Water Supplier is able to meet the overall compliance deadline for exercising all valves.
  - c) Cross Connection Control Program. By 06/01/2022, the Water Supplier shall submit to the department an administrative plan describing how the Water Supplier is implementing its cross-connection control program and include a schedule for completing inspections of high-risk properties. This plan must include a signed contract with a third-party contractor. The plan must be in writing.
  - d) Cross Connection Inspections. By 12/31/2023, the Water Supplier shall complete and submit to the department documentation for all required non-residential cross-connection inspections.
  - e) Notification. Within 30 days of completing each required corrective action, the Water Supplier shall notify the department in writing that it has corrected the significant deficiency.

Actions taken to date.

Valve exercising frequency is being increased and new record keeping software is in place. A cross connection inspection contract has been executed and inspections are underway.



Wisconsin Dells Consumer Confidence Report will not be mailed out.

Copies of the report will be available at:

City Hall

Kilbourn Public Library

Kilbourn Fire Department

City Website: [www.citywd.org](http://www.citywd.org)