

[Click here to open USEPA 2022 Guidance for Developing and Maintaining a Service Line Inventory](#)

Note: Field names that are shaded navy are required for every service connection. Field names shaded blue are recommended, optional, or only required under certain conditions. See field descriptions for more information.

	Column	Description		
B	LOCATION IDENTIFIER	The location identifier can be the site address, however if there is more than one service connection at a given address, it must include additional detail. If the PWS does not wish to report addresses to the department it can be a block, intersection or landmark. This column is required per sub-subparagraph §141.84 (a)(8)(i) of the LCRR which requires that a location identifier be associated with each service line.		
	Column	Description	Answer options	Answer Option Descriptions
D	CURRENT STREET SIDE SERVICE LINE MATERIAL	Service line pipe material, from the water main to curb stop.	L	CONFIRMED LEAD
			C	CONFIRMED COPPER
			G	CONFIRMED GALVANIZED
			P	CONFIRMED PLASTIC
			DI	CONFIRMED DUCTILE IRON
			CI-L	CONFIRMED LINED CAST IRON
			CI-U	CONFIRMED UNLINED CAST IRON
			UNK-LG	UNKNOWN - MAY CONTAIN LEAD OR GALVANIZED
			UNK-NOLG	UNKNOWN - DEFINITELY DOES NOT CONTAIN LEAD OR GALVANIZED
	Column	Description		
H	CURRENT PROPERTY SIDE SERVICE LINE MATERIAL	Service line pipe material, from the curb stop to water meter. See Row D for answer options.		