

Year	Bypass Events #	Annual Rainfall Buffalo (Inches)
2007	1	35.18
2008	2	47.35
2009	6	44.35
2010	4	36.76
2011	7	49.59
2012	2	32.83
2013	1	46.09
2014	0	42.44
2015	0	36.85
2016	0	33.9
2017	1	48.5
2018	1	41.69
2019	1	47.84
2020	1	39.69
2021	1	40.37
2022	3	45.34
2023	1	40.58
2024	2	36.79

\* Per NCEI.NOAA.GOV

Bypass Events		
Date	Location	Volume
3/14/2007	S. 4th St. (pump failure)	565,000
4/4/2008	S. 4th St. (1 pump out for service)	60,000
6/4/2008	Adams St. (high flow event)	4,000
6/4/2008	S. 4th St. (high flow event)	90,000
2/11/2009	S. 4th St. (high flow event)	530,000
3/10/2009	Martha Ave. (high flow / pump faulted)	28,000
3/11/2009	S. 4th St. (high flow / pump faulted)	2,000,000
6/20/2009	Martha Ave. (high flow event)	8,000
6/20/2009	S. 4th St. (high flow event)	104,000
8/10/2009	Martha Ave. (high flow event)	64,000
8/10/2009	S. 4th St. (loss of power)	580,000
8/10/2009	Adams St. (loss of power)	148,000
10/7/2009	Martha Ave. (loss of power)	236,000
1/25/2010	S. 4th St. (high flow event)	46,000
6/27/2010	S. 4th St. (high flow event)	14,100
7/25/2010	S. 4th St. (high flow event)	66,000
12/1/2010	S. 4th St. (high flow event)	1,000,000
12/1/2010	Martha Ave (high flow event)	100,000
2/28/2011	S. 4th St. (high flow event)	292,000
2/28/2011	Martha Ave (high flow event)	58,000
4/27/2011	S. 4th St. (high flow event)	145,000
5/3/2011	S. 4th St. (high flow event)	115,000
5/18/2011	Martha Ave (high flow event)	23,000
5/18/2011	S. 4th St. (high flow event)	230,000
5/24/2011	S. 4th St. (high flow event)	190,000
5/26/2011	S. 4th St. (high flow event)	55,000
11/14/2011	S. 4th St. (high flow event)	20,000
7/15/2012	S. 4th St. (high flow event)	32,000
7/31/2012	S. 4th St. (high flow event)	64,000
6/13/2013	S. 4th St. (loss of power)	18,700
1/27/2017	Martha Ave (high flow event)	158,000
8/17/2018	S. 4th St. (loss of power)	45,000
8/7/2019	S. 4th St. (loss of power and communications)	330,000
7/16/2020	S. 4th St. (high flow event)	64,000
7/16/2021	Adams St. (high flow event)	16,000
2/17/2022	Martha Ave (high flow event)	85,000
2/17/2022	S. 4th St. (high flow event)	200,000
3/7/2022	S. 4th St. (high flow event)	48,000
11/11/2022	Adams St. (high flow event)	1,000
11/11/2022	S. 4th St. (high flow event)	7,500
8/25/2023	S. 4th St. (high flow event)	40,000
4/3/2024	S. 4th St. (high flow & pump faulted)	115,000
4/3/2024	S. 4th St. (high flow event)	71,000
6/19/2024	Adams St. (high flow event)	50,000
6/19/2024	S. 4th St. (high flow event)	200,000
6/19/2024	Martha Ave (high flow event)	30,000