



CITY OF GARDEN CITY

6015 Glenwood Street ■ Garden City, Idaho 83714
Phone 208/472-2900 ■ Fax 208/472-2996

Chief Romeo Gervais
Boise Fire Department
333 Mark Stall Place
Boise, Idaho 83704-0644

January 24, 2025

Subject: Ability to Provide Fire Flows

Fire Flow Information:

Address fire flow requested for: 4410 Osage Street

Fire hydrant serving this address: Hydrant # 3030

Fire flow Garden City is able to provide is 1500 gpm at 20 psi residual for 2 hours.

Sprinkler System Design Information:

Static pressure: 60 psi

Residual pressure: 20 psi

Minimum flow at residual pressure: 1500 gpm

For questions, please contact the Garden City permitting desk at 472-2921.

Sincerely,

Chad Vaughn

Garden City Public Works Water Division

cc:
Applicant
File