

**From:** [Derek Hurd](#)  
**To:** [Hanna Veal](#)  
**Cc:** [Brett Labrie](#); [Jenah Thornborrow](#); [DSDIntern](#)  
**Subject:** Re: DSRFY2024-0009 - 4844 Fenton St.  
**Date:** Friday, July 12, 2024 2:16:13 PM  
**Attachments:** [image002.png](#)  
[image003.png](#)  
[image004.png](#)  
[image005.png](#)

---

This appears to have met the intentions of the comments that I had. However, the notes mention CMU concrete enclosure for the toter staging area, but we discussed that not being needed. It was to be just a pad that the toters park on for the daytime pickup on trash day and making a permanent enclosure unnecessary. And Republic rolls each one across the sidewalk for pickup....not with the claws across the sidewalk. Staff can work with that adjustment, I have no further comments.

Derek Hurd  
Gravitas, Inc.  
208.841.4112

On Fri, Jul 12, 2024 at 12:45 PM Hanna Veal <[hveal@gardencityidaho.org](mailto:hveal@gardencityidaho.org)> wrote:

Good afternoon,

Please see attached resubmittals. At the previous consultation meeting you permitted an email resubmittal review. Please provide your comments.

Happy Friday!



**Hanna Veal**

*Associate Planner*

Development Services Department, **City of Garden City**

p: 208-472-2922

a: 6015 Glenwood Street, Garden City, ID 83714

w: [www.gardencityidaho.org](http://www.gardencityidaho.org)



---

This email has been scanned for spam and viruses by Proofpoint Essentials. Click [here](#) to report this email as spam.