

Jeff Ramey  
*Commissioner/Chairman*

J. Todd Bunderson  
*Commissioner*

Jeff Souza  
*Commissioner*

Shelley Vaughan  
*District  
Administrator*



September 25, 2024

Garden City Development Services

Re: DSRFY2024-0017 8247 W State St

These are design review comments for the modification of an existing wireless facility to include the installation of a 30kWh AC diesel generator.

The Boise Fire Department has reviewed and can approve the application subject to compliance with all the following code requirements and conditions of approval. Any deviation from this plan is subject to Fire Department approval. Please note that unless stated otherwise, this memo represents the requirements of the International Fire Code (IFC) as adopted and amended by the North Ada County Fire District.

Comments:

The applicant must submit an application for an operational fire permit for the combustible liquids tank associated with the generator to the Fire Marshal's office. This can be done at the following URL: <https://www.cityofboise.org/departments/fire/fire-prevention/permits/special-use-and-operations/flammable-combustible-liquids-or-tank-permit/>

General Requirement:

Fire Department required fire hydrants, access, and street identification shall be installed prior to construction or storage of combustible materials on site. Provisions may be made for temporary access and identification measures.

Specific building construction requirements of the International Building Code, International Fire Code and NACFR Rules will apply. However, these provisions are best addressed by a licensed Architect at time of building permit application.

Regards,

*Mike Bisagno*

Mike Bisagno

Division Chief – Fire Marshal  
Boise Fire Department

5800 Glenwood • Garden City, Idaho 83714 • (208) 375-0906