



## CITY OF GARDEN CITY

6015 Glenwood Street ■ Garden City, Idaho 83714  
Phone 208/472-2900 ■ Fax 208/472-2996

Chief Romeo Gervais  
Boise Fire Department  
333 Mark Stall Place  
Boise, Idaho 83704-0644

July 24, 2023

Subject: Ability to Provide Fire Flows

### **Fire Flow Information:**

Address fire flow requested for: 5586 N Maple Grove Rd

Fire hydrant serving this address: #1112

Fire flow Garden City is able to provide is 2000 gpm at 20 psi residual for 2 hours.

### **Sprinkler System Design Information:**

Static pressure: 50 psi

Residual pressure: 20 psi

Minimum flow at residual pressure: 2000 gpm

For questions please contact the Garden City permitting desk at 472-2921.

Sincerely,

*Chad Vaughn*

Garden City Public Works Water Division

cc:  
Applicant  
File