

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:

6/8/2026

2025

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	0.2562	x	287	x	8.34	=	613
February	0.2591	x	319	x	8.34	=	690
March	0.3443	x	202	x	8.34	=	579
April	0.3966	x	173	x	8.34	=	572
May	0.3806	x	194	x	8.34	=	615
June	0.3643	x	196	x	8.34	=	595
July	0.3854	x	158	x	8.34	=	507
August	0.3524	x	249	x	8.34	=	733
September	0.3370	x	256	x	8.34	=	720
October	0.2999	x	346	x	8.34	=	865
November	0.2426	x	334	x	8.34	=	676
December	0.2438	x	455	x	8.34	=	924

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.501	x	90	=	0.4509
		x	100	=	.501
Design BOD, lbs/day	1310	x	90	=	1179
		x	100	=	1310

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

- ☒ Yes Enter last calibration date (MM/DD/YYYY)

2025-05-19

- ☐ No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

- ☒ Yes

- ☐ No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

- ☐ Yes

- ☒ No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks Holding Tanks Grease Traps

- ☐ Yes

- ☐ Yes

- ☐ Yes

- ☒ No

- ☒ No

- ☒ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

- ☐ Yes

gallons

- ☒ No

Holding Tanks

- ☐ Yes

gallons

- ☒ No

Grease Traps

- ☐ Yes

gallons

- ☒ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

- ☐ Yes

- ☒ No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:

6/8/2026

2025

- Yes
- No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

Landfill leachate was received from Juneau County landfill, it was hauled in and dumped into our overflow tank and slowly discharged into influent headworks. Pre sampling was performed and will continue to be sampled.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	17	1	0	0
February	30	27	22	1	0	0
March	30	27	15	1	0	0
April	30	27	13	1	0	0
May	30	27	3	1	0	0
June	30	27	4	1	0	0
July	30	27	4	1	0	0
August	30	27	2	1	0	0
September	30	27	4	1	0	0
October	30	27	4	1	0	0
November	30	27	6	1	0	0
December	30	27	8	1	0	0

* Equals limit if limit is ≤ 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

☒ Yes Enter last calibration date (MM/DD/YYYY)
2025-05-19

☐ No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

None

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

☐ Yes
☒ No

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

If Yes, please explain:
4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test? ☐ Yes ☒ No If Yes, please explain:
4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity? ☐ Yes ☐ No ☒ N/A Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	4	1	0	0
February	30	27	4	1	0	0
March	30	27	6	1	0	0
April	30	27	3	1	0	0
May	30	27	1	1	0	0
June	30	27	2	1	0	0
July	30	27	1	1	0	0
August	30	27	1	1	0	0
September	30	27	2	1	0	0
October	30	27	0	1	0	0
November	30	27	1	1	0	0
December	30	27	1	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		0	0
Points		0	0
Total Number of Points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:

6/8/2026

2025

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceed ance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceed ance
January	108	108	2.049	0	1	.103	.943	4.833	0
February	108	108	2.443	0	.783	2.433	1.623	4.933	0
March	108	108	.433	0	1.133	.2	.2	.2	0
April	108	108	.215	0	.27	.2	.2	.2	0
May	108	108	0	0	0	0	0	0	0
June	108	108	0	0	0	0	0	0	0
July	108	108	0	0	0	0	0	0	0
August	108	108	1.108	0	0	4.433	0	0	0
September	108	108	0	0	0	0	0	0	0
October	108	108	.2	0	.2	.2	.2	.2	0
November	108	108	.017	0	0	.067	0	0	0
December	108	108	2.687	0	9.6	1.323	2.337	.173	0
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.155	1	0
February	1	0.149	1	0
March	1	0.144	1	0
April	1	0.106	1	0
May	1	0.085	1	0
June	1	0.092	1	0
July	1	0.256	1	0
August	1	0.293	1	0
September	1	0.435	1	0
October	1	0.221	1	0
November	1	0.111	1	0
December	1	0.095	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- ☒ Land applied under your permit
☐ Publicly Distributed Exceptional Quality Biosolids
☐ Hauled to another permitted facility
☐ Landfilled
☐ Incinerated
☐ Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

2. Land Application Site

2.1 Last Year's Approved and Active Land Application Sites

2.1.1 How many acres did you have?

323.9 acres

2.1.2 How many acres did you use?

33.8 acres

2.2 If you did not have enough acres for your land application needs, what action was taken?

2.3 Did you overapply nitrogen on any of your approved land application sites you used last year?

o Yes (30 points)

● No

2.4 Have all the sites you used last year for land application been soil tested in the previous 4 years?

● Yes

o No (10 points)

o N/A

0

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - Liquid Sludge

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75				160										1	1
Cadmium		39	85				4.4										0	0
Copper		1500	4300				270										0	0
Lead		300	840				47										0	0
Mercury		17	57				.23										0	0
Molybdenum	60		75				98									1		1
Nickel	336		420				78									0		0
Selenium	80		100				160									1		1
Zinc		2800	7500				620										0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 4

Exceedence Points

o 0 (0 Points)

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

☐ 1-2 (10 Points)

☒ > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

☒ Yes

☐ No (10 points)

☐ N/A - Did not exceed limits or no HQ limit applies (0 points)

☐ N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 3

Exceedence Points

☐ 0 (0 Points)

☐ 1 (10 Points)

☒ > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

☒ Yes (20 Points)

☐ No (0 Points)

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken?
Has the source of the metals been identified?

Looked into possible sources but nothing was found we are testing leachate more often to identify if that is our source.

0

4. Pathogen Control (per outfall):

4.1 Verify the following information. If any information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Outfall Number:	002
Biosolids Class:	B
Bacteria Type and Limit:	Fecal Coliform
Sample Dates:	01/01/2025 - 12/31/2025
Density:	0
Sample Concentration Amount:	CFU/G TS
Requirement Met:	Yes
Land Applied:	Yes
Process:	Aerobic Digestion
Process Description:	Sludge is Aerobic digested for at least 40 days prior to being pumped to storage to await land application.

0

4.2 If exceeded Class B limit or did not meet the process criteria at the time of land application.

4.2.1 Was the limit exceeded or the process criteria not met at the time of land application?

☐ Yes (40 Points)

☒ No

If yes, what action was taken?

5. Vector Attraction Reduction (per outfall):

5.1 Verify the following information. If any of the information is incorrect, use the Report Issue button under the Options header in the left-side menu.

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Outfall Number:	002	0
Method Date:	12/31/2025	
Option Used To Satisfy Requirement:	Injection when land apply	
Requirement Met:	Yes	
Land Applied:	Yes	
Limit (if applicable):		
Results (if applicable):		
5.2 Was the limit exceeded or the process criteria not met at the time of land application? ☐ Yes (40 Points) ☒ No If yes, what action was taken?		
6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? ☒ >= 180 days (0 Points) ☐ 150 - 179 days (10 Points) ☐ 120 - 149 days (20 Points) ☐ 90 - 119 days (30 Points) ☐ < 90 days (40 Points) ☐ N/A (0 Points) 6.2 If you checked N/A above, explain why.		
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:		

Total Points Generated	30
Score (100 - Total Points Generated)	70
Section Grade	D

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing 1.1 Was your wastewater treatment plant adequately staffed last year? ● Yes ○ No If No, please explain: Could use more help/staff for: 1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping? ● Yes ○ No If No, please explain:	
2. Preventative Maintenance 2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items? ● Yes (Continue with question 2) □□ ○ No (40 points)□□ If No, please explain, then go to question 3: 2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment? ● Yes ○ No (10 points) 2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly? ● Yes ○ Paper file system ○ Computer system ● Both paper and computer system ○ No (10 points)	0
3. O&M Manual 3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed? ● Yes ○ No	
4. Overall Maintenance /Repairs 4.1 Rate the overall maintenance of your wastewater plant. ○ Excellent ● Very good ○ Good ○ Fair ○ Poor Describe your rating: Plant has a maintenance plan in place and have low to moderate equipment failures.	

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- ☒ Yes (0 points)
- ☐ No (20 points)

Name:

NICK D WYSS

Certification No:

36205

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Advanced	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				X
A3	Recirculating Media Filters		X		
A4	Ponds, Lagoons and Natural				X
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus	X			X
N	Total Nitrogen				
D	Disinfection	X			X
L	Laboratory				X
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	X	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- ☒ Yes (0 points)
- ☐ No (20 points)

2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?

- ☐ Yes
- ☐ No
- ☒ N/A – Wastewater treatment facility does not have a registered or certified laboratory

2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?

- ☒ Yes
- ☐ No
- ☐ N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- ☐ One or more additional certified operators on staff

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:

6/8/2026

2025

☒ An arrangement with another certified operator ☒ An arrangement with another community with a certified operator ☒ An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year ☒ A consultant to serve as your certified operator ☐ None of the above (20 points) If "None of the above" is selected, please explain: 	0
4. Continuing Education Credits 4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: ☐ Averaging 6 or more CECs per year. ☐ Averaging less than 6 CECs per year. Advanced Certification: ☒ Averaging 8 or more CECs per year. ☐ Averaging less than 8 CECs per year.	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:

6/8/2026

2025

Financial Management

1. Provider of Financial Information Name: Jen Pedersen Telephone: 608-562-5213 (XXX) XXX-XXXX E-Mail Address (optional): nlclerk@mwt.net										
2. Treatment Works Operating Revenues 2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ? ● Yes (0 points) ☐ ☐ ○ No (40 points) If No, please explain: 2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: 2026 ● 0-2 years ago (0 points) ☐ ☐ ○ 3 or more years ago (20 points) ☐ ☐ ○ N/A (private facility) 2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system? ● Yes (0 points) ○ No (40 points)		0								
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]										
3. Equipment Replacement Funds 3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: 2026 ● 1-2 years ago (0 points) ☐ ☐ ○ 3 or more years ago (20 points) ☐ ☐ ○ N/A If N/A, please explain: 3.2 Equipment Replacement Fund Activity 3.2.1 Ending Balance Reported on Last Year's CMAR 3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.) 3.2.3 Adjusted January 1st Beginning Balance 3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)		<table><tr><td>\$</td><td> 754,653.75 </td></tr><tr><td>\$</td><td> 80,828.00 </td></tr><tr><td>\$</td><td> 835,481.75 </td></tr><tr><td>\$</td><td> 9,392.00 </td></tr></table>	\$	754,653.75	\$	80,828.00	\$	835,481.75	\$	9,392.00
\$	754,653.75									
\$	80,828.00									
\$	835,481.75									
\$	9,392.00									

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)

- \$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 844,873.75

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

N/A

3.3 What amount should be in your Replacement Fund? \$ 844,873.75

0

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

● Yes

○ No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

● Yes - If Yes, please provide major project information, if not already listed below. ☐ ☐

○ No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Replace sewer main on east side of Adams St.	\$1,800,000	2027
2	Replace sewer main on east side of Adams St.	\$1,800,000	2027
3	Replace sewer main on east side of Adams St.	\$1,800,000	2027

5. Financial Management General Comments

None

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations: 12

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	6,334	1,150
February	6,207	96
March	4,751	40
April	5,062	27
May	4,679	6
June	5,091	8
July	4,705	0
August	4,562	3
September	4,656	56
October	4,142	94
November	4,404	522
December	4,494	1,068
Total	59,087	3,070
Average	4,924	279

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- ☒ Comminution or Screening
- ☐ Extended Shaft Pumps
- ☐ Flow Metering and Recording
- ☒ Pneumatic Pumping
- ☒ SCADA System
- ☐ Self-Priming Pumps
- ☒ Submersible Pumps
- ☐ Variable Speed Drives
- ☐ Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

- ☒ No
- ☐ Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

Replace pneumatic pump station at Baders West with a submersible pump station.

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/ Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/ Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	44,520	7.94	5,607	19.00	2,343	147
February	46,920	7.25	6,472	19.32	2,429	120
March	41,640	10.67	3,903	17.95	2,320	82
April	45,600	11.90	3,832	17.16	2,657	96
May	41,520	11.80	3,519	19.07	2,177	28
June	39,720	10.93	3,634	17.85	2,225	6
July	37,320	11.95	3,123	15.72	2,374	11
August	39,120	10.92	3,582	22.72	1,722	15
September	37,800	10.11	3,739	21.60	1,750	20
October	37,560	9.30	4,039	26.82	1,400	46
November	41,760	7.28	5,736	20.28	2,059	79
December	40,320	7.56	5,333	28.64	1,408	199
Total	493,800	117.61		246.13		849
Average	41,150	9.80	4,377	20.51	2,072	71

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- ☒ Aerobic Digestion
- ☐ Anaerobic Digestion
- ☒ Biological Phosphorus Removal
- ☒ Coarse Bubble Diffusers
- ☒ Dissolved O2 Monitoring and Aeration Control
- ☐ Effluent Pumping
- ☐ Fine Bubble Diffusers
- ☒ Influent Pumping
- ☐ Mechanical Sludge Processing
- ☐ Nitrification
- ☒ SCADA System
- ☒ UV Disinfection
- ☒ Variable Speed Drives
- ☐ Other:

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

7.2.2 Comments:

None

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

Replace digester blowers with more efficient blowers.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

☒ No

☐ Yes

If Yes, how is the biogas used (Check all that apply):

☐ Flared Off

☐ Building Heat

☐ Process Heat

☐ Generate Electricity

☐ Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

☐ No

☒ Yes

☒ Entire facility

Year:

2016

By Whom:

MSA Engineering

Describe and Comment:

A complete study was performed prior to plant upgrades

☐ Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- ☒ Yes
- ☐ No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- ☒ Yes
- ☐ No (30 points)
- ☐ N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

☒ Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Clean and inspect sewer mains and manholes throughout the entire collection system.
Clean and inspect all lift stations including pulling pumps and servicing pumps and control equipment.

Did you accomplish them?

- ☒ Yes
- ☐ No

If No, explain:

☒ Organization [NR 210.23 (4) (b)] ☐ ☐

Does this chapter of your CMOM include:

- ☒ Organizational structure and positions (eg. organizational chart and position descriptions)
- ☒ Internal and external lines of communication responsibilities
- ☒ Person(s) responsible for reporting overflow events to the department and the public

☒ Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

Sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2026-01-01

Does your sewer use ordinance or other legally binding document address the following:

- ☒ Private property inflow and infiltration
- ☒ New sewer and building sewer design, construction, installation, testing and inspection
- ☒ Rehabilitated sewer and lift station installation, testing and inspection
- ☒ Sewage flows satellite system and large private users are monitored and controlled, as necessary
- ☒ Fat, oil and grease control
- ☒ Enforcement procedures for sewer use non-compliance

☒ Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- ☒ Equipment and replacement part inventories
- ☒ Up-to-date sewer system map

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

☒ A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation ☒ A description of routine operation and maintenance activities (see question 2 below) ☒ Capacity assessment program ☒ Basement back assessment and correction ☒ Regular O&M training ☒ Design and Performance Provisions [NR 210.23 (4) (e)] ☐ ☐ What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property? ☒ State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements ☒ Construction, Inspection, and Testing ☐ Others: ☒ Overflow Emergency Response Plan [NR 210.23 (4) (f)] ☐ ☐ Does your emergency response capability include: ☒ Responsible personnel communication procedures ☒ Response order, timing and clean-up ☒ Public notification protocols ☒ Training ☒ Emergency operation protocols and implementation procedures ☒ Annual Self-Auditing of your CMOM Program [NR 210.23 (5)] ☐ ☐ ☒ Special Studies Last Year (check only those that apply): ☐ Infiltration/Inflow (I/I) Analysis ☐ Sewer System Evaluation Survey (SSES) ☒ Sewer Evaluation and Capacity Management Plan (SECAP) ☐ Lift Station Evaluation Report ☐ Others:	0																														
2. Operation and Maintenance 2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained. <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Cleaning</td> <td style="width: 15%; text-align: center; border: 1px solid black;">40</td> <td style="width: 55%;">% of system/year</td> </tr> <tr> <td>Root removal</td> <td style="text-align: center; border: 1px solid black;">2</td> <td>% of system/year</td> </tr> <tr> <td>Flow monitoring</td> <td style="text-align: center; border: 1px solid black;">100</td> <td>% of system/year</td> </tr> <tr> <td>Smoke testing</td> <td style="text-align: center; border: 1px solid black;">0</td> <td>% of system/year</td> </tr> <tr> <td>Sewer line televising</td> <td style="text-align: center; border: 1px solid black;">10</td> <td>% of system/year</td> </tr> <tr> <td>Manhole inspections</td> <td style="text-align: center; border: 1px solid black;">60</td> <td>% of system/year</td> </tr> <tr> <td>Lift station O&M</td> <td style="text-align: center; border: 1px solid black;">12</td> <td># per L.S./year</td> </tr> <tr> <td>Manhole rehabilitation</td> <td style="text-align: center; border: 1px solid black;">1</td> <td>% of manholes rehabbed</td> </tr> <tr> <td>Mainline rehabilitation</td> <td style="text-align: center; border: 1px solid black;">0</td> <td>% of sewer lines rehabbed</td> </tr> <tr> <td>Private sewer inspections</td> <td style="text-align: center; border: 1px solid black;">0</td> <td>% of system/year</td> </tr> </table>		Cleaning	40	% of system/year	Root removal	2	% of system/year	Flow monitoring	100	% of system/year	Smoke testing	0	% of system/year	Sewer line televising	10	% of system/year	Manhole inspections	60	% of system/year	Lift station O&M	12	# per L.S./year	Manhole rehabilitation	1	% of manholes rehabbed	Mainline rehabilitation	0	% of sewer lines rehabbed	Private sewer inspections	0	% of system/year
Cleaning	40	% of system/year																													
Root removal	2	% of system/year																													
Flow monitoring	100	% of system/year																													
Smoke testing	0	% of system/year																													
Sewer line televising	10	% of system/year																													
Manhole inspections	60	% of system/year																													
Lift station O&M	12	# per L.S./year																													
Manhole rehabilitation	1	% of manholes rehabbed																													
Mainline rehabilitation	0	% of sewer lines rehabbed																													
Private sewer inspections	0	% of system/year																													

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Private sewer I/I
removal

0

% of private services

River or water
crossings

0

% of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

37.45	Total actual amount of precipitation last year in inches
36.33	Annual average precipitation (for your location)
18.1	Miles of sanitary sewer
12	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
.320	Average daily flow in MGD (if available)
.397	Peak monthly flow in MGD (if available)
.557	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

0.00	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.00	Sanitary sewer overflows (number/sewer mile/yr)
0.00	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.2	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
1.7	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

☐ Yes

☒ No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

☐ Yes

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

- No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

None

5.4 What is being done to address infiltration/inflow in your collection system?

We continue to utilize our CMOM program and clean and inspect our sanitary sewer collection system and repair as needed.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Grading Summary

WPDES No: 0020699

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	D	1	5	5
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	133
GRADE POINT AVERAGE (GPA) = 3.59				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

New Lisbon Wastewater Treatment Facility

Last Updated: Reporting For:
6/8/2026 2025

Resolution or Owner's Statement

Name of Governing
Body or Owner:

City of New Lisbon

Date of Resolution or
Action Taken:

2026-06-15

Resolution Number:

0615-26-01

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = D

We are looking for the source of the metals that have caused to elevated contaminates. At this time we have not found the source.

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.59

