



Office of the Building Inspector

Brian L. Flannery, State Certified Building Inspector # 249647

405 4th St. Albany, WI 53502

Phone: (608) 558-1833 Email: brianflannery@outlook.com

Affidavit of Compliance

Plumbing System Testing

All new plumbing and all parts of existing systems which have been altered, extended or repaired shall be tested as specified in the current version of the Wisconsin Uniform Plumbing Code, Chapters SPS 380-387. The purpose of this test is to disclose leaks and defects before the plumbing is put into operation.

Personal information you provide may be used for secondary purposes [Privacy Law, s. 15.04 (1)(m)].

Plumber, Owner and Site Information	
Date of Test:	
Responsible Master Plumber:	
Responsible Master Plumber MP Number and Expiration:	
Owner's Name:	
Project Site Address:	
Project Site Municipality:	

Type of project (check one): New Installation ☐ Remodel or Addition ☐ Repair ☐ Other ☐

If other, explain: _____

Testing Information	
Sanitary Building Sewer or Private Interceptor Main Sewer:	☐ Water test (10' for 15 minutes) ☐ Air test (3 psig for 15 minutes) (air test not recommended for plastic pipe)
Water Service or Private Water Main::	☐ Water test (Working pressure) ☐ Air test (Working pressure)
Building Drain	☐ Water test (10' except for top 10' for 15 minutes) ☐ Air test (5 psig for 15 minutes)
Drain & Vent System	☐ Water test (10' for 15 minutes) ☐ Air test (5 psig for 15 minutes)
Water Distribution	☐ Water test (Working pressure) ☐ Air test (Working pressure)
Air Admittance Valves	☐ Manometer test to 1" water column
Air Admittance Valve Brand & Model	



Office of the Building Inspector

Brian L. Flannery, State Certified Building Inspector # 249647
405 4th St. Albany, WI 53502
Phone: (608) 558-1833 Email: brianflannery@outlook.com

I hereby certify that I have tested said plumbing system as listed within this document according to all Code provisions as listed in the current version of the Wisconsin Uniform Plumbing Code as written by the Wisconsin Department of Safety and Professional Services Division of Industry Services.

Responsible Master Plumber - Signature

Date