

**STATE OF MINNESOTA  
CASS COUNTY  
ENVIRONMENTAL SERVICES**

**INDIVIDUAL SEWAGE TREATMENT SYSTEM PERMIT  
No. 01021**

**PERMITTEE:** Wabedo Township- Barbara Anderson- Township Clerk

**FACILITY NAME:** Lazy Boy Trail NE Subordinate Service District

**ADDRESS:** 1535 Barga Lane NE

**PHONE:** 218.363.2649

**Longville, MN 56655**

**GIS LOCATION:** 408151, 5198115

**ISSUANCE DATE:** 11-14-2017

**EXPIRATION DATE:** 12-31-2022

Cass County, on behalf of its citizens through Cass County Environmental Services authorizes the Permittee to discharge from an onsite wastewater treatment system at the facility named above to the groundwater of the Upper Mississippi River Basin in Cass County in accordance with the requirements of this permit.

The permit is effective on the issuance date identified above.

This permit and the authorization to discharge shall expire 12/31/2022. The Permittee is not authorized to discharge after the above date of expiration. In order to receive authorization to discharge beyond the above date of expiration, the Permittee shall submit such information and forms as are required by Cass County Environmental Services no later than 30 days prior to the above date of expiration.

Signature: \_\_\_\_\_



Cass County Environmental Services

Owner/Agent

If you have questions regarding this permit, including the specific permit requirements, permit reporting, or permit compliance status, please contact:

Cass County Environmental Services  
Courthouse Box 3000  
Walker, MN 56484

- I. DESCRIPTION:** The system provides wastewater treatment for four houses adjacent to Little Boy Lake. The system consists at a minimum of a 1,000-gallon septic tank with a filter and water meter per house, and a 1000 gallon time dosed duplexed pump transfer tank. Dual 10 x 41.5 rock bed mound.
- II. PERFORMANCE REQUIREMENTS:** During the period beginning on the effective date of this permit and lasting until this permit's expiration date, the Permittee is authorized to discharge treated water from this system to the groundwater. No discharge from the system to surface water nor overland flow from any of the system components is permitted. The maximum of an average seven-day daily flow can't be more than 75% of 1000 gallons.

This discharge shall be limited by the Permittee as specified below:

PARAMETER	DAILY	MONTH	FREQUENCY	LOCATION	SAMPLE TYPE
<b>Water Volumes</b>	750 gpd	July	Weekly	House meter	GPW Readings
<b>Spring Inspection:</b>					
Soil Treatment Area		April	Annual	Mound	Fill out Form 8-4a
Septic Tanks		April	Annual	Septic Tanks	Fill out Form 5-2
Pump Tank		April	Annual	Pump Tank	Fill out Form 6-3
<b>Fall Inspection:</b>					
Soil Treatment Area		October	Annual	Mound	Fill out Form 8-4a Questions 2, 3, 5, 6
Pump Tank		October	Annual	Pump Tank	Fill out Form 6-3 Questions 1b, 2a, 3c
<b>One-Time:</b>					
Jet Clean and Distal Head Measurement Baselines		April, 2012	One-Time	Mound Laterals	Fill out Form 8-4a, Question 4

### III. MAINTENANCE REQUIREMENTS:

PARAMETER	LOCATION	FREQUENCY
Septage removal	All septic tanks	As needed-when Scum and Sludge levels reach 25% accumulations (document measurements)
Effluent Removal And Backwashing	Pump tank	Sludge level is 25% from inlet of pump to bottom of tank (document measurement)

#### **IV. SCHEDULE OF COMPLIANCE**

12/31/2022 or if system fails, system must be operated as a holding tank.  
Apply for renewal of permit by 12/1/2022

#### **V. REPORTING REQUIREMENTS:**

Report annually with requirements of the operating permit to Cass County Environmental Services by January 1 of each year.

Cass County Environmental Services  
Courthouse, Box 3000  
Walker, MN 56484

The monitoring reports shall be signed by the owner. Copies are to be retained for your records.

Sampling and laboratory testing procedures, if required, shall be performed in accordance with Standard Methods.

#### **VI. NONCOMPLIANCE**

##### Permit Violation

Within 24 hours of becoming aware of a permit violation that may endanger human health or the environment, the Permittee shall notify the Cass County Environmental Services at (218) 547-7243. The Permittee shall submit a written description of the violation and a written plan to bring the system into compliance to Cass County Environmental Services within five days of discovery. Cass County Environmental Services shall review the plan and provide a date and conditions by which the system is required to be restored.

##### Operational Emergency

Cass County Environmental Services shall be notified at (218) 547-7243 in the event that the Permittee determines that immediate operational assistance is needed. The Permittee shall provide all pertinent information regarding the emergency. If a life-threatening situation exists, the Permittee shall first call 911.

##### Remedial Action

The Permittee shall take all reasonable steps to minimize the adverse impacts to human health, public drinking water supplies, or the environment resulting from a permit violation, or discharges of oil, toxic pollutants, or hazardous substances.

##### Written Reports

The Permittee shall include with the next monitoring report a written report describing any permit violation(s) that occurred during the reporting period. The report shall describe the discharge, including volume, duration, effluent characteristics, and location.