

**PWSID ME0091580**  
**SABATTUS SANITARY DISTRICT**  
**2023 Consumer Confidence Report**

**General Information**

**Water System Contact Name:** Paul H. Morin

**Address:** 190 Middle Road

**City, State, Zip Code:** Sabattus, Maine. 04280

**Telephone #:** 207-577-3177

**Fax#:** 207-375-4104

**Email:** pmorin@sabattus.org

**Report Covering Calendar Year:** Jan 1 - Dec 31, 2023

**Upcoming Regularly Scheduled Meeting(s):** November - 2024

**Source Water Information**

**Description of Water Source:** Wells: 2

The water division uses ground water as its water source. There are 2 wells, one located at Riley Rd. and the primary well located at Marsh Rd. They are both 12-inch gravel packed wells each location. Water hardness is 140 mg/l. The system currently has 64 hydrants. 2023 delivered 49,150,000 gallons of water to customers. The system maintains a 450,000 gallon concrete storage tank. The storage allows us to maintain an adequate supply during firefighting activities. The distribution system has approximately 8 miles of water main.

**Water Treatment & Filtration Information:**

The water division currently has no treatment but is set up for chlorination if needed. Hydrants are flushed Spring and fall to keep lines and water clean and more frequently if needed.

**Source Water Assessment:**

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices and public water systems.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health.

**Secondart Maximum Contaminant Level (SMCL)**

**Running Annual Average (RAA):** A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.

**Locational Running Annual Average (LRAA):** A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

**Action Level (AL):** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Units:**

ppm = parts per million or milligrams per liter (mg/L).

ppb = parts per billion or micrograms per liter (µg/L).

pCi/L = picocuries per liter (a measure of radioactivity).

pos = positive samples.

MFL = million fibers per liter

# Water Test Results

<i>Contaminant</i>	<i>Date</i>	<i>Results</i>	<i>MCL</i>	<i>MCLG</i>	<i>Possible Sources of Contamination</i>
--------------------	-------------	----------------	------------	-------------	--

## Microbiological

COLIFORM (TCR) (1)	Mar 2023	<b>3 pos</b>	1 pos/mo or 5%	0 pos	Naturally present in the environment.
--------------------	----------	--------------	----------------	-------	---------------------------------------

## Inorganics

ARSENIC (6)	3/16/2023	<b>3.2 ppb</b>	10 ppb	0 ppb	Erosion of natural deposits. Runoff from orchards, glass and electronics production wastes.
BARIUM	3/16/2023	<b>0.0091 ppm</b>	2 ppm	2 ppm	Discharge of drilling wastes. Discharge from metal refineries. Erosion of natural deposits.
CHROMIUM	3/16/2023	<b>1.7 ppb</b>	100 ppb	100 ppb	Discharge from steel and pulp mills. Erosion of natural deposits.
NITRATE (5)	3/16/2023	<b>2.66 ppm</b>	10 ppm	10 ppm	Runoff from fertilizer use. Leaching from septic tanks, sewage. Erosion of natural deposits.

## Radionuclides

COMBINED RADIUM (-226 & -228)	3/17/2021	<b>1.4 pCi/l</b>	5 pCi/l	0 pCi/l	Erosion of natural deposits.
COMBINED URANIUM	3/16/2023	<b>4.5 ppb</b>	30 ppb	0 ppb	Erosion of natural deposits.
RADIUM-226	3/17/2021	<b>1.4 pCi/l</b>	5 pCi/l	0 pCi/l	Erosion of natural deposits.

## Lead/Copper

LEAD 90TH% VALUE (4)	1/1/2021 - 12/31/2023	<b>2.1 ppb</b> <b>Range (0-6.5 ppb)</b>	AL = 15 ppb	0 ppb	Corrosion of household plumbing systems.
COPPER 90TH% VALUE (4)	1/1/2021 - 12/31/2023	<b>0.223 ppm</b> <b>Range (0.072-0.289 ppm)</b>	AL = 1.3 ppm	1.3 ppm	Corrosion of household plumbing systems.

### Notes:

- 1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
- 2) E. Coli: E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely-compromised immune systems.
- 3) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
- 4) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
- 5) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
- 6) Arsenic: While your drinking water may meet EPA's standard for Arsenic, if it contains between 5 to 10 ppb you should know that the standard balances the current understanding of arsenic's possible health effects against the costs of removing it from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. Quarterly compliance is based on running annual average.
- 7) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
- 8) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
- 9) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.
- 10) PFAS: The degree of risk depends on the level of chemicals and duration of exposure. Laboratory studies of animals exposed to high doses of PFAS have shown numerous negative effects such as issues with reproduction, growth and development, thyroid function, immune system, neurology, as well as injury to the liver. Research is still relatively new, and more needs to be done to fully assess exposure effects on the human body.

**All other regulated drinking water contaminants were below detection levels.**

**Secondary Contaminants (You are not required to list detects for secondary contaminants, but this information, particularly sodium levels, might be useful to your customers. The decision to supply this information in your CCR is up to you.)**

SULFATE	18 ppm	3/16/2023
SODIUM	10.4 ppm	3/16/2023
CHLORIDE	20 ppm	3/16/2023
MAGNESIUM	5 ppm	3/16/2023

## Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

**Radioactive Contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or at the following link:

**<https://www.epa.gov/ccr/forms/contact-us-about-consumer-confidence-reports>**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sabattus Sanitary District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at the following link:

**<http://www.epa.gov/safewater/lead>**

## **Total Coliform Bacteria Level Assessments**

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any issues that were found during these assessments.

A Level 1 Assessment is an investigation of the water system designed to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. During the past year, we triggered Level One assessment(s) that was/were escalated to a Level Two assessment (see below).

A Level 2 Assessment is a more detailed investigation of the water system designed to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred or why our water system continues to show total coliform bacteria on multiple occasions even after completing a Level 1 Assessment. During the past year, we were required to conduct 1 Level Two assessment(s). We completed 1 Level Two assessment(s). We were not required to take any corrective actions.

## **Violations**

**No Violations in 2023**

## **Waiver Information (to be included in the CCR for systems that were granted a waiver)**

In 2023, our system was granted a 'Synthetic Organics Waiver.' This is a three year exemption from the monitoring/reporting requirements for the following industrial chemical(s): TOXAPHENE/CHLORDANE/PCB, HERBICIDES, CARBAMATE PESTICIDES. This waiver was granted due to the absence of these potential sources of contamination within a half mile radius of the water source(s).