



Monday, December 4, 2023

WELL INFORMATION:

WI Unique Well Number **JE928**
 Add 2118 Cook Dr
 City Somerset
 State WI Zip 54025
 County SAINT CROIX
 Town Star Prairie

Legal Description

SE NW Sec 21 T 31 R 18W
 1/4 1/4 (section) (town) (range)
 Map : Gov't Lot#

Year well installed

Casing Diameter:

3" - less 4-9" 10-18" 18+"

Total well depth 102
 Depth of casing 98
 Depth to water 38

SOURCE:

Municipal Spring
 Other

TREATMENT SYSTEM(S) OWNED:

Water softener Rev Osmosis
 Carbon filter Neutralizer
 Particle filter Iron Filter
 Other

PROBLEMS OBSERVED:

Color Taste Odor
 Corrosion Health None
 Other

LAST DATE TESTED:

Never Unknown
 Less than 1 year 1-2 years
 2-5 years 5-10 years
 Greater than 10 years

REASON FOR TESTING:

Curious about water quality
 Suspect water quality problems
 Regularly test my well
 Required by lending institution
 Retest of positive bacteria test
 Retest following well disinfection
 Infant/pregnant woman/daycare
 Other CGMP

MAIL TO:

Town of Prairie
 2118 Cook Dr
 Somerset WI 54025

SAMPLE(S) COLLECTED

Date 10/25/2023
 Time 11:00

SAMPLE(S) TAKEN FROM:

Pressure Tank
 Kitchen faucet
 Bathroom faucet
 Outside faucet
 Barn
 Other

Sample ID 140697
 Labno 2300558-CM
 Group ST CROIX 23OCT

COMMENT:

LABORATORY RESULTS

Parameter	Qualifier	Results	Units
Hardness-Total	Less Than	5	mg/l CaCO3
Alkalinity		218	mg/l CaCO3
Conductivity		396	umhos/cm
pH		8.48	std units
Saturation Index		-0.9	Corrosivity Slight
Nitrogen-Nitrate/Nitrite	Less Than	0.1	mg/l N
Chloride		2.0	mg/l

Disclaimer- The analyses run on your samples only cover some of the more common water quality characteristics. Safe levels of these chemicals or bacteria do not guarantee that your water is free of all toxic chemicals. If you suspect gasoline residues, pesticides, or other trace chemicals, you would need additional analyses. Contact the lab or your Extension office for more information.