Town of Newport ZONING/CODES DEPARTMENT REPORT

Summary Report for Period of:	13-Jan-15		to	9-Feb-15
Building Permit Section				
A I' I'				
Applications Filed	2			
Permits Approved Permits under review	2 1			
	1			
Permits Rejected				
Fees Collected	\$	270.00		
Inspection Section				
Field Inspections	4			
Office Actions	4			
Stop Work Orders				
Complaints Received				
Complaints Inspected				
TOTAL INSPECTIONS	8			
Other Notes				
Permits: Kasarda (\$NA), Snyder (\$270)			
TOTAL MILES DRIVEN:	26.5			
Respectfully Submitted,				
Ut =				
	-			
Clifton Bennett				

Town of Newport

ZONING/CODES DEPARTMENT

DAILY INSPECTION RECORD

Feb-15

				rep-15	
DATE	#	Location	Owner or Agent	Inspection Type	Miles
16-Jan		Office	Town of Newport	filed year end reports with NYSDOC, electronically done	
6-Feb		484 Rose Valley Rd	Ed Kasarda	issued permit for maintenance work to furnace due to fire reported on 1/9/15	
6-Feb		484 Rose Valley Rd	Ed Kasarda	inpected furnace, ed had the furnace cleaned and a regular maintenance done by Snyder Fuel, looks ok will issue certificate of compliance today	5.5
6-Feb		2608 Newport Rd	Art Felio PERMIT#24-14	did a walk thru with Art, rough electric is started, framing almost complete, project is stopped for a few weeks until the weather breaks	4
6-Feb		250 Twin Ponds Drive	Thomas Marioti PERMIT#01-14	did a final walk thru with tom, all set will issue C of O today	5
6-Feb		613 Strumlock Rd	Anthony Kattato PERMIT#25-14	did a walk thru with Anthony, had a couple questions about the fireplace and framing, discussed the fireproofing that needs to be done around the fireplace, he has started rough electric, on-going, he will call me prior to insulation and sheetrock	12
6-Feb		623 Honey Hill Rd	PERMIT #01-15 Matt Snyder	received plans from Matt Snyder for an 1800 sf addition to his house, the plans are stamped by an Engineer, all looks in order, I will issue a Permit today	6
6-Feb		546 Butler Rd	Cris Zook	received plans from AMISH Cris Zook, there is no mention of the type of lumber or any reference to Chapter 23 of the NYS Building Codes. I will contact John Ferris regarding this and have him correct this with the Engineer	×