



**AGENDA ITEM NO. 7.C.**

DATE: January 24, 2019  
TO: Board of Directors  
FROM: Rene A. Ramirez, Operations Manager  
Joubin Pakpour, P.E., District Engineer

---

**SUBJECT: CONSIDER RESOLUTION 2019-02 AUTHORIZING AWARD OF CONTRACT TO STOLOSKI & GONZALEZ, INC., FOR CONSTRUCTION OF THE HILLCREST PRESSURE REGULATING STATION IN THE AMOUNT OF \$649,620, AND PROVIDING A 20% PROJECT CONTINGENCY IN THE AMOUNT OF \$129,924, FOR A TOTAL PROJECT BUDGET OF \$779,544.**

---

**RECOMMENDATION**

Approve Resolution 2019-02 authorizing award of a contract to Stoloski & Gonzalez, Inc., from Half Moon Bay, CA for the construction of the Hillcrest Pressure Reducing Station in the amount of \$649,620 and a 20% project contingency in the amount of \$129,924 for a total project budget of \$779,544

**FISCAL IMPACT**

|   |                  |
|---|------------------|
| Original Estimate FY 15/16  | \$250,000        |
| 2019 Construction Estimate with several years of Construction inflation 17% | \$292,500        |
| 2018 Engineer's Estimate  | \$795,000        |
| Lowest Responsible Bid  | \$649,620        |
| Plus 20% Contingency  | <u>\$129,924</u> |
| Total Project Budget  | \$779,544        |

Pakpour Consulting Group will provide construction management and District staff will provide inspection services for the construction project. Funding for the Hillcrest Pressure Reducing Station Project will come from the Certificates of Participation (COP) for the entire amount.

**DISCUSSION**

One of the District’s turn-outs for water supply from the SFPUC is located near the City of Redwood City’s Tank Site on Hillcrest Drive, which is known as the Hillcrest Meter Station (HMS). Water from the HMS sends water into the District’s Zone 1 (lowest zone in the system). The HMS currently has no pressure regulation and when the SFPUC makes changes to their supply from Hetch-Hetchy to surface water sources in the East Bay, staff has to manage pressure increases in Zone 1. Without pressure regulation, the District has had several large water main breaks in Zone 1 over the years. This project will provide the District with the ability to manage pressure from the SFPUC near the HMS and mitigate pressure spikes in Zone 1 due to SFPUC operations.

District Engineer, Joubin Pakpour, P.E., will lead the discussion for this project. His detailed report of the bids is attached.

Attachments:     Resolution 2019-02  
                      Contract for Construction of Hillcrest Pressure Regulating Station  
                      Pakpour Consulting Group, Inc., Recommendation of Award dated January 17, 2019

---

BOARD ACTION: APPROVED:\_\_\_\_\_ DENIED:\_\_\_\_\_ POSTPONED:\_\_\_\_\_ STAFF DIRECTION:\_\_\_\_\_

UNANIMOUS\_\_\_\_\_ VELLA\_\_\_\_\_ ZUCCA\_\_\_\_\_ WARDEN\_\_\_\_\_ SCHMIDT\_\_\_\_\_ WHEELER\_\_\_\_\_