

## STAINLESS STEEL VENT-HOOD FOR DARKROOM WALL SINKS

THIS VENT-HOOD MOUNTED OVER A WALL SINK SAFELY REMOVES CHEMICAL FUMES FROM OPEN TRAYS WHILE PROVIDING A HANDY SHELF FOR TIMERS & ACCESSORIES. IT IS MADE ENTIRELY OF 316/304 STAINLESS STEEL (IN GAUGES RANGING FROM 18-14) INERT TO ALL PHOTO DARKROOM CHEMICALS.




TABLE FOR DETERMINING cfm EXHAUST REQUIREMENTS

VENT-HOOD MODEL	OVERALL HOOD LENGTH	OVERALL SINK LENGTH	cfm Required at intake of each Stack					LOSSES IN INCHES IN EACH STACK	QUANTITY OF 8\"
SVH-TT-48	4'	4'	400	500	600	700	800	0.22	1
SVH-TT-60	5'	5'	500	625	750	875	1,000	0.37	1
SVH-TT-72	6'	6'	600	750	900	1,050	1,200	0.55	1
SVH-TT-84	7'	7'	700	875	1,050	1,225	1,400	0.69	1
SVH-TT-96	8'	8'	800	1,000	1,200	1,400	1,600	0.85	1
SVH-TT-108	9'	9'	900	1,125	1,350	1,570	1,800	1.02	1
SVH-TT-120	10'	10'	1,000	1,250	1,500	1,750	2,000	1.16	1
SVH-TT-132	11'	11'	550	688	825	963	1,100	0.41	2
SVH-TT-144	12'	12'	600	750	900	1,050	1,200	0.55	2
SVH-TT-156	13'	13'	651	813	976	1,138	1,301	0.60	2
SVH-TT-168	14'	14'	700	875	1,050	1,225	1,400	0.73	2
SVH-TT-180	15'	15'	750	938	1,125	1,313	1,500	0.78	2
SVH-TT-192	16'	16'	800	1,000	1,200	1,400	1,600	0.85	2
SVH-TT-204	17'	17'	850	1,063	1,275	1,488	1,700	1.01	2
SVH-TT-216	18'	18'	900	1,125	1,350	1,575	1,800	1.02	2
SVH-TT-228	19'	19'	950	1,188	1,425	1,663	1,900	1.02	2
SVH-TT-240	20'	20'	1,000	1,250	1,500	1,750	2,000	1.16	2

- 8" Ø Stainless steel fume duct is supplied for a ceiling height of 10'.
- Chemical fumes travel to center of hood, away from students' faces
- Adjustable damper plates allow for final, on-site, air-balancing (by others)
- Mount vent-hood so that the shelf surface is not more than 20' above the sink rail for the optimum efficiency
- Utility shelf is 11 1/2" wide for timers and darkroom accessories
- Engineered up-draft fume exhaust design is quiet, safe and efficient
- Above ceiling ductwork and exhaust fans are not supplied because of various building configurations
- State-of-the-art design enhances and does not obstruct processing
- Sufficient make-up air must be supplied to the darkroom so that the vent-hood will function as designed
- Chemical fumes are captured evenly throughout the entire length of the sink

P1-2