

# Events Analysis Regional Insights or NERC Lessons Learned Review

Prepared by Task Force/Working Group CO-10

Date:

Regional Insights or NERC Lessons Learned reviewed :	Description: Loss of station observability
Lessons Learned 20101202	
Describe Area of Concern Addressed:	Loss of Communications and SCADA control
TF/ WG Action Taken( if any):	The WG did not consider the Ground Potential issue and we will refer to appropriate group. Reviewed the remaining components of the incidents and we have determined that actions taken by the entity were appropriate.
Identify Similar Experience ( if applicable):	N/A
State Any Supplemental Insights:	We agree with the corrective action and feel that best practice is to source power for RTUs, transducers and related critical communications be supplied from station battery/UPS
As a result of this review, has a Reliability Gap Identified in a NERC Standard or an NPCC Criterion or Guideline?	N/A
Where additional specificity can be added to existing NPCC Guidelines or Criteria, Cite reference and propose addition or change :	N/A