



Panasonic

Model name		SEER						SCOP																
								Warmer					Average				Colder							
Indoor unit	Outdoor unit	A - G	kW	SEER	*2 kWh/annum			A - G	kW	SCOP	*2 kWh/annum	elbu (2°C) kW	A - G	kW	SCOP	*2 kWh/annum			elbu (-10°C) kW	A - G	kW	SCOP	*2 kWh/annum	elbu (-22°C) kW
CS-HZ25TKE	CU-HZ25TKE	A++	2,5	7,8	112	55	61	-	X	X	X	X	A+++	3,0	5,2	808	60	62	0,00	-	X	X	X	X
CS-HZ25TKE-5	CU-HZ25TKE-5	A++	2,5	7,8	112	55	61	-	X	X	X	X	A+++	3,0	5,2	808	60	62	0,00	-	X	X	X	X
CS-HZ35TKE	CU-HZ35TKE	A++	3,5	7,6	161	58	63	-	X	X	X	X	A+++	3,8	5,1	1043	61	65	0,00	-	X	X	X	X
CS-NZ25TKE	CU-NZ25TKE	A++	2,5	7,4	118	55	61	-	X	X	X	X	A++	2,8	4,6	852	58	63	0,00	-	X	X	X	X
CS-NZ35TKE	CU-NZ35TKE	A++	3,5	7,1	173	58	63	-	X	X	X	X	A++	3,6	4,6	1096	60	65	0,00	-	X	X	X	X
CS-CZ25TKE	CU-CZ25TKE	A++	2,5	6,6	133	55	61	-	X	X	X	X	A+	2,8	4,1	956	56	62	0,00	-	X	X	X	X
CS-CZ35TKE	CU-CZ35TKE	A++	3,5	6,3	194	58	63	-	X	X	X	X	A+	3,6	4,1	1229	58	65	0,00	-	X	X	X	X

ENERGIA · ЕНЕРГИЯ · ΕΝΕΡΓΕΙΑ · ENERGIJA · ENERGY · ENERGIE · ENERGI

626/2011

R32 (GWP=675) *1

*1

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leakage to the atmosphere. This appliance contains refrigerant fluid with GWP equal to 675. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

*2

Energy consumption "XYZ" kWh per year, based on standard test results.
Actual energy consumption will depend on how the appliance is used and where it is located.