

OFFICE JUNIOR ENGINEER PUBLIC HEALTH ENGINEERING DEPARTMENT PATAN

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 160

DATE: 20.03.2023

It is certified that an inspection team headed by 10.02.2023

JEN OFFICE PUBLIC HEALTH ENGINEERING DEPARTMENT PATAN Inspected the ASHA ACADEMY, RAMPURA ROAD PATAN, SIKAR (Name & address for the School) on 10-02-2023 and found water facilities, good health condition for the students and members of staff of the institution, and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

(Signature)
SECRETARY

Asha Devi Shikshan Sansthan
Kotra Neem Ka Thana (Sikar)

(Signature)
PRINCIPAL

ASHA ACADEMY
Patan, Distt. Sikar (Raj.)

(Signature)
कनिष्ठ अभियन्ता
जन स्व. स. विभाग
Signature with seal

Name SHAKEEL KHAN

Designation Junior Engineer

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Laboratory
SIKAR (Rajasthan)

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech. (chem.) 2022 - 2023 / 1178

Dated 13.02.2023

To,

Not Valid for legal case

Principal,
Asha Academy, Patan

District : Sikar
Block : Patan

Referene Your Letter No. 10 Date 30.01.2023

Name of Sample Taker : Manoj Kumar Saini

Date of Receipt : 30.01.2023

Date of Examination: 10.02.2023

Source	TW	BIS 10500:2012 Drinking Water Standards	
Location of Source	Asha Academy School me		
Gram Panchayat	Patan	Max. Desirable Limit	Max. Permissible Limit
Village/Town	Patan		
Village/Habitation	Patan		
Date of Collection	30.01.2023		
Lab. Sample No.	U 652		
Note: All Results except PH are in mg/lit.		-	-
1. PH	7.73	6.5 - 8.5	NR
2. Turbidity (NTU)	clear	1	5
3. Total Alkalinity (as CaCo ₃)	250	200	600
4. Total Hardness (as CaCo ₃)	300	200	600
5. Chloride (as Cl ⁻)	60	250	1000
6. Sulphate (as So ₄ ⁻)	17	200	400
7. Nitrate (as No ₃ ⁻)	25	45	NR
8. Fluorides (as F ⁻)	0.320	1.0	1.5
9. Total Dissolved Solids	640	500	2000

Remarks:- Sample not collected by Lab

A. Saini
कनिष्ठ अभियन्ता
जन स्वास्थ्य विभाग
उपमहानगर, सिकर
अनुभाग नैमकाथाना (ग्रामीण)

Rishi
SECRETARY
Asha Devi Shikshan Sansthan
Kotla Neem Ka Thana (Sikar)

H. D. Saini
Senior Chemist
सुरेश कुमार अग्रवाल
P.H.E.D. Laboratory, Sikar
वरिष्ठ रसायनज्ञ
जन स्वास्थ्य अभियांत्रिकी विभाग
प्रयोगशाला, सीकर

Pringh
PRINCIPAL
ASHA ACADEMY
Patan, Distt. Sikar (Raj.)

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 160

Dated: 20.03.2023

It is certified that an inspection team headed by 10.02.2023 SHAKEEL KHAN, J.
 (Name of Officers with designation) from JEN, Office Public Health ENGG, PAT,
 (Name of Department/ Office) inspected the ASHA ACADEMY, RAMPURA, PATAN
 (Name & Address of the school) on 10-02-23 (date of inspection) and found that the
ASHA ACADEMY, RAMPURA ROAD, PATAN, DISTT. SIKAR (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of one year


Signature with Seal: कनिष्ठ अभियन्ता
 जन सेवा: अभि: विभाग...
 Name: शकेल खान
 Designation: जन सेवा: नैम का थाना (सिकर)

Name & Address of the Office / Department :

To

ASHA ACADEMY,
RAMPURA, ROAD, PATAN, -DISTT. SIKAR - 332718

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


 SECRETARY

Asha Devi Shikshan Sansthan
 Kotra Neem Ka Thana (Sikar)



PRINCIPAL
 ASHA ACADEMY
 Patan, Distt. Sikar (Raj.)