

# Anatek Labs, Inc.

1282 Alluras Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1125-01 **Collect Date:** 06/27/23 12:00 **DOH Source #:** 01  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/29/23 13:12 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41880 (Well 1)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-12501**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/8/23 12:38	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/8/23 12:38	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/8/23 12:38	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/8/23 12:38	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/8/23 12:38	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

**System ID#** 10748      **System Name:** Camano Visa Water District  
**Reference Number:** MDF1125-01      **Collect Date:** 06/27/23 12:00      **DOH Source #:** 01  
**Multiple Source Nos:**      **Sample Type:** After      **County:** Island  
**Date Received:** 06/29/23 13:12      **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41880 (Well 1)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-12501**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	IRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutan oic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropa noic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 12:38	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

System ID# 10748 System Name: Camano Visa Water District  
 Reference Number: MDF1125-02 Collect Date: 06/27/23 13:35 DOH Source #: 02  
 Multiple Source Nos: Sample Type: After County: Island  
 Date Received: 06/29/23 13:12 Sample Purpose: RC - Routine/Compliance Sample  
 Sample Location: 23-10880 41881 (Well 2)  
 Matrix: Drinking Water

Lab/Sample Number: 125-12502

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFDA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/8/23 13:29	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/8/23 13:29	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/8/23 13:29	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/8/23 13:29	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/8/23 13:29	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

**System ID#:** 10748      **System Name:** Camano Visa Water District  
**Reference Number:** MDF1125-02      **Collect Date:** 06/27/23 13:35      **DOH Source #:** 02  
**Multiple Source Nos:**      **Sample Type:** After      **County:** Island  
**Date Received:** 06/29/23 13:12      **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41881 (Well 2)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-12502**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:29	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1125-03 **Collect Date:** 06/27/23 13:45 **DOH Source #:** 03  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/29/23 13:12 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41882 (Well 3)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-12503**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/8/23 13:55	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/8/23 13:55	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/8/23 13:55	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/8/23 13:55	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/8/23 13:55	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1125  
**Project:** 23-10880 41880,1,2  
**Reported:** 7/17/2023 12:33

## Analytical Results Report

**System ID#** 10748      **System Name:** Camano Visa Water District  
**Reference Number:** MDF1125-03      **Collect Date:** 06/27/23 13:45      **DOH Source #:** 03  
**Multiple Source Nos:**      **Sample Type:** After      **County:** Island  
**Date Received:** 06/29/23 13:12      **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41882 (Well 3)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-12503**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		7/8/23 13:55	MER	EPA 533	

Authorized Signature,



Justin Doty For Todd Taruscio, Laboratory Manager

**M2** Matrix spike recovery was low; the associated blank spike recovery was acceptable. Potential matrix effect.  
**LRL** Lab Reporting Limit  
**SDRL** State Detection Reporting Limit  
**ND** Not Detected  
**MCL** EPA's Maximum Contaminant Level  
**Dry** Sample results reported on a dry weight basis  
**SAL** State Action Level  
**\*** Not a certified analyte  
**RPD** Relative Percent Difference  
**%REC** Percent Recovery  
**Source** Sample that was spiked or duplicated.

This report shall not be reproduced except in full, without the written approval of the laboratory  
 The results reported related only to the samples indicated.

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-01 **Collect Date:** 06/27/23 12:50 **DOH Source #:** 05  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41883 (Well 5)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16201**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/11/23 20:23	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/11/23 20:23	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/11/23 20:23	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/11/23 20:23	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/11/23 20:23	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0445	ADONA 4,8-Dioxo-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxahexanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-01 **Collect Date:** 06/27/23 12:50 **DOH Source #:** 05  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41883 (Well 5)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16201**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutan oic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropa noic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:23	MER	EPA 533	



# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** . 10748      **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-02      **Collect Date:** 06/27/23 13:00      **DOH Source #:** 06  
**Multiple Source Nos:**      **Sample Type:** After      **County:** Island  
**Date Received:** 06/30/23 11:24      **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41884 (Well 6)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16202**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/11/23 20:49	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/11/23 20:49	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/11/23 20:49	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/11/23 20:49	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/11/23 20:49	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-02 **Collect Date:** 06/27/23 13:00 **DOH Source #:** 06  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41884 (Well 6)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16202**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutan oic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropa noic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane) sulfonic acid	ND	ng/L	2.00	2	--		7/11/23 20:49	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email [moscow@anateklabs.com](mailto:moscow@anateklabs.com)  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email [spokane@anateklabs.com](mailto:spokane@anateklabs.com)

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-03 **Collect Date:** 06/27/23 13:15 **DOH Source #:** 08  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41885 (Well 7)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16203**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/9/23 1:03	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/9/23 1:03	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/9/23 1:03	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/9/23 1:03	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/9/23 1:03	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0445	ADONA 4,8-Dioxa-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0446	9CI-PF3ONS	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0447	HFPO-DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0448	11CI-PF3OUdS	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email [moscow@anateklabs.com](mailto:moscow@anateklabs.com)  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email [spokane@anateklabs.com](mailto:spokane@anateklabs.com)

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-03 **Collect Date:** 06/27/23 13:15 **DOH Source #:** 08  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41885 (Well 7)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16203**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:03	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
 504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
 Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748 **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-04 **Collect Date:** 06/27/23 13:25 **DOH Source #:** 09  
**Multiple Source Nos:** **Sample Type:** After **County:** Island  
**Date Received:** 06/30/23 11:24 **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41886 (Well 8)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16204**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0434	PFOA Perfluorooctanoic acid	ND	ng/L	2.00	2	10		7/9/23 1:28	MER	EPA 533	
0433	PFOS Perfluorooctanesulfonic acid	ND	ng/L	2.00	2	15		7/9/23 1:28	MER	EPA 533	
0431	PFHxS Perfluorohexanesulfonic acid	ND	ng/L	2.00	2	65		7/9/23 1:28	MER	EPA 533	
0432	PFNA Perfluorononanoic acid	ND	ng/L	2.00	2	9		7/9/23 1:28	MER	EPA 533	
0429	PFBS Perfluorobutanesulfonic acid	ND	ng/L	2.00	2	345		7/9/23 1:28	MER	EPA 533	
0430	PFHpA Perfluoroheptanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0435	PFHxA Perfluorohexanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0436	PFDA Perfluorodecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0437	PFUnA Perfluoroundecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0438	PFDoA Perfluorododecanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0445	ADONA 4,8-Dioxo-3H-perfluorononanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0446	9Cl-PF3ONS	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0447	HFPO DA Hexafluoropropylene oxide dimer acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0448	11Cl-PF3OUdS	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0450	4:2FTS 1H,1H,2H,2H-Perfluorohexane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0451	6:2FTS 1H,1H,2H,2H-Perfluorooctane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0452	8:2FTS 1H,1H,2H,2H-Perfluorodecane sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0453	NFDHA Nonafluoro-3,6-dioxaheptanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0454	PFBA Perfluorobutanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	

# Anatek Labs, Inc.

1282 Alturas Drive - Moscow, ID 83843 - (208) 883-2839 - email moscow@anateklabs.com  
504 E Sprague Ste. D - Spokane, WA 99202 - (509) 838-3999 - email spokane@anateklabs.com

**Client:** Camano Visa Water District  
**Address:** 1355 Pacific Place, Suite 101  
Ferndale, WA 98248  
**Attn:** Exact Scientific

**Work Order:** MDF1162  
**Project:** 23-10880 41883-41886  
**Reported:** 7/17/2023 13:56

## Analytical Results Report

**System ID#** 10748      **System Name:** Camano Visa Water District  
**Reference Number:** MDF1162-04      **Collect Date:** 06/27/23 13:25      **DOH Source #:** 09  
**Multiple Source Nos:**      **Sample Type:** After      **County:** Island  
**Date Received:** 06/30/23 11:24      **Sample Purpose:** RC - Routine/Compliance Sample  
**Sample Location:** 23-10880 41886 (Well 8)  
**Matrix:** Drinking Water

**Lab/Sample Number: 125-16204**

### Per- and Polyfluoroalkyl Substances (PFAS)

DOH #	Analyte	Result	Units	LRL	SDRL	SAL	MCL	Analyzed	Analyst	Method	Qualifier
0455	PFHpS Perfluoroheptanesulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0456	PFMBA Perfluoro-4-methoxybutanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0457	PFMPA Perfluoro-3-methoxypropanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0458	PFPeA Perfluoropentanoic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0459	PFPeS Perfluoropentanesulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	
0460	PFEESA Perfluoro(2-ethoxyethane)sulfonic acid	ND	ng/L	2.00	2	--		7/9/23 1:28	MER	EPA 533	

Authorized Signature,



Justin Doty For Todd Taruscio, Laboratory Manager

**M2** Matrix spike recovery was low; the associated blank spike recovery was acceptable. Potential matrix effect.  
**LRL** Lab Reporting Limit  
**SDRL** State Detection Reporting Limit  
**ND** Not Detected  
**MCL** EPA's Maximum Contaminant Level  
**Dry** Sample results reported on a dry weight basis  
**SAL** State Action Level  
**\*** Not a certified analyte  
**RPD** Relative Percent Difference  
**%REC** Percent Recovery  
**Source** Sample that was spiked or duplicated.

This report shall not be reproduced except in full, without the written approval of the laboratory  
The results reported related only to the samples indicated.