



Solicitation Solicitation Amendment

1. Amendment Number A03 to Solicitation Number 360070-22-A-0016		Date 05/10/2022		
2a. Facility FORT MYERS, FL - P&DC		2b. Project K65332 C22P CCTV Upgrades 2640688		
3a. Offeror Name and Address		3b. Issued By IMPLEMENTATION ACQUISITION PO BOX 27497 GREENSBORO, NC 27498-1103		
		3c. Contact THOMAS M PIO 336-665-2873		
<p>4. The above numbered solicitation is amended as set forth in Block 5. Note: Offerors must acknowledge receipt of this amendment prior to the date and time specified in the solicitation by one of the following methods:</p> <ul style="list-style-type: none">a. By signing and returning one copy of the amendment;b. By acknowledging receipt of this amendment on each copy of the offer submitted; orc. By submitting a separate letter or telegram which includes a reference to the solicitation and amendment numbers. <p>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE SPECIFIED IN THE SOLICITATION PRIOR TO THE DATE AND TIME SPECIFIED FOR RECEIPT OF OFFERS MAY RESULT IN REJECTION OF YOUR OFFER.</p> <p>If by virtue of this amendment, you desire to change an offer already submitted, such change may be made by telegram or letter provided such telegram or letter makes reference to the solicitation and amendment numbers, and is received prior to the date and time specified. The date and time specified for receipt of offers is:</p>				
5. Description of Amendment: Amendment A03 serves to provide responses to contractors questions. All other terms and conditions remain the same.				
6. Contractor Signature		Date Signed	U. S. Postal Service Signature	Date Signed
Name of person authorized to sign		Contracting Officer NIKHIL SONI		



**Facilities Department
Attachment to Amendment**

1. Amendment Number ^{A03} to Solicitation Number 360070-22-A-0016

01 Contractor questions and answers

1. The specifications are broad and don't distinguish existing materials. Is the existing chilled water pipe steel or copper?

RESPONSE: During our site visit, the chilled water pipe was fully insulated and we were unable to determine the existing pipe material. The record documents by Korte Design, Inc., dated 3/6/98 specify pipe 2.5" and larger to be schedule 40 black seamless steel pipe and pipe 2" and smaller to be type L copper pipe.

2. Control dampers are listed, but not who the existing direct digital controls contractor is. Can you provide their contact information?

RESPONSE: Automated Building Controls Systems, Inc.