



August 11, 2025

File: 21020-50/WW/OP/Wroxton

RM of Calder #241  
Box 10  
Wroxton, SK S0A 4S0

Attention: Reeve and Council:

**RE: Rescinding Precautionary Drinking Water Advisory – Wroxton**

The Water Security Agency, in consultation with the Saskatchewan Health Authority, are advising that the **“Precautionary Drinking Water Advisory” (PDWA)** issued by the Water Security Agency for Wroxton’s potable water system be rescinded immediately this Monday August 11, 2025.

The rescinding of the PDWA was based upon information provided by your community, which included:

- 1) The work has been completed and the line re-pressurized.
- 2) Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- 3) The receipt of bacteriological samples collected one day apart and marked as “other” along with chlorine and turbidity results, that are negative for bacteriological growth in the distribution system mentioned above.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the RM of Calder in addressing the advisory.

Sincerely,

Lee Reinhart for:

A handwritten signature in black ink, appearing to read "R. Sheichuk".

Rick Sheichuk  
Environment Officer  
Water Security Agency

cc: Water Security Agency  
Saskatchewan Health Authority – Yorkton Office