








Class III


IP44



		
Ratio 100	Ratio 80	Ratio 60



**A****B****C**

Model	A	B	C
Ratio 100	100mm	100mm	92-95mm
Ratio 80	82mm	80mm	75mm
Ratio 60	63mm	60mm	55mm



WARNING - This product must be installed by a qualified installer.

Clearance Information - AS/NZS 3000 Wiring Rules



Location	Distance
A - Clearance above luminaire	0mm
B - Side clearance to Structural member	0mm
C - Clearance to thermal insulation	0mm