

Material Bid Specifications

Quantity	Item
24,000 L.F.	3" SDR-17 PVC Pipe (White or Blue)
7,000 L.F.	4" SDR-17 PVC Pipe (White or Blue)
14,000 L.F.	6" SDR-17 PVC Pipe (White or Blue)
13	6"x6"x6" D.I. C153 MJ Tee
19	3" MJ Resilient Wedge Gate Valve (2" Operating Nut, Left Open)
20	6" MJ Resilient Wedge Gate Valve (2" Operating Nut, Left Open)
16	3 ft. Bury Dry Barrel Fire Hydrant, 6" MJ Shoe, 5 1/4" Main Valve, Left Open, 3 Nozzle (2 - 2 1/2" Hose Nozzle & 1 - 5" STORZ Pumper nozzle design)
	Hydrants must be either Kennedy Guardian K81A or Mueller Super Centurion 250
	No other brands will be accepted
6	4 ft. Bury Dry Barrel Fire Hydrant, 6" MJ Shoe, 5 1/4" Main Valve, Left Open, 3 Nozzle (2 - 2 1/2" Hose Nozzle & 1 - 5" STORZ Pumper nozzle design)
	Hydrants must be either Kennedy Guardian K81A or Mueller Super Centurion 250
	No other brands will be accepted

- ¹ Bid will be awarded to the overall lowest total bid.
- ² All bids shall include the brand of material, unit cost, and total cost
- ³ Supplier shall provide The District with availability information and estimated delivery of said material
- ⁴ Bids shall include any and all applicable taxes, fees, charges, and shipping costs.
- ⁵ Must comply with all AWWA and Water District standards.
- ⁶ Wood Creek Water District reserves the right to wave any informalities and/or to reject or accept any or all bids.