



Submittal Requirements:
Special Hazard Systems

Important Note: Submittal guidelines for electronic submittal specifics are not contained in this document, please reference the “Electronic Submittal Requirements” document for electronic submittals specifics.

Generally, each submittal shall comply with the following requirements, at a minimum:

1. Each submittal shall contain enough information for Lund Fire Protection (LFP) to evaluate the entire system for compliance with all applicable provisions of the applicable standard and/or code. Poorly detailed and assembled submittals are unlikely to be approved by the jurisdiction and may lead to plan review delays and potentially resubmittal fees.
2. Each submittal shall consist of:
 - a. LFP Submittal Review Application legibly completed
 - b. Plans
 - c. Product Data
 - d. Calculations
 - e. Payment by physical check with physical copy of LFP application submitted to:

Mailing Address for U.S. Postal Service	Physical Address for other Parcel Services
Plan Review Lund Fire Protection, Inc. P.O. Box 459 Norwalk, Iowa 50211	Plan Review Lund Fire Protection, Inc. 124 Balfour Drive Norwalk, Iowa 50211

Plans shall be prepared in accordance with the following, at a minimum:

3. Drawn on sheets of uniform size
4. Drawn to a specified scale (drawn to 1/8” = 1’; details to 1/4” = 1’ or large enough to be legible)
5. Include plans of each floor
6. Contain all information required by the “Working Plans” paragraph of NFPA 2001 (or applicable NFPA standard)
7. Notes included on the plans shall be applicable to the project being submitted

Product data shall be prepared in accordance with the following, at a minimum:

8. Product data pages shall be submitted for each product which is required to be listed by the applicable NFPA standard
9. Each product data shall be annotated to clearly indicate model, size, finish, orientation, or any other defining product characteristics

Calculations shall be prepared in accordance with the following, at a minimum:

10. Contain all information required by the applicable NFPA standard and the product manufacturer

Note: Special Hazard Systems are intended to include, but not necessarily limited to: clean agent suppression systems, water mist systems, air sampling detection systems, carbon dioxide suppression systems, & dry chemical suppression systems. For other systems please contact LFP for submittal requirements.

“Working Together to Keep Your Community Safe”

P.O. Box 459 Norwalk, IA 50211 www.lundfp.com
(p) 515.981.0912 (f) 515.981.0913