

March 20, 2024

City of Belmont, NC

Project: Chronicle St. Overflow Parking Lot

ADDENDUM #2

- How thick should the stone be?
  - Stone should be a minimum of six (6) inches.