

## Unregulated Inorganic Contaminants

These unregulated inorganic contaminants were not required to be tested, rather the City of Belmont voluntarily tested these so both the City and its consumers could better understand the drinking water. It should be noted these samples were taken throughout the water system rather than just at the water plant effluent.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2021	<b>0.16</b>	0.12	0.19
Chromium (ppb)	2021	<b>ND</b>	ND	ND
Strontium (ppb)	2021	<b>30.20</b>	29	32
Vanadium (ppb)	2021	<b>0.26</b>	ND	0.35
Molybdenum (ppb)	2021	<b>0.18</b>	0.16	0.20
Cobalt (ppb)	2021	<b>ND</b>	ND	ND

Contaminant (units)	Sample Date*	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2020	<b>0.12</b>	0.07	0.19
Chromium (ppb)	2020	<b>ND</b>	ND	ND
Strontium (ppb)	2020	<b>34.86</b>	30	42
Vanadium (ppb)	2020	<b>0.51</b>	ND	0.94
Molybdenum (ppb)	2020	<b>0.17</b>	ND	0.31
Cobalt (ppb)	2020	<b>0.01</b>	ND	0.11

\*June & July results not included due to contract lab error.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2019	<b>0.10</b>	0.02	0.37
Chromium (ppb)	2019	<b>ND</b>	ND	ND
Strontium (ppb)	2019	<b>34.63</b>	29	43
Vanadium (ppb)	2019*	<b>0.68</b>	0.35	1.10
Molybdenum (ppb)	2019	<b>0.16</b>	0.09	0.28
Cobalt (ppb)	2019	<b>0.01</b>	ND	0.14

\*January & April 2019 results showed contamination in some field blanks. Results adjusted.