

Unregulated Inorganic Contaminants

These unregulated inorganic contaminants were not required to be tested, rather the City of Belmont voluntarily tested these so both the City and its consumers could better understand the drinking water. It should be noted these samples were taken throughout the water system rather than just at the water plant effluent.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2020	0.11	0.07	0.17
Chromium (ppb)	2020	ND	ND	ND
Strontium (ppb)	2020	37.56	32	42
Vanadium (ppb)	2020	0.50	ND	0.94
Molybdenum (ppb)	2020	0.15	0.11	0.18
Cobalt (ppb)	2020	ND	ND	ND

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2019	0.10	0.02	0.37
Chromium (ppb)	2019	ND	ND	ND
Strontium (ppb)	2019	34.63	29	43
Vanadium (ppb)	2019*	0.68	0.35	1.10
Molybdenum (ppb)	2019	0.16	0.09	0.28
Cobalt (ppb)	2019	0.01	ND	0.14

*January & April 2019 results showed contamination in some field blanks. Results adjusted.

Contaminant (units)	Sample Date	Your Water (average)	Range	
			Low	High
Chromium-6 (ppb)	2018	0.10	0.01	0.20
Chromium (ppb)	2018	ND	ND	ND
Strontium (ppb)	2018	34.71	27	51
Vanadium (ppb)	2018*	0.43	ND	0.75
Molybdenum (ppb)	2018	0.16	ND	0.28
Cobalt (ppb)	2018	0.01	ND	0.16

*March – June & December 2018 results showed contamination in some field blanks. Results adjusted.