



The following is a required list of parts to be used for a ¾", 1" and 2" water connection and for Fire Meter Service. Per City of Belmont

Water Service Connections for ¾" Meter:

Water Service Saddle	Smith Blair 313 for iron/metal piping and 317 for PVC Stainless Steel Bands
1" Corporation Stop	Mueller H-15008
1" Copper	Type K Soft Copper
1" x ¾" Curb Stop	Mueller B-24350
¾" Meter Resetter	Mueller H141182N 7" H
¾" Straight Coupling	Mueller H-10871
Meter	5/8" x ¾" VOGA2945 w/Nicor (Hersey)
Remote Disconnect Meter	5/8" x ¾" HEMVOGD294M4 w/Nicor (Hersey)
Meter Box	12x17x12 D1200 Body with 12" drop in lid w/2" AMR TR hole

Water Service Connections for 1" Meter:

Water Service Saddle	Smith Blair 313 for iron/metal piping and 317 for PVC Stainless Steel Bands
1" Corporation Stop	Mueller H-15008
1" Copper	Type K Soft Copper
1" Curb Stop	Mueller B-24350
1" Meter Resetter	Mueller H141182N 10"H
1" Straight Coupling	Mueller H-10871
Meter	1" VOKS2945 w/Nicor (Hersey)
Meter Box	12x19x12 D1200 Body with 12" drop in lid w/2" AMR TR hole

Water Service Connections for 2" Meter:

Water Service Saddle	Smith Blair 313 for iron/metal piping and 317 for PVC Stainless Steel Bands
2" Corporation Stop	Mueller H-15013
2" Copper	Type K Soft Copper
2" Curb Stop	Mueller B-25172
2" Meter Resetter	VHH77-12B-11-77
Meter	2" WOPN29155 (Hersey)
Meter Box	DFWA4C – 12 – 1A with black AMR Lid

*** Larger meters will be Hersey meters and you will need to contact Mueller Systems for all part numbers

*** For all Facilities requiring Backflow Preventers an approved list and test forms are available on the City's Website at www.cityofbelmont.org

UPDATED 1/14/21