

Stormwater Wetland Inspection Report
City of Belmont, North Carolina

Project Name: _____ Inspection Date: _____
 Inspector Name: _____ Inspector Email: _____
 Inspector Phone #: _____ Inspector Signature: _____
 Date of Last Rain Event: _____ Amount of Last of Rain: _____
 Owner Name: _____ Owner Address: _____

_____ Aerial Photo of Site and Photographs of BMP Attached (required)

Code Key: N/A = Not Applicable | M = Monitor (potential for future problems) | WN = Work Needed

Potential Problem	Code	Comments
Entire BMP		
Trash/debris is present		

Perimeter of Wetland		
Bare soil/erosive gullies		
Vegetation is too short or too long		
Other (describe)		

Inlet Device: Pipe, Stone Verge or Swale		
The pipe is clogged (if applicable)		
The pipe is cracked or otherwise damaged		
Erosion is occurring in the swale (if applicable)		
Stone Verge is clogged or covered in sediment		
Other (describe)		

Forebay		
Sediment/debris Accumulation		
Erosion has occurred		
Invasive Vegetation		
Flow is bypassing pretreatment		
Other (describe)		

Deep Pool, Shallow Water and Shallow Land Areas		
Algal growth over 50% of normal pool water surface		
Invasive vegetation over 50% of normal pool		
Shallow land flooded more than 5 days after storm		
Plants are dead, diseased or dying		
Pruning needed for optimal plant health		
Sediment accumulation (75% of original deep pool depth)		
Other (describe)		

Stormwater Wetland Inspection Report
City of Belmont, North Carolina

Embankment		
Tree growth on embankment		
Needs repair (determined by appropriate professional)		
Evidence of muskrat or beaver activity is present		
Other (describe)		

Micropool		
Sediment accumulation (75% of original pool depth)		
Other (describe)		

Outlet Device		
Clogging has occurred		
Device is damaged		
Debris on trash rack		
Other (describe)		

Receiving Water		
Erosion or other signs of damage at the outlet		
Other (describe)		

Miscellaneous		
Access		
Vandalism		
Signage (if applicable)		
Other (describe)		

Additional Comments/Recommendations:

Please notify us when work is complete or if you have questions.

Stormwater Wetland Inspection Report
City of Belmont, North Carolina

1. Name of the Land Owner: _____

Address of the Land Owner: _____

2. Recorded book and page number for the lot of this structural BMP: Book _____ Page _____

3. The following repairs and maintenance are needed at this time: (if no repairs or maintenance are needed at this time, insert N/A and move to item 4.)

Original signature and seal of the engineer, surveyor, or landscape architect:

Signature and Title

Seal

4. Certificate of compliance:

This BMP is performing properly and is in compliance with the terms and conditions of the approved maintenance agreement as required by the City of Belmont Watershed Protection Ordinance and the adopted Gaston County Stormwater Ordinance.

Original signature and seal of the engineer, surveyor, or landscape architect:

Signature and Title

Seal