CITY OF BELVEDERE SPECIFICATIONS FOR CONCRETE CURB, GUTTER, SIDEWALK AND DRIVEWAY APPROACH CONSTRUCTION

- 1. Subgrade shall be compacted to at least 95% relative compaction in the top 6 inches.
- 2. Where unsuitable subgrade material is encountered, the City's representative may require remedial work to be done, including, but not limited to, placing a layer of Class 2 aggregate under the concrete section.
- Existing concrete shall be removed at expansion or weakened plane joints or at sawcuts.
- 4. Sawcuts must be at least 1-1/2 inches deep.
- 5. No utility boxes or poles will be permitted in the sidewalk area without the written approval of the City's representative.
- 6. All concrete finishes shall be broom finish and or other finish as approved by the City's representative.
- 7. Concrete shall be State Class B, 5 sack mix with ¾ inch maximum aggregate. Belvedere requires 2 pounds of Davis Superblack per cubic yard concrete. No additional color shall be added except as approved by the City's representative to match existing concrete.
- 8. Concrete shall have a slump of not more than 4 inches.
- 9. No admixtures shall be used without the permission of the City's representative.
- 10. No concrete shall be placed until the City's representative has inspected and approved forms and subgrade.

See Diagrams on next two pages.



