

**ADA Transition Plan
Physical Barriers Removed
FY2015-16**

| Location | Problem Identified | Recommended Solution | Est. Cost | Actual Cost | Date Corrected |
|-----------|---|---|-----------|-------------|--|
| Town Hall | Doorway connecting to the west office from the Foyer is less than 32 inches in width. | Widen doorway or provide alternative entrance to office area. | \$12,000 | \$ - | Estimated completion is 2017 as part of the Town Hall CIP project. |
| Town Hall | Restrooms between office area and Council Chamber are not ADA compliant. | Bring restrooms into ADA compliance. | \$200,000 | \$ - | Estimated completion is 2017 as part of the Town Hall CIP project. |