



**Town of Colma  
Access Control  
Bid RFI List - 2/26/2018**

<b>Bid RFI #</b>	<b>Bid RFI Description</b>	<b>Responses</b>
1	I am interested in obtaining the Dongle Number of your current system (Bosch Ready-Key Pro....which is actually a re-branded Lenel system) in effort to re-engineer my bid.	This information is not available for the bid. Bidders are to bid based on device quantities shown on bid plans. Dongle information can be obtained by the successful responsive bidder after a contract is awarded.
2	Will the Town of Colma accept Samsung/Hanwha Techwin Cameras as equal as long as all technical specifications are met?	The brands specified in Section 28 23 00 represent reference models of construction and functional robustness. We would further be concerned with implementing MPEG5 compression at the current time.
3	The Access Control Spec calls out for Genetec Synergis Enterprise when Synergis Professional will suffice to fit the specification due to Genetec Omnicast Enterprise being utilized. Will the Town of Colma accept Genetec Synergis Professional in place of Enterprise? Functionality of the system will fit all the technical criteria detailed as Genetec Failover will be programmable through Genetec Omnicast Enterprise.	Provided the quantitative requirements of the specifications (including quantity of cameras, readers, viewing stations, etc.) are met as well as all of the specified functional features, there will not be an objection to providing a different tier of software than specified.
4	Is the Town of Colma looking for 12 months storage retention for both PD and Town Hall cameras or just the PD? If its just the PD that needs 12 months are you looking for only 30-60 days for Town Hall?	The storage requirement is project-wide, including the cameras of both sites.