

5b

August 2021

On 8/3/2021 we had a sewer line collapse at the corner of Pecan and Ave N. We blocked off the road that night and began work the next day. The excavation was slow due to avoiding water mains on both sides, and the depth of the sewer main. Although I had Todd and Larry their as well, at the end of the first day, we needed additional help. So, I called another crew in for Friday. By Friday night around 10:30 pm we had finished the job and the road was back open for the weekend.

8/9/2021 a 2-inch water main came apart on E Cypress and Ave F. To keep the customers with water, we chose to fix it without turning the water supply off. It took most of the day and had to remove the sidewalk before work could begin. The sidewalk has been replaced but I haven't repaired the street with asphalt.

The daily average discharge was 172,586 gal per day at the WWTP with no violations.

We pumped 6,700,000 gal of water for the month. The addition of reading unbilled meters won't come to light till the end of the month after billing.

BJ Sultemeier

[View Certification](#) | [Download COR](#)

DMR Copy of Submission

Permit TX0052973
Permit ID: TX0052973
Permittee: JOHNSON CITY, CITY OF
Facility: JOHNSON CITY MUNICIPAL WWTP
Permitted Feature: 001 - External Outfall
Report Dates & Status
Monitoring Period: From 07/01/21 to 07/31/21
Status: **NetDMR Validated**
Discharge: 001-A - DOMESTIC FACILITY - 001
DMR Due Date: 08/20/21

Considerations for Form Completion

Principal Executive Officer
First Name: Rick
Title: City Manager
Last Name: Schroder
Telephone: 830-868-7111

No Data Indicator (NODI)

Form NODI: -

Code	Parameter Name	NODI	Quantity or Loading	Quality or Concentration	# of Ex.	Freq. of Analysis	Smpl. Type
			Value 1	Value 2	Units		
00300	Oxygen, dissolved [DO]	Smpl.	=6.3		19 - mg/L	01/07 - Weekly	GR - GRAB
1 - Effluent Gross		Req.	>=5.0 MO MIN		19 - mg/L	01/07 - Weekly	GR - GRAB
NODI: -		NODI					
00400	pH	Smpl.	=7.9	=8.0	12 - SU	01/30 - Monthly	GR - GRAB
1 - Effluent Gross							

Code	Name	Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units	of Ex.	Analysis	Type
Season: 0		Req.			>=6.0 MINIMUM		<=9.0 MAXIMUM	12 - SU		01/30 - Monthly	GR - GRAB
NODI: -		NODI									
00530	Solids, total suspended										
1 - Effluent Gross		Smpl.	=20.15	26 - lb/d	=14.0		=29.0	19 - mg/L		01/07 - Weekly	GR - GRAB
Season: 0		Req.	<=38.0 DAILY AV	26 - lb/d	<=15.0 DAILY AV		<=60.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
NODI: -		NODI									
00610	Nitrogen, ammonia total [as N]										
1 - Effluent Gross		Smpl.	=2.33	26 - lb/d	=1.62		=2.0	19 - mg/L		01/07 - Weekly	GR - GRAB
Season: 0		Req.	<=7.6 DAILY AV	26 - lb/d	<=3.0 DAILY AV		<=15.0 SINGGRAB	19 - mg/L		01/07 - Weekly	GR - GRAB
NODI: -		NODI									
50050	Flow, in conduit or thru treatment plant										
1 - Effluent Gross		Smpl.	=0.172586	03 - MGD	=0.255029					05/WK - Five Per Week	IN - INSTAN
Season: 0		Req.	<=0.303 DAILY AV	03 - MGD	Req Mon DAILY MX					05/WK - Five Per Week	IN - INSTAN
NODI: -		NODI									
50060	Chlorine, total residual										
1 - Effluent Gross		Smpl.			=1.12		=3.9	19 - mg/L		05/WK - Five Per Week	GR - GRAB
Season: 0		Req.			>=1.0 MO MIN		<=4.0 MO MAX	19 - mg/L		05/WK - Five Per Week	GR - GRAB
NODI: -		NODI									
51040	E. coli										
1 - Effluent Gross		Smpl.			=0.0		=0.0	3Z - CFU/100ml		01/30 - Monthly	GR - GRAB
Season: 0		Req.			<=126.0 DAILY AV		<=399.0 SINGGRAB	3Z - CFU/100ml		01/30 - Monthly	GR - GRAB
NODI: -		NODI									
80082	BOD, carbonaceous [5 day, 20 C]										
1 - Effluent Gross		Smpl.	=5.75	26 - lb/d	=4.0		=6.0	19 - mg/L		01/07 - Weekly	GR - GRAB

Code	Name	Value 1	Value 2	Units	Value 1	Value 2	Value 3	Units	of Ex.	Analysis	Type
Season: 0		Req. <=25.0 DAILY AV		26 - lb/d						01/07 - Weekly	GR - GRAB
NODI: -		NODI									

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

JOHNSON CITY, CITY OF

User: bsultemeier@johnsoncitytx.org
 Name: Brent Sultemeier
 E-Mail: bsultemeier@johnsoncitytx.org
 Date/Time: 2021-08-25 16:35 (Time Zone: -05:00)

Report Last Signed By

User: bsultemeier@johnsoncitytx.org
 Name: Brent Sultemeier
 E-Mail: bsultemeier@johnsoncitytx.org
 Date/Time: 2021-08-25 16:35 (Time Zone: -05:00)



POLICE DEPARTMENT

Chief of Police Ross Allen

P.O. Box 159 • 406 West Main Street

Johnson City, Texas 78636

Office (830) 868-0995 • Fax (830) 868-2095 • E-mail policechief@johnsoncitytx.org

Summary of August 2021

JCPD had 148 Calls for service

JCPD made 109 Traffic stops

15 Citations Issued

JCPD Investigated 5 Crashes

JCPD made 25 Out of city assists

JCPD made 10 Arrests

- 1 Arrest for Disorderly Conduct.
- 2 Warrant Arrests.
- 1 Arrest for Poss. Of Controlled Substance.
- 1 Arrest for Driving While Intoxicated.
- 3 Arrest for Assault Family Violence.
- 1 Arrest for Harassment.
- 1 Arrest for MIP Tobacco.

Personnel

Nothing to report for the month of August.

Public Safety


On 08-06-2021, Officer Ethan Bishop received a call-in reference to a possible intoxicated driver traveling into the city on West US 290. Officer Bishop was able to find the driver and after observing several traffic infractions stopped the car. While speaking with the driver Officer Bishop observed signs of possible intoxication and upon further investigation determined the driver to be under the influence of an illicit substance. An arrest for driving while intoxicated was made and the driver agreed to the taking of a blood specimen. This specimen has been submitted to the DPS Crime Lab for analysis.

On 08-25-2021, Officer Ethan Bishop was patrolling in the 800 block of US HWY 281 South when he observed a black Dodge Challenger parked/abandoned on the shoulder of the highway. When Officer Bishop ran the license plate the vehicle came back stolen out of San Angelo, Texas. The car was impounded and was reported to SAPD as recovered.

If any of you have any questions or feedback on my monthly reports, please feel free to contact me.

Respectfully,

Chief Ross Allen



5d

8/2/2021

We had our August Court Docket. We had a minimal turnout, but we were productive with all cases.

Warrants were issued on those Defendants that did not show up. We sent Conviction Letters to any Show Cause Hearing "no shows". We will be able to issue Capias Pro Fine Warrants to said individuals after 30 days, if non-compliant. We want the Warrants issued prior to the February Warrant Round Up. The court issued a total of 24 warrants, and still going.

Judge and I will be discussing some City Ordinance Violation fines that were not previously set by our previous Judge. We have a few ordinance violations that have been issued and are being pursued.

Our next bigger project will be how to handle the cases from Judge Riedel's hearings, in November & December, that were "no shows". Since we were not issuing warrants or FTAs at that time, these cases have remained stagnant. More than likely we will reset them with Judge Walston.

Our next docket is the last week of September.

We have closed out August with the City's incoming collections totaling \$3568.68 after the State's remittance. We disposed of 23 cases. 10 were "new" within the last 6 months (4 were dismissed by Compliance, DSC, or Deferred). 13 were "older" cases. 6 of the older cases were Dismissed with Plea Agreements with or without attorneys. One of those Defendants with 2 charges was proven Deceased. We started the month with 1310 pending cases, and ending with 1285.



Permit Report

08/01/2021 - 08/31/2021

Permit Date	Field Type	Applicant Name	Applicant Address	Project Type	Status	Description	Value of Project	Sq Ft
8/18/2021	Special Event	Blanco Co. Fair & Rodeo Assoc.	PO Box 261	Commercial	Septic	2021 Blanco Co. Fair & Rodeo Parade	0	0
8/23/2021	Platting	Bonita Baskin Revocable	PO Box 1670	Residential	Septic	Plat Application	0	0
8/26/2021	Foundation Repair	Methodist Church	103 N LBJ Drive	Commercial	Septic	Repair Foundation	26,000	0
8/31/2021	Fence	Mark Shannon	505 E Main Street	Commercial	City	Put a fence up on sides and back yard	0	0
8/23/2021	Other	Robby & Nora Castro	206 Avenue O	Residential	City	Put in new HVAC	0	0
8/24/2021	Remodeling	Wesley LaCrone	101 Old Austin Hwy	Residential	City	Turn workshop into a home	0	1,104
8/18/2021	Remodeling	Jeff & Karen Hulett	105 N Avenue C	Residential	City	Add a bathroom and closet	0	240
8/19/2021	Sewer Tap	Bill Aydam(LaCrone Property)	101 B Old Austin Hey	Residential	City	Put in a Water & Sewer Tap	0	1,200
8/23/2021	New Construction	Darbar Construction	144 Brianna Circle	Residential	City	Build New Home	0	1,296
8/4/2021	Other	Jeanne Parker	401 E Elem Drive	Residential	City	New HVAC	0	0
8/4/2021	New Construction	Darbar Construction	107 Brianna Circle	Residential	City	Build New Home	0	1,380
8/5/2021	Certificate of Occupancy	LBJ Middle School	502 E Cypress	Commercial	City	Kitchen Portable near little Middle School. Plumbing and Electrical update	0	0
8/5/2021	Certificate of Occupancy	LBJ Administration	304 N LBJ Drive	Commercial	City	Administration Offices	0	0
8/5/2021	Certificate of Occupancy	LBJ Shockley Field Baseball	505 N Nugent Avenue	Commercial	City	Shockley Field Baseball Restrooms	0	0
8/16/2021	Platting	Amanda Martin	128 Martin Bros Ln	Commercial	City	Platting	0	0
8/17/2021	Remodeling	Johnson City Bank	117 Nugent Ave.	Commercial	City	Remodel front half of building only, and replace the outer wall in front of building	70,000	876
8/17/2021	Sign	Stephanie Bass	117 Nugent Avenue	Commercial	City	Sign	0	876
8/18/2021	Other	Oscar Segura	110 Leaning Oak Circle	Residential	City	Put in a Storage Unit	0	0
8/18/2021	Platting	Johnson City RV Park	408 N US Hwy 281	Commercial	City	RV Park	0	0
8/18/2021	Special Event	Moonshine Ridge, Inc.	104 E. Pecan Dr., Ste. 1838	Commercial	City	9/11 Special Event	0	0

Total Records: 20

9/1/2021



Work Order Report

08/01/2021 - 08/31/2021

Work Order #	Work Order Date	Issued By	Department	Issued to	Work Requested	Requestor Name	Location of work to be performed	Description	Requested Completion Date	Status	Date Completed	Notes
808	8/31/2021	Rick Schroder	Public Works	BJ Sultemeier	Mowing of City Property	Rick Schroder	Multiple Locations		9/30/2021	Open		
807	8/31/2021	Rick Schroder	Public Works	BJ Sultemeier	Street Maintenance	Rick Schroder	Intersection of Scofield Ave. and Old Austin Hwy.		9/30/2021	Open		Place large rectangular boulders along triangle to prevent traffic cutting through
806	8/31/2021	Rick Schroder	Parks & Recreation	BJ Sultemeier	Park Equipment Repair Requests	Rick Schroder	City Park		9/30/2021	Open		Vinyl fencing fronting Nugent; one cap is missing from the top of a post; replace
805	8/31/2021	Rick Schroder	Public Works	BJ Sultemeier	Street Sweeping	Rick Schroder	Multiple		9/30/2021	Open		LBJ/Ash & LBJ Dr.
804	8/31/2021	Rick Schroder	Public Works	BJ Sultemeier	Traffic Sign Complaints	Rick Schroder	Multiple Locations		9/30/2021	Open		
803	8/27/2021	Whitney Walston	Public Works		City Building Maintenance		City Hall Flag		8/27/2021	Open	1/1/1900	US Flags at Half-Staff Immediately Until Sunset on Monday, August 30, 2021
802	8/23/2021	Whitney Walston	Utilities	Larry Bible	Water Problems		Dr Bushnells/Laura Smith		1/1/1900	Open	1/1/1900	Leak at meter box
801	8/23/2021	Betty Eckenrode	Public Works	Larry Bible	Other	Rhonda Post Master	201 S Ave G		8/27/2021	Open		Post Office Meter leaking
800	8/20/2021	Rick Schroder	Public Works	BJ Sultemeier	City Building Maintenance	Rick Schroder	Citywide / Recycle Center		8/27/2021	Open		Please move all recycling center equipment, tools, trailers, etc. to the recycling center for cataloguing and auction. Again, everything that was associated with or purchased for the recycling center should be relocated - if not already there - to the recycling center facility.
799	8/19/2021	Whitney Walston	Utilities	Larry Bible	Water Problems	Derek Percenti	202 E Bluebonnet		1/1/1900	Open	1/1/1900	Hi Whitney, My family is the owner of 202 E Bluebonnet and we have been dealing with a leak coming from a water valve. We had somebody come out before to look at it but they were supposed to come back since they didn't have the replacement part. The water valve is in the front yard close to the street, it's technically the city's water

798	8/19/2021	Betty Eckenrode	Parks & Recreation	Todd Kneese	Parks & Recreation Maintenance Requests	Church member	620 N Nugent	Todd will fix it	8/20/2021	Closed	8/24/2021	toilet , replace the wax ring
797	8/18/2021	Whitney Walston	Public Works	BJ Sultemeier	Potholes		Cedar Drive					Resident said there is a giant pothole that keeps getting bigger and bigger
796	8/18/2021	BJ Sultemeier	Public Works	Todd Kneese	Drainage Concern		Ave N and Pecan West side			Open		Culvert needs cleaned
795	8/17/2021	Betty Eckenrode	Public Works	Larry Bible	Grounds Maintenance	Betty Eckenrode	713 Liveoak Drive	need to change the meter		Open		the meter is not logging water usage
794	8/12/2021	Whitney Walston	Utilities	Larry Bible		Darbar Construction	106 and 108 Brianna		8/13/2021	Closed		Water needs to be turned on at those address and final readings taken (if you havent already) for 111 & 104 Brianna
793	8/11/2021	Trish Mikla	Public Works	BJ Sultemeier	Water Problems	Kevin Jacks	708 Live Oak	Water standing at meter. leak	1/1/1900		1/1/1900	
792	8/10/2021	BJ Sultemeier	Public Works	Todd Kneese	Drainage Concern	203 N Ave J	203 N Ave J	Johns Plemmons	8/13/2021	Open	1/1/1900	Need to jet the line on N Ave J from Pecan back to the Eagle well to see how far the line goes down the street and the size of the line!
791	8/10/2021	Rick Schroder	Public Works	BJ Sultemeier	Traffic Sign Complaints	Rick Schroder	Ave. G & Bluebonnet	See photo	8/13/2021	Open		Street signage is falling off.
790	8/4/2021	Whitney Walston	Public Works	Todd Kneese	City Building Maintenance		Men's bathroom at big park	See BJ with any questions	8/5/2021	Closed	8/11/2021	The toilet paper dispenser rod is jammed.
789	8/4/2021	Whitney Walston	Public Works	Todd Kneese	Broken Fences / Walls		Community Building	See BJ with any questions	8/5/2021	Closed	8/6/2021	The double doors in the front of the building are not closing correctly. Continued issue with the striker plate
788	8/2/2021	Rick Schroder	Public Works	BJ Sultemeier	City Building Maintenance	Rick Schroder	Council Chambers		8/3/2021	Closed		The lights in Council Chambers need to be replaced / fixed prior to tomorrow's City Council Meeting

Total Records: 21

8/11/2021